

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT			3		3		3				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	7	4	7	4	7	0	0	
	Grand Total	1082	6468	4	11	4	11	4	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.12.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Sri Rangapur	Mogiligidda	33KV	Shadnagar	17.10	17.30	00.20	E/L&O/L	33KV Insulator failed at 132KV SS Sri Rangapur	Mogiligidda	Alternate supply arranged from 33KV Shadnagar at 17:30Hrs
1	SDPT	Husnabad	Koheda	33KV	Husnabad	20:30	23:59	3:29		Jumper cut	Koheda	No
2		Siddipet	Thornala	33KV	Siddipet	13.45	14.45	01.00		Insulator failed	Thornala	No
3		Siddipet	Pedhakodur	33KV	Siddipet	07.45	09.15	01.30		Jumper cut	Pedhakodur	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nemmani	Merlakunta	11KV	Nalgonda	5:40	7:40	2:00	E/L	11KV Jumper Cut	No
2		Penpahad	Penpahad	11KV	Suryapet	09.30	11.40	02.10	E/L	11KV Insulator failed	No
3		Dirincherla	Narsaigudem	11KV	Huzurnagar	08.00	09.30	01.30	E/L	11KV Line snapped	No
4		MT.Pally	Mulkalapally	11KV	Bhongir	08.30	11.30	03.00	EL/OL	11KV Line pin binding failed	No
5		Golankonda	Matoor	11KV	Bhongir	01.30	06.30	05.00	E/L	11KV Line snapped near Sharbanapuram (v)	No
6		Rajapeta	Narsapuram	11KV	Bhongir	00.30	10.15	09.45	E/L	11KV Line snapped near Narsapuram (V)	No
7		Pallerla	Pallerla	11KV	Bhongir	8:20	9:45	1:25	EL/OL	11KV Line snapped at Maloni well near Pallerla (V)	No
1	HYD N	N.I.M.S	Babu Khan Chambers	11KV	X	01.20	02.30	01.10	EL	Double feeding Point Cable fault at Opp: Taj Krishna	No
1	HYD S	Ch' Baradari	Ch' Baradari	11KV	III	02.30	03.55	01.25	EL	Lorry ramed to Pole at Mothi Galli (2No. DTR's Kept Off)	17:18 Hrs 2No.DTR's charged
1	HYD C	Durga Nagar	Sunder Nagar	11KV	II	09.25	10.28	01.03	EL,OL-Rph	No Visible Fault	Arranged B/F on 11KV Kamala Ngr for
2		Nampally	Amba Hospital	11KV	VII	11.55	13.18	01.23	EL	GHMC Crane ramed to Pole at New Mallepally (3No. DTR's Kept Off)	17:35 Hrs 3No.DTR's charged