

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988									
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	2	0	2	0	2	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Madgulapally	Thadakamalla	33kv	Miryalaguda	12.40	15.00	02.20	O/L	Line over lap two phases	Thadakamalla	-
2		220KV MLG	NATL	33kv	Miryalaguda	14.15	17.00	02.45	O/L	Moment fault	NATL	-

TSSPDCL - LMRC / Corporate office

Date: 22.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kothamolgara	Maddigatla	11kv	Jadcherla	04.45	12.40	07.55		11 KV Jumper cut and DTR failed near Maddigatla (v)	-
1	SDPT	Husnabad	Madatha	11kv	Husnabad	06.00	07.30	01.30		BD due to Conductor snapped	-
1	RR S	Madinaguda	Hafeezpet	11kv	Gachibowli	02.53	03.55	01.02	BD	11KV line snapped at Madinaguda	-
2		Gachibowli	Aparna	11kv	Gachibowli	08.14	09.20	01.06	BD	11KV line snapped at Aparna main gate	-
1	RR N	Aleap	Dr Colony Cable	11kv	Jeedimetla	00.38	02.00	01.22	EL/OL	11kv Endy Kit Failure At Pt-No96 Dr colony	-
2		Jeedimetla-I	ApiiC Colony	11kv	Jeedimetla	17.20	18.50	01.30	EL/OL	11kv Ab Cable Failure At Hammale Adda	-