

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	1	4	1	4	1	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		7		7		7			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	2	11	2	11	2	11	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/33KV Singotam	Kollapur	33kv	Nagarkurnool	11.05	13.31	02.26	E/L	Due to Tree Branches Fallen on the Line	Kollapur	-
1	HYD N	132KV J' Hills	Road No.13A (Road No.12)	33kv	Jubilee Hills	17.10	17.14	00.04	EL,OL-Rph	Cable damaged by Master Plan Wing, near Police Commodo Control Room	Road No.13A (Road No.12)	Loads transferred onto 13KV J' Hills SS via 33KV Road No.12 fdr

TSSPDCL - LMRC / Corporate office

Date: 23.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Inupamula	11kv	Nalgonda	11.40	12.45	01.05	EL	Insulator failed	-
2		Jammigadda	Kesaram	11kv	Suryapet	16.00	17.30	01.30	EL	Insulator failed	-
3		Peddakandukur	Bahupet	11kv	Bhongir	14.40	16.30	01.50	EL	11kv Insulator Failed	-
4		Chamapur	Chandepally	11kv	Bhongir	11.30	14.00	02.30	EL	63kva DTR Failed	-
5		Mothkur	Anajipur	11kv	Bhongir	07.10	07.30	00.20	EL	11 kv Line snapped	-
6		Paladugu	Duppelly	11kv	Bhongir	00.30	08.00	07.30	EL	11 kv Line snapped	-
7		Aroor	Lingarajupally	11kv	Choutuppal	04.00	09.30	05.30	EL	11 kv Line snapped	-
1	RR N	Aliabad	Majeedpur	11kv	Medchal	06.55	08.25	01.30	BD	Bird fallen on the 11Kv Line at Modi Builders, Aliabad Road	-
2		Town Medchal	Jyothi Nagar	11kv	Medchal	19.46	20.26	00.40	BD	11KV Pin Insulator Failed at Jyothi Nagar(11KV Line AB Switch Opened)	-
1	HVD S	Kandikal Gate	Gazimillath Colony	11kv	Charminar	02.05	04.36	02.31	EL,OL-Bph	Cable fault	Arranged B/F on 11KV Kandikal Gate feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	TTD S	Miralam	Madina Masjid	11kv	Charminar	14.02	15.55	01.53	EL,OL	Cable fault	Arranged B/F on 11KV Hasan Nagar feeder