

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		1		1		1			
3	MDK	107	933									
4	SDPT			1		1				1		1 No. 33kv still
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	2	2	2	1	2	1	0	
	Grand Total	1082	6468	2	4	2	4	1	4	1	0	

TSSPDCL - LMRC / Corporate office

Date: 29.12.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	GR Cable	33kv	Jadcherla	14.20	16.10	01.50	E/L	B/D due to LA Failed	GR Cable	-
1	SDPT	Mustyala	Komuravelly	33kv	Husnabad	08.45	00.00	15.15		No visible fault	Komuravelly	Arranged B/F on 33KV Duddeda SS

TSSPDCL - LMRC / Corporate office

Date: 29.12.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Hemajipur	Koilkunta	11kv	Jadcherla	23.40	08.45	09.05		11 KV Jumper Cut Near Koilkunta (v)	-
1	NLG	N B Gudem	Redlakunta	11kv	Huzurnagar	06.10	07.10	01.00	E/L	11Kv Line Snapped	-
1	RR N	Aliabad	Majeedpur	11kv	Medchal	15.55	17.40	01.45	BD	11KV Conductor Snapped and replaced at Modi Biluders, Aliabad	-
1	HYD S	Petlaburz	Chowk	11kv	Charminar	05.05	06.44	01.39	OL	Cable fault	Arranged B/F on 11KV Telephone Exchange fdr