

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	0	6	0	6	0	6	0	0	



TSSPDCL - LMRC / Corporate office

Date: 30.12.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Siripuram	Srirangapuram	11KV	Huzurnagar	5:15	7:00	1:45	EL	11KV Line snapped	No
2		Keethavarigudem	Laxmipuram	11KV	Huzurnagar	09.00	10.10	01.10	EL	11KV Line snapped	No
3		Palleria	Siddhapuram	11KV	Bhongiri	16.10	17.05	00.55	EL	11KV Line snapped near Palleria Vilage	No
1	SDPT	Gurjakunta	Dommata	11KV	Husnabad	11:50	14:00	2:10		11KV Line cut	No
1	RR S	IIIT	Kendriya Vihar	11KV	Gachibowli	13:10	14:15	1:05		11KV Line phase to phase near Bajaj Electronics at Vinayak Nagar.	No
1	HYD S	Falaknuma	Chatrinaka	11KV	III	12.28	14.25	01.57	EL,OL	I/C Cable fault	Arranged B/F on 11KV G.M.Chowni fdr