

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		13		13		13			
3	MDK	107	933		1		1		1			
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	17	1	17	1	17	0	0	
	Grand Total	1082	6468	1	23	1	23	1	23	0	0	

TSSPDCL - LMRC / Corporate office

Date: 01.07.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narwa	33KV	Narayanapet	16.50	17.30	00.40	E/L	33KV AB Switch opened at Narva towards Marikal	Narwa	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kandoor	Komreddypally	11KV	Jadcherla	11.10	13.45	02.35		11KV Insulator failed near Komreddypally (V)	No
2		Annasagar	Tatikonda	11KV	Jadcherla	08.55	12.20	03.25		11KV Jumper cut near Tatikonda (V)	No
1	NLG	Tatikol	Kacharam	11KV	Devarakonda	10:30	13:30	3:00	EL	11KV Jumper cut	No
2		Kuda Kuda	M G Nagar Thanda	11KV	Suryapet	11.00	13.05	02.05	E/L	Insulator failed	No
3		Ponugodu	Velidanda	11KV	Huzurnagar	10.55	13.42	02.47	EL	11KV line cut	No
4		Raghunadapalem	Nakkalagudem	11KV	Huzurnagar	09.50	13.00	03.10	EL	11KV Jumper cut	No
5		Munagala	Kokkireni-II	11KV	Huzurnagar	08.35	11.50	03.15	EL	11KV Line snapped	No
6		Nadigudem	Lift	11KV	Huzurnagar	07.45	09.50	02.05	EL	11KV line cut	No
7		Chandupatla	Chandupatla	11KV	Bhongir	02.30	08.20	05.50	EL	11KV Jumper cut near Chandupatla Village	No
8		Chandupatla	Kunnor	11KV	Bhongir	08.00	11.10	03.10	EL	11KV Jumper cut near Kunnor Village	No
9		CH.Laxmapuram	Madapur Agl	11KV	Bhongir	11.40	13.20	01.40	OL	11KV Line snapped at Kevulathanda near Madapur Village	No
10		Datherpally	Jangamappally	11KV	Bhongir	13.56	15.43	01.47	EL	11KV Jumper cut near Jangampally Village	No
11		Chada	Chada	11KV	Bhongir	10.30	14.30	04.00	EL	11KV Jumper cut near Chada Village	No
12		Narayanapur	Melacheruvu	11KV	Choutuppall	13.10	15.45	02.35	OL	11KV Line snapped near Melacheruvu Village	No
13		Voligonda	Dasireddygudem	11KV	Choutuppall	12:00	17:00	5:00	EL	Tree branchess fallen at line near Dasireddygudem Village	No
1	MDK	Munipally	Budhera	11KV	Sangareddy	14:00	15:12	1:12		Conductor cut	No
1	SDPT	Ramchandrapur	Vinjapally	11KV	Husnabad	15:10	15:40	0:30		Insulator failed	No
1	RR S	Shamshabad	Madhuranagar	11KV	Rajendranagar	12:40	14:20	1:40		Flex Banner fallen on 11kv Line at Madhuranagar	No
1	RR N	Subhash Nagar	Meenakshi	11KV	Medchal	19:43	20:01	0:23	EL	Lizard fallen on the 11KV line at Happy Homes	No
2		Jeedimetla SS - II	Komaply phorma	11KV	Jeedimetla	11.45	14.10	02.25	EL&OL	11KV Line AB cable failure at SS	No
1	RR E	Pocharam	Jodimetla	11KV	Keesara	11:02	11:47	0:45		Tree fallen on 11KV line Jodimetla	No
1	HYD N	Macha Bollarum	Father Balaiah Nagar	11KV	C-VI	11.30	13.20	01.50	EL	Jumper cut at Navya Enclave	No
2		I.D.P.L	Shivalayam	11KV	VI	12:05	13:20	1:15	EL	Cable fault at Railway Bridge, Sanath Nagar	No