

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		10		10		10			
	Total	606	3055	1	21	1	21	1	21	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		9		9		9			
3	MDK	107	933		3		3		3			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	13	1	13	1	13	0	0	
	Grand Total	1082	6468	2	34	2	34	2	34	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	CR Cable	33KV	Jadcherla	15.25	16.40	01.15	E/L	Tree Fallen on the Line	CR Cable	-
1	RR N	132KV LGM Pet	33KV MN Park	33KV	Medchal	18.20	20.50	02.30	BD	33KV Pin Insualator failed at Unique Biotech Company	33KV MN Park	-

TSSPDCL - LMRC / Corporate office

Date: 11.07.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Nawabpet	11KV	Jadcherla	13.45	14.46	01.01		B.D.11Kv Wire Cut Near Nawabpet(Vi).	-
1	NLG	Yerkaram	Yerkaram	11KV	Suryapeta	04.30	08.10	03.40	E/L	Insulator flashover	-
2		Raghunadapalem	Nakkalagudem	11KV	Huzurnagar	06.30	10.00	03.30	EL	Due to 11kv jumper cutted	-
3		Nadigudem	Krishnanagar	11KV	Huzurnagar	08.15	11.30	03.15	EL	Due to 11kv jumper cutted	-
4		Nadigudem	Nadigudem agl	11KV	Huzurnagar	04.00	07.00	03.00	EL	Due to HT/ LT fault Occurred	-
5		Mattampally	Allipuram	11KV	Huzurnagar	05.40	07.40	02.00	EL	Due to 11kv jumper cutted	-
6		Thoragal	Gandendragudem	11KV	Nalgonda	08.30	11.00	02.30	EL	11 KV Line Jumper Cut	-
7		Addagudur	Dharmaram	11KV	Bhongir	04.00	07.30	03.30	EL	11 kv Line Snapped at Banjarabavi Near Addagudur Village	-
8		Addagudur	Ch.Ramaram	11KV	Bhongir	04.00	07.30	03.30	EL	11 kv Line Snapped Near Chinnnpadishala Canal	-
9		Jai kesaram	Jai kesaram Indl	11KV	Choutuppal	02.00	05.00	03.00	EL/OL	11kv Pole Damaged Lorry near Jai.Kesaram Village	-
1	MDK	Kistareddypet	Beeramguda	11KV	Patancheru	17.10	18.50	01.40		B/D due to Jumper cut at Kistareddypet	-
2		Patancheru	MIA-I	11KV	Patancheru	08.50	09.20	00.30		B/D due to Jumper cut	-
3		Patancheru	Town-Indl.	11KV	Patancheru	17.40	19.00	01.20		B/D due to Tree branches fallen on the line	-
1	RR S	Nanakramguda	Church	11KV	Gachibowli	16.52	18.00	01.08		Due to heavy wind and rain,11kv Pin-insulator failed at Outerring road Nanakramguda	-
1	RR N	G Vikas	CoCo-Cola	11KV	Kukatpally	20.10	21.40	01.30	BD	11kv Pin insultor Failure At Excells Company	-
2		Jeedimetla-IV	Bhagylaxmi	11KV	Jeedimetla	16.30	17.40	01.10	BD	11kv Post Of insultor Failure near Konark company	-
3		Jeedimetla-III	Andhrapolymer	11KV	Jeedimetla	20.20	21.40	01.20	BD	Due To rain	-
4		Chintal	Bhagathsingh Nagar	11KV	Medchal	11.45	12.15	00.30	BD	11KV Line AB Opened at Mohan Chicken Shop(No Fault)	-
5		Dp pally	Gandi maisamma	11KV	Jeedimetla	17.40	18.40	01.00	BD	Due To rain	-
6		Devarayamjal	Kottapet	11KV	Medchal	04.10	06.00	01.50	BD	Tree Fallen on 11KV Line at VRL Godham,Yamjal	-
7		Kandlakoya	KV Reddy Nagar	11KV	Medchal	17.38	19.58	02.20	BD	11KV Pin Insualator failed at Tata Company	-
8		Kandlakoya	Saigeetha Asramam	11KV	Medchal	17.25	19.10	01.45	BD	11KV Pin Insulator failed at Saigeetha Asramam	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	AS Rao Nagar	Maruthi Nagar	11KV	Sainikpuri	22.32	23.17	00.45		11Kv Disk faialed & replacement at SS Opposite (Artisan Ravinder/Santhosh)	-
2		Aushapur	Aushapur	11KV	Keesara	17.10	18.40	01.30		11KV line cut at Aushapur high school	-
1	HYD N	H.M.T.	Sri Sai Colony	11KV	VI	19.55	00.38	04.43	EL	RMU Cable fault at Maruthi Nagar	Partial fdr charged at 20:00Hrs & remaining loads added on 11KV L&T feeder
2		Gunrock	M.D.F.	11KV	VI	20.10	21.35	01.25	EL,OL	No Visible Fault (Due to rain)	-
3		Gunrock	Surya Enclave	11KV	C-VI	20.20	21.35	01.15	EL	No Visible Fault (Due to rain)	-
4		Bowenpally	Ferozguda	11KV	VI	20.00	21.15	01.15	EL,OL	No Visible Fault (Due to rain)	-
5		Bowenpally	I.A.F.	11KV	VI	20.00	22.10	02.10	EL,OL-Bph	Tree branches fallen on lines at IAF Quarters	-
6		Prashanth Nagar	Sony Complex	11KV	VI	20.10	22.05	01.55	EL	End Kit failed at Prashanth Nagar (1No. DTR kept off)	-
7		Marredpally	Nehru Nagar	11KV	C-VI	21.10	22.50	01.40	EL	No Visible Fault (Due to rain)	Partial loads added on 11KV Hanuman Temple fdr at 22:23Hrs & remaining loads charged at SS
8		I.D.P.L.	Oblum	11KV	VI	20.10	22.35	02.25	OL	Tree branches fallen on lines at Varun Moters	-
9		Jubilee Hills	I.O.A.	11KV	X	22.50	00.10	01.20	All Indication	No Visible Fault (Due to rain)	-
1	HYD S	Miralam	N.S.Kunta	11KV	III	08.05	09.23	01.18	EL,OL	Cable fault at N.S.Kunta	Arranged B/F on 11KV Teegala Kunta feeder