

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403									
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	8	0	8	0	8	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	1	4	1	4	1			
2	NLG	144	988		7		7		7			
3	MDK	107	933		3		3		3			
4	SDPT				5		5		5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	16	4	16	4	16	0	0	
	Grand Total	1082	6468	4	24	4	24	4	24	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Marikal	Koilkonda Water Grid	33KV	Narayanapet	17.20	17.30	00.10	E/L	Loads tag on to 33KV Kondapur Feedeer	Marikal	Loads tag on to 33KV Kondapur Feedeer at 17:30Hrs
2		Gadwal	Nandinne	33KV	Gadwal	16.05	19.10	03.05	E/L	Falsh Over Insulator Replacement at Diyagadoddi Village	Gadwal	No
3		Gadwal	Bijwaram	33KV	Gadwal	16.10	23.30	07.20	E/L	33KV Conductor Snapped	Gadwal	No
4		leeza	Gattu	33KV	Gadwal	16.24	17.50	01.26	E/L&O/L	No Visible Fault	leeza	No

TSSPDCL - LMRC / Corporate office

Date: 13.07.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Annasagar	Annasagar	11KV	Jadcherla	01.05	07.30	06.25		11KV Wire Cut Near Annasagar(Vi).	-
1	NLG	Rayanguda	A.D.Pally	11KV	Nalgonda	07.00	09.20	02.20	E/L	11KV jumper cut	-
2		Bondugula	Parupally	11KV	Bhongir	07.00	09.20	02.20	OL	11 kv Line Snapped Near Kurraram Village	-
3		Choutuppal	Thangedipally	11KV	Choutuppal	11.30	13.25	01.55	OL	Phase to Phase at Katmaiah Colany Near Choutuppal Village	-
4		Huurnagar-2	Singaram	11KV	Huzurnagar	06.00	09.00	03.00	EL	Due to 11kv line cutted	-
5		Gaddipaly	Ponugodu	11KV	Huzurnagar	07.00	09.00	02.00	EL	Due to 11kv jumper cutted	-
6		Bethavolu	Bethavolu	11KV	Huzurnagar	02.00	05.00	03.00	EL	Due to 11KV line snapped	-
7		G.T.Giri	Gunjaloor	11KV	Suryapet	14.50	15.55	01.05	E/L	HT/LT Line Melt	-
1	MDK	Pati	Pati	11KV	Patancheru	19.15	20.30	01.15		BD due to Pin Insulator failed	-
2		Gummadidala	Agrobell	11KV	Patancheru	19.20	20.45	01.25		BD due to Conductor snapped	-
3		Gundla Machnoor	Industrial	11KV	Jogipet	19.30	21.00	01.30		BD due to Tree fallen on line	-
1	SDPT	Gouravelli	Gudatipally	11KV	Husnabad	16.00	18.30	02.30		Heavy gale and wind (3PH)	-
2		Guruvannapet	Pochampally	11KV	Husnabad	18.50	21.00	02.10		Heavy gale and wind (3PH)	-
3		Guruvannapet	Tapaspally	11KV	Husnabad	19.50	22.10	02.20		Heavy gale and wind (3PH)	-
4		Chityala	Thadur	11KV	Husnabad	20.25	22.30	02.05		Heavy gale and wind (3PH)	-
5		Chityala	Chityala	11KV	Husnabad	21.10	23.30	02.20		Heavy gale and wind (3PH)	-
1	RR S	Borabanda	Padmavathi Nagar	11KV	Kondapur	17.20	19.10	01.50	BD	11KV Jumper cut near Timber depo and Post off insulator failed at Allapur.	-
1	RR N	Jeedimetla-I	C S Wire	11KV	Jeedimetla	15.30	17.30	02.00	BD	11kv AB cable Failure opp Nakoda Chemical	-
2		Devarayamjal	Kottapet	11KV	Medchal	07.40	09.40	02.00	BD	Bird Fallen on 11KV Line at Six Pole DP	-
3		Medicity	Pudur	11KV	Medchal	20.00	22.30	02.30	BD	Tree fallen on the 11KV Line at Ganapur Village	-
4		Dp Pally	AGL gagillapur	11KV	Jeedimetla	19.03	22.35	03.32	BD	11kv Pin insultor failure At Gagillapur	-
1	HYD N	Macha Bollarum	Madhura Enclave	11KV	Bowenpally	15.45	16.50	01.05	EL,OL	Tree branches fallen on lines near Palavi School	-
1	HYD S	Ch' Baradari	Fire Station	11KV	Charminar	12.25	14.05	01.40	EL	Tree branches fallen on lines near Fire Station	-
1	HYD C	Exhibition	J.N	11KV	Saifabad	01.10	02.13	01.03	EL,OL-Rph	No Visible Fault	-