

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		15		15		15			
3	MDK	107	933		7		7		7			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	22	1	22	1	22	0	0	
	Grand Total	1082	6468	1	31	1	31	1	31	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.07.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Gadwal	Nandinne	33KV	Gadwal	15.40	18.15	02.35	E/L	Insulator replaced at Atmakur Mitta	Nandinne	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Arvapally	Kasarlaphad	11KV	Suryapet	9:30	12:06	2:36	E/L	11KV Conductor snapped	No
2		Akupamula	Kodadarampuram	11KV	Huzurnagar	05.00	07.30	02.30	E/L	11KV Jumper cut	No
3		Ananthagiri	Ameenabad	11KV	Huzurnagar	06.00	09.30	03.30	E/L	11KV Insulator failed	No
4		Garideapally	Appannapet	11KV	Huzurnagar	06.30	09.30	03.00	E/L	11KV Line snapped	No
5		Mattampally	Choutapally	11KV	Huzurnagar	6:30	09.00	02.30	E/L	11KV Line snapped	No
6		Sirikonda	Ravipahad	11KV	Huzurnagar	07.00	10.30	03.30	E/L	11KV Insulator failed	No
7		Mellacheruvu	Revoor	11KV	Huzurnagar	04.00	06.30	02.30	E/L	11KV Disc failed	No
8		Chandupatla	Chandupatla	11KV	Bhongir	04.00	08.40	04.40	E/L	11KV Line snapped near Ramachandra Puram (V)	No
9		NG.Bandal	Konapur	11KV	Bhongir	06.30	09.45	03.15	EL/OL	11kv Disc Failed & 11KV Line snapped near Ibrahimpur (V)	No
10		Veluvarthy	Sunkishala	11KV	Choutuppal	05.30	09.15	03.45	E/L	11KV Insulator failed near Sunkishala (V)	No
11		Nandipahad	Nandipahad	11KV	Miryalguda	05.50	08.30	02.40	E/L	11KV Jumper cut	No
12		Thimmapuram(Ramadugu)	Thimmapuram	11KV	Miryalguda	06.50	08.32	01.42	E/L	11KV Jumper cut	No
13		Arlagadda Gudem	Thatikal	11KV	Nalgonda	04.00	06.00	02.00	E/L	HT/LT Melting	No
14		Nemmani	Nemmani	11KV	Nalgonda	09.20	11.10	01.50	E/L	AB Switch femail cut	No
15		Ch.Mamidi	Kompally	11KV	Nalgonda	12:45	14:50	2:05	E/L	11KV Jumper cut	No
1	SDPT	Pandilla	Pandilla Express	11KV	Husnabad	0:00	9:00	9:00		Tree branch fallen on line	No
2		Katkur	Katkur Express	11KV	Husnabad	4:00	6:20	2:20		Lines touched	No
3		Gouravelly	Gudatipally	11KV	Husnabad	0:00	11:10	11:10		HT/LT lines touched	No
4		Guruvannapet	Posanpally	11KV	Husnabad	0:00	6:00	6:00		Due to gale and wind	No
5		Guruvannapet	Tapaspally	11KV	Husnabad	0:00	8:35	8:35		Disc failure	No
6		Bekkal	Kondapur	11KV	Husnabad	14:20	17:30	3:10		Disc failure	No
7		Dhoolmitta	Arjunpatla	11KV	Husnabad	14:30	17:00	2:30		Insulator failure	No
1	RR N	UMCC	Mahadevpuram	11KV	Medchal	02.20	03.30	01.10		11KV Jumper cut and replaced at Ramky Apartment	No
2		Bandamadaram	Barmajiguda	11KV	Medchal	00.00	03.15	03.15		11KV Brass Patti cut and replaced at Madura Water Plant	No
1	RR E	Aushapur	Aushapur	11KV	Keesara	08.30	10.00	01.30		Bird fallen on the 11KV line at Aushapur	No
2		Pocharam	Pocharam Village	11KV	Keesara	15.30	16.10	00.40		HT/LT line cut at Jodimetal	No
3		Singapur	RGK	11KV	Keesara	04.45	06.15	01.30		Disc failed at Modi main road	No
1	HYD N	Yellareddyguda	Maruthi Nagar	11KV	X	10.40	12.00	01.20	EL	Internet Cable fallen on lines at Padmaja Arcade	No
1	HYD S	Aliyabad	Boys Town	11KV	III	02.38	04.09	01.31	EL	Cable fault at Boys Town School	Arranged B/F on 11KV Masrath Function Hall for
2		Panjasha	Shajahan Hotel	11KV	III	2:51	4:24	1:33	EL	No Visible Fault	No
3		Falaknuma	Chatrinaka	11KV	III	3:34	4:40	1:06	EL,OL-Bph	No Visible Fault	No