

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	1	6	1	6	1	6	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1			
2	NLG	144	988		20		20		20			
3	MDK	107	933	1	3	1	3	1	3			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	26	2	26	2	26	0	0	
	Grand Total	1082	6468	3	32	3	32	3	32	0	0	

TSSPDCL - LMRC / Corporate office

Date: 15.07.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Ghanapur	Lattupally	33KV	Wanaparthi	18:32	18:57	00:25		Jumper cut due to Rain	Lattupally	Alternate supply arranged from 132KV SS Nagarkurnool
1	MDK	Pashamailaram	EPIP	33KV	Sangareddy	11:45	13:10	1:25		Jumper cut at Kirby	EPIP	No
1	RR N	132KV Medchal	33KV Medchal-I	33KV	Medchal	20:02	21:12	1:10		Tree fallen on the 33KV Line at Hindustan Company	Medchal-I	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Teegalapally	Town	11KV	Jadcherla	11.00	12.21	01.21		11KV Insulator failure near Mission Bhageeratha Teegalapally (V)	No
1	NLG	Reddygudem	Gorentla	11KV	Suryapeta	14:30	17:00	2:30	E/L	Insulator failed	No
2		Alingapuram	Channaipalem	11KV	Huzurnagar	12.20	14.15	01.55	EL	Due to 11KV Line snapped	No
3		Mukundapuram	Somaram	11KV	Huzurnagar	13.00	16.15	03.15	EL	Due to 11KV Jumper cut	No
4		Burugadda	Burugadda	11KV	Huzurnagar	14.30	17.00	02.30	EL	Due to 11KV Jumper cut	No
5		Kistapuram	Thammaram	11KV	Huzurnagar	14.30	17.10	02.40	EL	Due to 11KV Insulator Failure	No
6		Raghunadapalem	Gundlapally	11KV	Huzurnagar	10.30	11.45	01.15	EL	Due to 11KV jumper cut	No
7		Gaddipaly	Ponugodu	11KV	Huzurnagar	15.40	17.30	01.50	EL	Due to 11KV Line snapped	No
8		Gaddipaly	Medaram	11KV	Huzurnagar	15.40	17.15	01.35	EL	Due to 11KV Line snapped	No
9		Garidepally	L B Nagar	11KV	Huzurnagar	14.05	17.10	03.05	EL	Due to 11KV jumper cutted	No
10		Munagala	Munagala Industriual	11KV	Huzurnagar	04.00	07.00	03.00	EL	Due to 11Kv Jumper cut	No
11		Pamanagundla	Yerrasanigude	11KV	Nalgonda	05.00	08.30	03.30	EL	11 KV Line jumper cut	No
12		Arlagadda	Suraram	11KV	Nalgonda	14.45	15.25	00.40	EL	11KV Insulator Failure	No
13		Palem	Bopparam	11KV	Nalgonda	04.00	08.00	04.00	EL	11 KV Line jumper cut	No
14		Chityala	Chityala Town	11KV	Nalgonda	02.30	05.10	02.40	EL	11KV Insulator failure	No
15		Mamidala	Aregudem	11KV	Nalgonda	14.20	15.30	01.10	EL	11 KV Line jumper cut	No
16		Mamidala	Godavarigudem	11KV	Nalgonda	12.00	14.45	02.45	EL	11 KV Line jumper cut	No
17		Anantharam	Anantharam	11KV	Bhongiri	04.00	07.10	03.10	EL/OL	11KV Line snapped near Mudempally Vilage	No
18		Sharajipet	Saigudem	11KV	Bhongiri	07.15	09.00	01.45	EL/OL	11kv Line snapped near Saigudem Village	No
19		Rajapet	Rajapet Agl	11KV	Bhongiri	02.30	07.30	05.00	EL	11KV Insulator failure	No
20		Rajapet	Renikunta	11KV	Bhongiri	03.00	07.30	04.30	EL/OL	11KV Line snapped near Begampet Village	No
1	MDK	Patancheru Town	Town	11KV	Patancheru	01.15	03.55	02.40		Disc failed at Yard	No
2		Bollaram - I	Pavan	11KV	Patancheru	15.20	17.25	02.05		Conductor snapped	No
3		Bollaram - II	Rupa	11KV	Patancheru	11.30	12.22	00.52		Conductor snapped	No
1	SDPT	Guruvannapet	Tapaspally	11KV	Husnabad	01.20	07.00	05.40		Insulator failure	No
2		Komuravelly	Kistampet	11KV	Husnabad	08.00	10.00	02.00		Insulator failure	No
1	RR S	ESCI	Divya Sree	11KV	Gachibowli	11:50	15:00	3:10		Divya Sree company LBF's Short circuit at Orian Villah, Divyasree	No
1	RR N	Prashanth Hills	Brundhavan Hills	11KV	Kukatpally	13:35	14:35	1:00		Lizard Fallen on the 11kv line at Prashanthi Hills	No
2		Devarayamjal	Kottapet	11KV	Medchal	15.55	17.45	01.50		Tree fallen on the 11KV Line at DMC	No
1	RR E	Moula-Ali	Malkajiri	11KV	Sainikpuri	17:50	18:48	0:58		11KV Polimer Disc failed at RTC Colony	No
1	HYD N	Srinagar Colony	Kamalapuri Colony	11KV	X	02.01	03.54	01.53	EL,OL-Bph	Lizard fallen on lines at Indira Nagar Darga	No
2		Tirumalagiri	Mangapuram Colony	11KV	C-VI	13:48	15:30	1:42	EL,OL-Rph	Saree fallen on lines near SS	No