

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933	1		1		1				
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	6	1	6	1	6	0	0	
	Grand Total	1082	6468	1	9	1	9	1	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 18.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	R.C.Puram	NSL	33KV	Patancheru	01.13	02.03	00.50		BD Due lightning Arrester Blast	NSL	-

TSSPDCL - LMRC / Corporate office

Date: 18.07.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marriguda	Konduru	11KV	Devarakonda	14.15	14.50	00.35	E/L	11 KV Jumper Cut	-
2		Penpahad	Dubbathanda	11KV	Suryapet	10.30	13.20	02.50	E/L	11Kv Insulator failed	-
3		Amaravaram	Amaravaram	11KV	Huzurnagar	04.00	06.30	02.30	E/L	11Kv Line Snapped	-
4		Mukundapuram	Somaram	11KV	Huzurnagar	03.00	06.45	03.45	E/L	11 KV Jumper Cut	-
1	SDP	Nagapuri	Nagapuri	11KV	Husnabad	19.10	21.20	02.10		DTR Failure & conductor snapped	-
2		Potharam	Nagaram	11KV	Husnabad	17.15	18.35	01.20		Jumper cut	-
1	RR E	Uppal Kalas	Swaroop nagar	11KV	Habsiguda	00.25	01.23	00.58		11KV Cable damaged due to crane water pipes line work at swroop nagar & B/F from 11kv Vegetable market	-
1	HYD S	Khilwath	Charminar	11KV	III	01.18	02.33	01.15	EL,OL-Bph	Cable damaged & Conductor snapped at Macca Masjid	-
1	HYD C	Hussain Sagar	N.T.R Marg	11KV	I	02.45	04.15	01.30	EL,OL	No Visible Fault	Arranged B/F on 11KV Basheerbagh feeder