

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	1	2	1	2	1	2	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	2	1	2	1			
2	NLG	144	988	1	11	1	11	1	11			
3	MDK	107	933		1		1		1			
4	SDPT			2	3	2	3	2	3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	16	5	16	5	16	0	0	
	Grand Total	1082	6468	6	18	6	18	6	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.07.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Revally	33KV	Wanaparthy	12.44	13.30	00.46	E/L	Y Phase Jumper cut at 132KV SS	Revally	Allternate supply Arranged from 33KV Peddakothapally SS
2		Wanaparthy	Chinnamaroor	33KV	Wanaparthy	12.44	13.15	00.31	E/L	Y Phase CT blast at 132KV SS	Chinnamaroor	Allternate supply Arranged from 33KV Peddadagada SS
1	NLG	Madgulapally	Laxmidevigudem	33KV	Miryalaguda	16:00	19:10	3:10	E/L	Post type of Insulator failed	Laxmidevigudem	No
1	SDPT	Siddipet	Ponnal	33KV	Siddipet	12:20	0:00	11:40		Breakdown	Ponnal	No
2		Habshipur	Peddacheekode	33KV	Siddipet	03.45	05.10	01.25		Breakdown	Peddacheekode	No
1	HYD S	132KV M.D.Pally	Devi Bagh	33KV	Malakpet	15.56	16.15	00.19	EL,OL-Rph	Cable damaged by HDCL at Miralam Tank	Devi Bagh	Loads transferred onto 132KV Imlibun SS via 33KV Petlaburz fdr

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Malkapur	11KV	Jadcherla	00.15	05.30	05.15		11KV Insulator Failure Near Malkapur (V)	No
1	NLG	Velugupally	Velugupally	11KV	Suryapeta	11:50	13:05	1:15	E/L	Bird fallen on the line	No
2		Mattapally	Ramachandrapuram	11KV	Huzurnagar	11.30	14.00	02.30	EL	Due to 11Kv line snapped	No
3		Repala	Narsimhulagudem	11KV	Huzurnagar	06.50	09.30	02.40	EL	Due to bird fall on 11Kv line	No
4		Nadigudem	Ratnavaram	11KV	Huzurnagar	07.00	10.00	03.00	EL	Due to 11Kv Disk failure	No
5		Karivirala	Ramchandrapuram	11KV	Huzurnagar	06.07	09.15	03.08	EL	Due to 11Kv insulator failure	No
6		K.N.Konda	Balempally	11KV	Miryalaguda	11.02	13.20	02.18	EL	Tree branches fallen on the line near village	No
7		Chamapur	Chamapur	11KV	Bhongir	09.30	12.25	02.55	EL	11 kv Pin Insulator Failed & 11 KV Line Snapped Near Chamapur Village	No
8		S.Lingotam	Lingojigudem	11KV	Choutuppal	08.35	13.16	04.41	EL	11 kv Disc Failed Near Lingijigudem Village	No
9		Voligonda	Voligonda	11KV	Choutuppal	03.07	04.20	01.13	OL	Phase to Phase at SS- 8 Near Voligonda Town	No
10		Puligilla	Kanchanapally	11KV	Choutuppal	06.00	11.30	05.30	EL	100 kva DTR Failed at SS-1 Near Kanchanapally Village	No
11		Vemulakonda	Vemulakonda	11KV	Choutuppal	9:10	13:09	3:59	EL	100 kva DTR Failed Near Vemulakonda Village	No
1	MDK	Bollaram - II	Vipla	11KV	Patancheru	14:30	15:30	1:00		Due to AB Switch Spark	No
1	SDPT	Husnabad	Pandilla & Malapally	11KV	Husnabad	0:00	6:40	6:40		Tree fallen on the line	No
2		Akkannapet	Gollakunta	11KV	Husnabad	04.45	07.30	02.45		Tree fallen on the line	No
3		Akunoor	Rudrapally	11KV	Husnabad	13.05	17.15	04.10		Phase to phase	No
1	HYD S	Hyderguda	Jana Priya OH	11KV	III	03.20	05.32	02.12	EL	Cable fault	Arranged B/F on 11KV Attapur fdr
1	HYD C	Vittalwadi	Y.M.C.A	11KV	II	03.00	04.15	01.15	EL	Tree branches fallen on lines & Jumper cut at YMCA Chowrasta	No