

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		9		9		9			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	11	1	11	1	11	0	0	
	Grand Total	1082	6468	1	12	1	12	1	12	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
		All Circles			NIL					NIL		-

TSSPDCL - LMRC / Corporate office

Date: 24.07.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	CH.Mamidi	Kompally	11kv	Nalgonda	10.30	12.30	02.00	E/L	11KV Line Disc Failur	-
2		Aregudem	Chinnakaparthu	11kv	Nalgonda	13.10	15.20	02.10	E/L	11KV Line Cut	-
3		Kattangur	Munukintla	11kv	Nalgonda	07.00	09.00	02.00	E/L	11KV Line Jumper Cut	-
4		Penpahad	Potlapahd	11kv	Suryapet	10.20	12.20	02.00	E/L	Insulator failed	-
5		Amararam	Lingagiri	11kv	Huzurnagar	08.00	10.20	02.30	EL	11 KV LINE SNAPPED	
6		Ananthagiri	Kistapuram	11kv	Huzurnagar	12.30	15.00	02.30	EL	11 KV JUMPER CUT	-
7		Pedaveedu	Krishnathanda	11kv	Huzurnagar	12.00	15.00	03.00	EL	11 KV LINE SNAPPED	-
8		Gondiryala	Gonidiryala-1	11kv	Huzurnagar	13.00	14.15	01.15	EL	11 KV LINE SNAPPED	-
9		D.Nagaram	D.Nagaram Agl	11kv	Choutuppal	08.00	11.20	03.20	EL	11kv Line snapped	-
1	SDPT	Nagapuri	Pothireddypalli	11kv	Husnabad	21.05	00.00	02.55		11KV Line Cut	-
2		Chityal	Thadoor	11kv	Husnabad	15.45	18.46	03.01		11KV Line Cut	-
1	RR S	Rajendranagar	Sulemannagar	11kv	RJNR	06.40	08.50	02.10	B/D	11KV Insulator failed at Khaja hotel back side	-