

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		3		3		3			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	12	0	12	0	12	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988	1	17	1	17	1	17			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	20	3	20	3	20	0	0	
	Grand Total	1082	6468	3	32	3	32	3	32	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Nagarkurnool	33KV	Manthathi	09.27	12.30	03.03	E/L	Due to Phase to Phase & Jumper Cut Near 132KV SS Nagarkurnool	Nagarkurnool	-
2		Jadcherla	Polepally	33KV	Gangapur	14.05	16.56	02.51	E/L	AB Switch Opened Near Alwanpally SS Towards Midjil	Jadcherla	-
1	NLG	Zaheerabad	Chota Hyderabad	33KV	Zaheerabad	08.30	10.55	02.25		BD due to Underline cable cut	Zaheerabad	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Moosapet	11KV	Jadcherla	00.10	09.20	09.10		11KV Disk fail near Moosapet	-
2		Marrikal	Kanmankawla	11KV	Jadcherla	05.05	09.14	04.09		11KV Wire cut near Kothapally	-
1	NLG	B.Chandupatla	Bheemla thanda	11KV	Suryapeta	10.00	11.30	01.30	E/L	Tree branch fallen on the line	-
2		Mukundapuram	Dacharam	11KV	Huzurnagar	10.11	13.15	03.04	EL	Due to 11Kv insulator failure	-
3		Garidepally	Appannapet	11KV	Huzurnagar	05.00	07.35	02.35	EL	Due to 11Kv line cutted	-
4		Ponugodu	Velidanda	11KV	Huzurnagar	06.40	07.50	01.10	EL	Due to bird fall on 11kv line	-
5		Mattampally	Erajeelu agl	11KV	Huzurnagar	08.45	11.45	03.00	EL	Due to 11Kv line cutted	-
6		Raghunadapalem	Nakkalagudem	11KV	Huzurnagar	06.35	09.30	02.55	OL	Due to 11Kv jumper cutted	-
7		Nadigudem	Nadigudem	11KV	Huzurnagar	07.40	11.00	03.20	EL	Due to 11Kv line snapped	-
8		Pullemula	Bodangiparthy	11KV	Nalgonda	05.05	09.50	04.45	EL	11 KV Line Jumper Cut	-
9		Indugula	Malaparajugudem	11KV	Nalgonda	09.30	11.25	01.55	EL	11 KV Line Jumper Cut	-
10		Palivela	Palivela Agl	11KV	Nalgonda	05.00	05.55	00.55	EL	11 KV Line Jumper Cut	-
11		Nakkalapally	Shapally	11KV	Nalgonda	16.30	14.40	01.50	EL	11KV Insulator Fialure	-
12		Cherukupally	Bolanpally	11KV	Devarakonda	09.00	12.00	03.00	EL	11 KV 1 No Insulator Fail	-
13		Shivannaguam	R.R.Pally	11KV	Devarakonda	05.00	09.00	04.00	EL	11 KV 1 No Insulator Fail	-
14		Pamukunta	Singaram	11KV	Bhongir	06.15	09.00	02.45	EL	11 kv Disc Failed Near Singaram Village	-
15		Pamukunta	Pamukunta	11KV	Bhongir	07.30	11.50	04.20	EL	11 KV Insulator Failed Near Pamukunta Village	-
16		Ishkilla	Munipampula	11KV	Choputuppall	06.00	08.30	02.30	EL	11 kv Disc Failed In Ishkilla Sub-station Yard	-
17		Sangem	Sangem	11KV	Choputuppall	07.40	09.14	01.34	EL	11 kv Insulator Failed Near Sangem Village	-
1	MDK	Bollaram - I	Arobindo	11KV	Patancheru	09.40	11.00	01.20		BD due to Jumper cut	-
1	RR S	Shamshabad	Dharmasai	11KV	RJNR	15.50	17.05	01.15	B/D	11kv Jumper Touching To Channel at Prakash nagar	-
2		Rajendranagar	Pahadi	11KV	RJNR	05.30	06.30	01.00	B/D	Tree Branches Fallen on 11kv Line at kishori masjid Jumper Opened	-
3		ESCI	Lumbini Park	11KV	Kondapur	01.48	02.58	01.10	B/D	11KV line patrolling, no fault, (11kv Line AB switch opened at My Home)	-
1	RR N	Bommarajpet	Ponnal	11KV	Medchal	04.50	07.10	02.20	BD	11KV Pin Insulator Failed near Ponnal Village	-
2		Shameerpet	Devarayamjal	11KV	Medchal	10.50	12.30	01.40	BD	11KV Brass Patti cut and replaced at Lingala Bhavi	-
3		Shameerpet	Shameerpet	11KV	Medchal	17.40	19.00	01.20	BD	63KVA DTR Brass patti cut & replacement at Babaguda	-
4		Kistapur	IDA Hanuman	11KV	Medchal	23.30	02.05	02.35	BD	Tree fallen on the 11KV Line at Ravalkole Comman	-
1	RR E	Mallapur	Joflo	11KV	Habsiguda	22.50	00.30	01.40		11KV Insulator failed near Bread Company	-
2		Yapral	Tulasi Garden	11KV	Sainikpuri	00.50	01.15	00.25		Tree branches fallen on 11Kv line at Maru Enclave (Ae/Yapral) due to AB Switch Open 70% charged ok	-
3		Keesara	Anki Reddy Pally	11KV	Keesara	15.36	19.25	03.49		11KV line twisted & Monkey fallen on DTR near Peddamma Cheruvu	-
1	HYD S	Ch' Baradari	Ch' Baradari	11KV	Charminar	01.00	02.35	01.35	EL,OL	HT Jumper cut at Badi Masjid	-
2		Khilwath	Charminar	11KV	Charminar	01.02	02.32	01.30	EL,OL	3Way R.M.U Insulator flash over	4No. DTR's loads added on 11KV Pancha Mohalla feeder