

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550	1	8	1	8	1	8			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	12	1	12	1	12	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		17		17		17			
3	MDK	107	933									
4	SDPT				10		10		10			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	28	0	28	0	28	0	0	
	Grand Total	1082	6468	1	40	1	40	1	40	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.07.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	BE Vaccine	33KV	Medchal	1:40	8:55	7:15		2 Nos 33KV Pin Insulators failed at Tower No 12	BE Vaccine	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Kodgal	Kodgal	11KV	Jadcherla	08.02	09.15	01.13		Tree fallen on The 11KV line near Morambavi Tanda Side.	No
1	NLG	Palem	Palem	11KV	Nalgonda	22:00	07.00	09.00	E/L	11KV insulators failed	No
2		Koppole(K)	Koppole	11KV	Nalgonda	05.15	17.15	12.00	E/L	Tree fallen on line at Bhagyanagar thanda	No
3		CH.Annaram	Vallala	11KV	Nalgonda	07.10	13.50	06.40	E/L	11 KV Line Jumper Cut	No
4		Nemmani	Merlakunta	11KV	Nalgonda	06.18	11.30	05.12	O/L	11KV insulators failed	No
5		Teldevarapally	Ghanapur	11KV	Devarakonda	09.30	11.30	02.00	E/L	Jumper Cut	No
6		Thatipamula	Nandapuram	11KV	Suryapet	04.30	07.00	02.30	E/L	Conductor snapped	No
7		Velugupally	Velugupally	11KV	Suryapet	08.10	10.50	02.40	E/L	Insulator flashover	No
8		Munagala	Bharakath Gudem	11KV	Huzurnagar	12.35	13.45	01.10	EL	Due to 11Kv line snapped	No
9		Siripuram	Siripuram	11KV	Huzurnagar	08.30	11.20	02.50	EL	Due to 11kv Insultor failure	No
10		Mattapally	Sulthanpuram	11KV	Huzurnagar	09.37	12.57	03.20	EL	Due to 11kv Insultor failure	No
11		Y.Singaram	Y.Singaram	11KV	Huzurnagar	12.00	15.00	03.00	EL	Due to 11Kv line cutted	No
12		Chandupatla	Chandupatla	11KV	Bhongir	08.40	11.00	02.20	EL	11KV Disc failed near Ramachandrapuram Village	No
13		NG.Bandal	Veerareddypally	11KV	Bhongir	06.30	09.00	02.30	EL	100 kva DTR failed near Veerareddypally Village	No
14		Nemaragommula	Nemaragommula	11KV	Bhongir	11.30	15.40	04.10	EL	3 no's 11 kv Insulators failed near Nemaragommulathanda	No
15		Bondugula	Godumakunta	11KV	Bhongir	03.35	06.30	02.55	EL	11KV Insulator failed near Pittalagudem Village	No
16		Thummalagudem	Thummalagudem	11KV	Choutuppal	03.10	06.25	03.15	EL	11KV Insulator failed at Thummala Lachaiiah Well Near Thummalagudem Village	No
17		Laxmapuram	Laxmapuram	11KV	Choutuppal	11:05	14:50	3:45	EL	11KV Insulator failed near Laxmapuram Village	No
1	SDPT	Bejjanki	Kallepally	11KV	Husnabad	20:00	6:00	10:00		Due to Rain	No
2		Guggilla	Guggilla	11KV	Husnabad	12:30	14:05	1:35		Insulator failure	No
3		Komuravelly	Kistampet	11KV	Husnabad	3:35	5:30	1:55		Disc failure	No
4		Katkur	Katkur Rural	11KV	Husnabad	10:43	12:07	1:24		Insulator failure	No
5		Koheda	Cannal	11KV	Husnabad	19:30	23:30	4:00		Disc failure	No
6		Koheda	Kurella	11KV	Husnabad	19:30	23:30	4:00		Disc failure	No
7		Rayapole	Thimmakkapally	11KV	Gajwel	3:15	7:55	4:40		Disc failed at Thimmakkapally peddamma gudi	No
8		Rayapole	Thimmakkapally	11KV	Gajwel	11:15	14:10	2:55		Insulator failed	No
9		Rayapole	Thimmakkapally	11KV	Gajwel	19:30	20:45	1:15		Disc failed at Thimmakkapally main road	No
10		mandapur	godugupally	11KV	Gajwel	9:02	9:50	0:48		Pin binding lost	No
1	RR S	Rajendranagar	Pahadi	11KV	Rajendranagar	8:15	9:44	1:29		Bird fallen on the 11KV line at Bondalagadda Pahadi	No
1	RR N	Madinaguda	Bk Enclave	11KV	Kukatpally	13:04	14:04	1:00		11KV Pin insultor failed at Jana priya West City	No
2		Jeedimetla-I	Raghava	11KV	Jeedimetla	18.05	20.05	02.00		11KV AB Cable Failure at Vidayuth Company	No
3		Jeedimetla-I	Subashanagar	11KV	Jeedimetla	15.00	16.00	01.00		Due to Rain	No
4		HMT	Ganesh Nagar	11KV	Medchal	05.35	08.45	03.10		11KV Cable failed Qutubullapur Section Office	B/F arranged from 11KV Ganesh Nagar feeder from 132/33KV Chintal SS
5		GP Pally	GP Pally	11KV	Medchal	04.40	06.40	02.00		11KV Pin Insulator failed at Ramreddy Godown	No
6		Athiwelly	Somaram	11KV	Medchal	04.45	07.20	02.35		11KV Pin Insulator failed at Yellampet Chowrasta	No
7		Devarayamjal	DMC	11KV	Medchal	03.20	06.20	03.00		11KV Disc failed at Devarayamjal Village	No
8		Devarayamjal	Kottapet	11KV	Medchal	06.00	09.25	03.25		11KV Disc failed at Cheruvukatta	No
1	RR E	NGRI	Scientist Colony	11KV	Habsiguda	5:57	7:08	1:11		11KV Insulaotor failed at IDBL Bank Nagender Nagar	No
2		Chakripuram	Simhapuri Colony	11KV	Keesara	01.40	06.20	04.40		11KV Insulator failed at Venkateswara Colony	No
1	HYD S	Panjasha	Pancha Mohalla	11KV	III	22.15	23.52	01.37	EL,OL-Bph	I/C Cable fault at Water Works	Arranged B/F on 11KV Bibi Bazar & 11KV Asra Hospital feeders