

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044	1	4	1	4	1	4			
	Total	606	3055	1	13	1	13	1	13	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	3	5	3	5	3			
2	NLG	144	988		15		15		15			
3	MDK	107	933		6		6		6			
4	SDPT			1	5	1	5	1	5			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	29	6	29	6	29	0	0	
	Grand Total	1082	6468	7	42	7	42	7	42	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.07.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kalwakurthy	Rachoor	33KV	Nagarkurnool	17.46	19.40	01.54	OL	R Phase Line isolator jumper cut towards line side	Rachoor	-
2		Balanagar	Kollur	33KV	Jadcherla	05.05	08.30	03.25	EL	Failed LA Replaced at 132KV SS	Kollur	-
3		Thirumalaipally	Kothakota	33KV	Wanaparthy	02.20	05.28	03.08	EL	Pin Insulator Replaced Near Palem (V)	Kothakota	-
4		leeza	Gattu	33KV	Gadwal	19.35	20.25	00.50	EL	Back Feeding Supply Taken to 33KV Mitta Doddy Feeder at 20:25Hrs	Gattu	-
5		Shadnagar	Vijayanand	33KV	Shadnagar	09.30	11.35	02.05	EL	R Phase Pin Insulator Failed Near company	Vijayanand	-
1	SDPT	Angadikistapur	Yerravalli	33KV	Gajwel	11.26	12.18	00.52		Disk Fail	Yerravalli	-
1	HYD N	132KV Patigadda	Sanjeevaiah Park	33KV	Bowenpally	03.33	03.38	00.05	W/O Indication	Cable fault at Solar Shade shop, Minister Road	Sanjeevaiah Park	Loads transferred onto 132KV Gunrock SS via 33KV Airport SS

TSSPDCL - LMRC / Corporate office

Date: 30.07.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Janampet	Polkampally	11kv	Jadcherla	06.15	10.05	03.50		11 KV phase to phase near polkampally.	-
2		Kothamolgara	Madigatla	11kv	Jadcherla	07.00	10.40	03.40		11 KV Disc Fail Near Ram reddy bai.	-
3		Kodgal	Kodgal	11kv	Jadcherla	02.00	10.10	08.10		11 KV insulater fail near kodgal (v).	-
1	NLG	Pamanagundla	Pittampally	11kv	Nalgonda	04.00	09.40	05.40	E/L	11KV Line Jumper Cut	-
2		Arlagaddagudem	Mangalapally	11kv	Nalgonda	14.35	15.20	00.45	O/L	11KV Line Jumper Cut	
3		Arlagaddagudem	N.R.Gudem	11kv	Nalgonda	10.30	13.20	02.50	O/L	11KV Line Jumper Cut	
4		P.D.Pally	P.D.Pally	11kv	Nalgonda	12.40	14.20	01.40	E/L	11 KV Insulator Fialure	
5		Thungathurthy	Vempaty	11kv	Suryapet	12.00	14.15	02.15	E/L	11Kv Insulator failed	
6		Alingapuram	Gundlapahad	11kv	Huzurnagar	05.00	07.30	02.30	E/L	11Kv Insulator failed	
7		Dirincherla	Town-2	11kv	Huzurnagar	14.10	16.00	02.10	E/L	11Kv Line Snapped	
8		Dirincherla	Dirincherla	11kv	Huzurnagar	14.30	16.10	01.40	E/L	11KV Line Jumper Cut	
9		BNL Thanda	Pathanda	11kv	Huzurnagar	11.25	14.25	03.00	E/L	11KV Line Jumper Cut	
10		Akupamula	Akupamula	11kv	Huzurnagar	10.40	12.50	02.10	E/L	11Kv Insulator failed	
11		MT.Pally	Dharmaram	11kv	Bhongir	04.00	07.00	03.00	E/L	11kv Insulator Failed Near Malkapur (V)	-
12		CH.Laxmapuram	Mission Bhageeratha	11kv	Bhongir	03.30	07.30	04.00	E/L	11kv Post-off Insulator Failed Near Thurkapally (v)	-
13		Peddathanda	Peddathanda	11kv	Bhongir	11.10	13.20	02.10	E/L	11kv Insulator Failed near Piligunthanda (V)	-
14		Rajapeta	Renikunta Agl	11kv	Bhongir	03.00	08.00	05.00	EL/OL	11kv Line snapped near Bagampet (V)3Phase B/d Single Phase OK	-
15		Bondugula	Bondugula Agl	11kv	Bhongir	08.45	09.45	01.00	EL/OL	11Kv Line Snapped Kurraram Road Near Bondugula (V)	-
1	MDK	EPIP II	Export	11kv	Sangareddy	09.40	11.45	02.05		B/D Due to pole damage near Indrakaran Vg	-
2		SOL	Markwell	11kv	Patancheru	02.00	07.55	05.55		BD due to Tree fallen on line	-
3		Patancheru Town	MIA-I	11kv	Patancheru	01.05	04.50	03.45		BD due to Insulator failed	-
4		Bollaram - II	Vasavidatta	11kv	Patancheru	01.26	07.16	05.50		BD due to Conductor snapped at SOL	-
5		Gummadidala	Agrobell	11kv	Patancheru	11.55	13.40	01.45		BD due to Conductor snapped near SS	-
6		Bonthapally	Veerabadra	11kv	Patancheru	05.20	07.00	01.40		BD due to Jumper cut	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Gandipally	Nandaram	11kv	Husnabad	00.00	11.05	11.05		3 Ph BD,1 Ph ok	-
2		Potharam	Potharam Rural	11kv	Husnabad	17.20	18.30	01.10		Bush failure	
3		Gagillapur	Narsaipally	11kv	Husnabad	01.00	07.00	06.00		DTR Failure&Tree fallen	
4		Dharmaram	Potharam(J)	11kv	Husnabad	08.05	11.15	03.10		HT/LT	
5		Koheda	Sriramulapally	11kv	Husnabad	09.10	09.45	00.35		Insulator failure	-
1	RR S	NPA	Shastripuram	11kv	RJNR	04.16	07.15	02.59	B/D	Tree Branches Fallen on 11kv Line at Canara bank and Kite Stick Fallen on 11kv Line at Sattar Masjid	-
2		Balaji Nagar	KPHB Road NO.1	11kv	Kondapur	03.46	05.30	01.44	B/D	Stick fallen on the 11kv line and touched to conductor&& Channel at Prime Hospital	-
1	RR N	Subhash Nagar	Padma Nagar	11kv	Medchal	01.35	02.30	00.55	BD	100KVA DTR HG Fuse Insulator Failed at Durga Estate	-
2		UMCC	Mahadevpuram	11kv	Medchal	15.55	16.45	00.50	BD	11KV Pin Insulator failed at Mahadevpuram	-
3		Jeedimetla-III	Fox Sagar	11kv	Jeedimetla	15.53	17.33	01.40	BD	R & B Cable Jumper Cut at Fox Sagar at Phase-IV	-
4		Devarayamjal	Kottapet	11kv	Medchal	06.30	08.15	01.45	BD	No visible Fault	-
1	RR E	Kushaiguda	NN Colony	11kv	Sainikpuri	07.25	08.45	01.20		11Kv Pin Insulator fail at Jaya Krishna Apt North Kamala Nagar (LM Srinivas)	-
2		AS Rao Nagar	BSNL	11kv	Sainikpuri	04.04	04.34	00.30		AB Switch Open at MoreSuper Market 50 off bit charged OK due to 11Kv Insulator failed (Artisan/Ramesh)	-
3		Janapriya	Shalivahana	11kv	Sainikpuri	16.16	17.21	01.05		11Kv Pin Insulator fail at Yellareddyguda due to Rain (LM Venkatesh)	-
1	HYD C	Fever Hospital	C.C.S.Hospital	11kv	II	00.20	06.50	06.30	EL,OL-Bph	Cable fault (3No. DTR's Kept off)	Partial bit added on 11KV YMCA fdr at 01:39Hrs & partial bit added on 11KV Nehru Nagar fdr at 02:30Hrs & remaining loads charged
2		Narayanguda	Chikkadpally	11kv	II	02.55	04.35	01.40	EL,OL-Rph	Faulty Loads of 11KV RTC X Road feeder	-----
3		Golnaka	Nehru Nagar	11kv	II	03.01	04.29	01.28	EL	Faulty partial loads of 11KV C.C.S.Hospital feeder	Arranged B/F on 11KV Tulasi Nagar feeder
4	Hyd N	Clock Tower	Station Road	11kv	V	04.20	05.30	01.10	All Indication	O/G Jumper cut at SS	-----