

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>1</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		8		8		8			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>2</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 01.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Palkonda	Janampet	33KV	Mahabubnagar	13.02	17.19	04.17	EL	Jumper cut at Annasagar SS	Janampet	-
1	MDK	Kandi	ITW Signode	33KV	Sangareddy	07.40	10.30	02.50		BD Due to Y PHASE JUMPER CUT at Kandi SS	ITW Signode	-

## TSSPDCL - LMRC / Corporate office

Date: 01.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Annaram	11KV	Suryapeta	09.50	12.10	02.20	E/L	Conductor snapped	-
2		Kethepally	Chikatigudem	11KV	Nalgonda	06.50	08.30	01.40	E/L	11KV line Jumper Cut SS-9	-
3		Akaram	Vathipamula	11KV	Nalgonda	06.30	10.30	04.00	E/L	11KV line Insulator Failure	-
4		Arlagaddagudem	Suraram	11KV	Nalgonda	08.30	12.30	04.00	E/L	11KV line Jumper	-
5		Baironibanda	Baironibadda	11KV	Nalgonda	08.35	12.05	03.30	E/L	11KV line Jumper	-
6		Keethavarigudem	Velidanda	11KV	Huzurnagar	03.00	05.30	02.30	EL	Due to 11Kv line snapped	-
7		Pamukunta	Jala	11KV	Bhongiri	07.15	09.20	02.05	OL	Phase to Phase Near Jala Village	-
8		Raghunathpur	Challuru Indl	11KV	Bhongiri	08.15	10.20	02.05	EL	11 Jumper Cut Near Basanthapur Village	-
1	MDK	Sadasivpet	TSM	11KV	Sangareddy	01.00	02.00	01.00		B/D for Pole damage & 11kv line cut at Chitta Company	-
1	RR N	Medchal	IDA Kandlakoya	11KV	Medchal	00.26	02.30	02.04		11KV Pole damaged by Lorry at IDA Bus Stop	-