

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044	1	4	1	4	1	4			
	Total	606	3055	1	13	1	13	1	13	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5		4		4		1		1 No. 33KV Still Pending
2	NLG	144	988		10		10		10			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	14	4	14	4	14	1	0	
	Grand Total	1082	6468	6	27	5	27	5	27	1	0	

TSSPDCL - LMRC / Corporate office

Date: 02.06.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	SLC Mills	33KV	Mahabubnagar	21.45	00.00	02.15	E/L & O/L	Not Rectified (33 KV Conductor snapped at Picnic hotel)	SLC Mills	No
2		Makthal	Gudeballore	33KV	Narayanapet	18.20	19.20	01.00	EL	AB Switch open at Thangidi line OK (Tangidi & Saropawer is Dark)	Gudeballore	No
3		Ghanapur	Solipur	33KV	Wanaparthy	18.20	21.15	02.55	EL	For replacement of 33KV insulator at Shapur Stage ,Tree fallen on Line at Kothapally	Solipur	No
4		Wanaparthy	Revally	33KV	Wanaparthy	18:47	19:48	01.01	OL	AB Switch open near Chennaram	Revally	No
5		Thirumalaipally	Veltoor	33KV	Wanaparthy	17.54	18.17	00.23	EL	33KV Insulators damaged	Veltoor	Alternate supply arranged from 33KV Peddamandadi feeder
1	HYD C	132KV Asif Nagar	I.T.I. Mallepally	33KV	Asif Nagar	12.28	12.36	00.08	EL,OL-Bph	Cable damaged while attending 33KV Asif Nagar - Seetharambagh fdr B/D at Sultan Darbar Hotel	I.T.I. Mallepally	Loads transferred onto 132KV NIMS SS via 33KV Nampally fdr

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamanagundla	Ismailpally	11KV	Nalgonda	13:00	17:00	04.00	E/L	Tree fallen on the 11KV line	No
2		Arlagaddagudem	N.R.Gudem	11KV	Nalgonda	08.00	11.10	03.10	E/L	11KV Insulator failed	No
3		Penpahad	Macharam	11KV	Suryapet	05.00	07.50	02.50	E/L	11KV Insulator failed	No
4		Dirincherla	Narsaigudem	11KV	Huzurnagar	07.15	10.00	02.45	E/L	11KV Line snapped	No
5		Bethavolu	Bethavolu	11KV	Huzurnagar	06.30	09.00	02.30	E/L	11KV Jumper cut	No
6		Kodad Town	Komarabanda	11KV	Huzurnagar	05.00	08.00	03.00	E/L	11KV Line snapped	No
7		Peddathanda	Pallepahad	11KV	Bhongir	16.30	18.20	01.50	E/L	11KV Line snapped	No
8		Ramannapet	Ramannapet	11KV	Choutuppal	07.00	08.30	01.30	E/L	11KV Pin insulator failed	No
9		Choutuppal	Thangedipally	11KV	Choutuppal	14.40	16.30	01.50	E/L	11KV Line Melted	No
10		Veluvorthy	Sunkishala	11KV	Choutuppal	8:00	11:10	03.10	E/L	Bird fallen on the line & 11KV Jumper cut	No
1	SDPT	Bejjanki	Kallepally	11KV	Husnabad	11:20	15:00	03.40		Line fault	No
2		Ramchandrapur	Vinjapally	11KV	Husnabad	09.05	13.30	04.25		Conductor snapped	No
3		Mustyal	Veerannapet	11KV	Husnabad	17.30	19.30	02.00		Due to gale and wind	No
4		Guruvannapet	Tapaspally	11KV	Husnabad	16.35	17.40	01.05		Due to gale and wind	No
1	RR N	Chintal	Surya nagar	11KV	Medchal	15:20	16:20	01.00		11KV AB Cable failed at Ganesh temple Surya Nagar	Backfeed arranged from 11KV Saibaba Nagar feeder
2		Dpally	Gagilapur AGL	11KV	JDM	05.30	11.06	05.36		11KV Line cut at Gagilapur	No
3		Nuthankal	Grip	11KV	Medchal	14.45	15.50	01.05		11KV Pin insulator failed at Pochamma Temple Nuthankal	No
1	RR E	Sainikpuri	Sainikpuri	11KV	Sainikpuri	14:56	16:11	01.15		Tree branches fallen on 11Kv line at Sainikpuri	No
2		Sainikpuri	Ramalayam	11KV	Sainikpuri	14.59	15.40	00.41		Tree branches fallen on 11Kv line at Defence Colony	No
3		Anand Bagh	Vinayak Nagar	11KV	Sainikpuri	18.21	18.56	00.35		11Kv Disk failed & jumper cut at MBH Colony	No
4		Vinayak Nagar	RK Nagar	11KV	Sainikpuri	15.00	15.35	00.35		100Kva DTR LT line cut at RK Nagar Street No.3	No
5		Nagaram	PS Rao Nagar	11KV	Keesara	14.44	16.20	01.36		11KV Jumper cut at Govt School	No
6		Nagaram	S.N Colony	11KV	Keesara	14:50	16:50	02.00		11KV End Kit Cable failed at East Gandhi Nagar	No
1	HYD N	Addagutta	Addagutta	11KV	C-VI	04.25	05.48	01.23	OL-Yph	Cable fault	Arranged B/F on 11KV Tagore Home feeder
2		Chinna Thokatta	Parkview Enclave	11KV	C-VI	15:25	16:40	01.15	EL,OL	Tree branches fallen on lines at Parkview Enclave	No
3		H.A.L.	Sri Rama	11KV	VI	15:45	18:25	02.40	All Indication	Tree branches fallen on lines at ICI Paints	No
1	HYD S	Panjasha	Gowlipura	11KV	III	15.25	17.25	02.00	EL,OL	Tree branches fallen on HT lines & HT Line snapped at Gowlipura Julla	No