

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	5		5		5			1 No. 33KV Still
	Total	606	3055	1	8	0	8	0	8	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	7	1	7	1	7			
2	NLG	144	988	7	26	7	26	7	26			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	8	33	8	33	8	33	0	0	
	Grand Total	1082	6468	9	41	8	41	8	41	0	0	

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Amangal	SLC Mills	33KV	Shadnagar	06.45	11.55	05.10	E/L	Due to 33KV Pole Damaged	SLC Mills	-
1	NLG	Shaligouraram	Nakrekal	33KV	Nalgonda	08.40	13.15	04.35	E/L	33KV Line problem	Ch.Annaram, Kadaparthi	-
2		Shaligouraram	Akaram	33KV	Nalgonda	08.40	13.15	04.35	E/L	33KV Disc failure	Akaram, Wangamarthy	-
3		Shaligouraram	Akkenapally	33KV	Nalgonda	08.40	13.15	04.35	E/L	33KV Line cut	Akkenapally, B.Banda	-
4		Thungathurthy	Phanigiri	33KV	Suryapet	00.00	11.25	11.25	EL	33Kv Insulators failed	Phanigiri	-
5		Thungathurthy	Ravulapally	33KV	Suryapet	00.00	09.35	09.35	EL	4 Nos 33Kv Insulators failed	Ravulapally	-
6		Suryapet	S V College	33KV	Suryapet	00.00	10.30	10.30	EL	33Kv Disk failed	S V College	-
7		Suryapet	Nemmkal	33KV	Suryapet	00.00	07.05	07.05	EL	33Kv Insulators failed	Nemmkal	-
1	HYD N	132KV I.D.P.L	Pragatools OH (Idle)	33KV	Allwyn	11.43		00.00	EL,OL-Rph	Cable damaged by Unknown person near Narsapur X-Roads	Pragatools OH (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 07.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mothiganapur	Medigaddatanda	11KV	Jadcherla	17.50	14.00	19.10		11KV Disc Failure And Poles Damaged At Kurvagadda Tanda Side.	-
2		Mothiganapur	Mothiganapur	11KV	Jadcherla	17.50	11.30	16.40		11Kc Disc Failure Near Mothiganapur(V)	-
3		Mothiganapur	Gangadharpally	11KV	Jadcherla	17.50	14.00	19.10		Tree Follen On The 11kv Line Near Gangadharpally Vi)Side	-
4		Karkonda	khanapur	11KV	Jadcherla	07.14	10.15	03.01		2No's Poles Broken At sanglagadda Side.	-
5		Badepally	Burgupally	11KV	Jadcherla	01.10	06.50	05.40		AB Switch Problem At Burgupally(V)	-
6		janampet	polkampally	11KV	Jadcherla	11.10	13.40	02.30		11 Wire Cut Near polkampally (V)	-
7		Edgaanpally	Nandigama	11KV	Jadcherla	23.40	09.43	10.03		11Kv Disc Fail Near Nandigama(V)	-
1	NLG	Kethapally	Korlapahad	11KV	Nalgonda	09.00	16.40	07.40	E/L	11KV jumper cut	-
2		Madgulapally	Kukkadam	11KV	Nalgonda	09.00	11.00	02.00	E/L	11KV jumper cut	-
3		Arlagaddagudem	Suraram	11KV	Nalgonda	06.00	12.50	06.50	E/L	11KV insulator failed	-
4		Pamanagundla	Yerasanigudem	11KV	Nalgonda	07.30	10.37	03.07	E/L	11KV jumper cut	-
5		Shaligouraram	Kondaram	11KV	Nalgonda	08.30	11.25	02.55	E/L & O/L	11KV disk failed	-
6		Akaram	Vallala	11KV	Nalgonda	06.10	14.54	08.44	E/L	11KV jumper cut	-
7		Akaram	Shanthinagar	11KV	Nalgonda	06.15	14.54	08.39	E/L	11KV insulator failed	-
8		Baironibanda	N.G.Kothapally	11KV	Nalgonda	14.10	16.45	02.35	E/L	11KV jumper cut	-
9		Chandampeta	Mudidandla	11KV	Devarakonda	04.00	06.00	02.00	E/L	11kv Disc Failed Failed	-
10		Chandampeta	Mudidandla	11KV	Devarakonda	14.00	17.00	03.00	E/L	DTR Failed	-
11		Kothapally	peddamunigal	11KV	Devarakonda	05.20	15.00	09.40	E/L	Pole damaged	-
12		Kothapally	peruvala	11KV	Devarakonda	05.30	10.00	04.30	O/L	Tree fllonen	-
13		Kothapally	Ksina Trhanda	11KV	Devarakonda	05.30	12.00	06.30	E/L	11 KV Insuloter Failed	-
14		Jalalpuram	Siddisamudram	11KV	Suryapet	09.40	13.40	04.00	E/L	Line cut near SRSV Canal	-
15		Kasarabada	Kesaram	11KV	Suryapet	12.00	18.00	06.00	E/L	Poles Damage	-
16		Annaram	Kothagudem	11KV	Suryapet	09.30	11.40	02.10	E/L	Insulator failed	-
17		Tekumatla	Yandlapally	11KV	Suryapet	07.30	10.15	02.45	E/L	Tree branch fallen	-
18		Mukundapuram	Mamillamadava	11KV	Suryapet	07.15	10.30	03.15	E/L	Insulator failed	-
19		Kodur	Loyapally	11KV	Suryapet	03.30	06.40	03.10	E/L	Jumper cut	-
20		Atmakur(S)	Naseempeta	11KV	Suryapet	09.00	13.30	04.30	E/L	line cut	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21		Penpahad	Anajipuram	11KV	Suryapet	07.30	09.30	02.00	E/L	HT/LT Line melt	-
22		Bopparam	Bopparam	11KV	Suryapet	06.00	08.35	02.35	E/L	Jumper cut & Insulator failed	-
23		Aipoor	Mukkuodevulapally	11KV	Suryapet	09.00	11.50	02.50	E/L	Insulator failed	-
24		B Chandupatla	Pachyathanda	11KV	Suryapet	07.10	10.00	02.50	E/L	Insulator failed	-
25		Velugupally	Keshavapuram	11KV	Suryapet	08.00	11.30	03.30	E/L	Insulator failed	-
26		Reddygudem	Kothagudem	11KV	Suryapet	12.30	15.30	03.00	E/L	Conductor Snapped	-
1	RR S	Gaganpahad	Gaganpahad	11KV	RJNR	12.36	15.34	02.58	B/D	11kv Cable Fault at Railway Track Gaganpahad	-
1	RR N	Petbasheerabad	Satyam Enclave	11KV	Medchal	01.30	02.10	00.40	BD	No Fault	-
1	RR E	Yapral	Yapral	11KV	Sainikpuri	02.50	04.50	02.00		Tree fallen and Iron Jali fallen on 11Kv line at Mani Enclave (AE/OP)	-
1	HYD N	Kalyan Nagar	Rahamath Nagar	11KV	X	08.29	11.10	02.41	EL	O/G Yph Jumper cut at SS & AB Switch Jumper cut at Nala	-
2		Monda Market	Monda Market	11KV	V	11.10	12.26	01.16	EL,OL-Bph	Pin Insulator flash over at Opp: Monda Market	-
3		R.P Nilayam	Saraswathi Nagar	11KV	C-VI	14.10	16.00	01.50	OL-R,Y&Bph	Tree fallen on lines near SS	Arranged B/F on 11KV Venkatapuram feeder
4		Bowenpally	Plassy Line	11KV	VI	14.11	15.44	01.33	EL,OL-Bph	Sparking AB Switch at HEL Bus Stop	80% fdr charged at 14:26Hrs after opened line AB Switch at Priyadarshini Hotel
1	HYD S	Arundathi Colony	Neelam Centre	11KV	III	06.20	08.20	02.00	EL,OL	Cable fault at Naseeb Nagar	-