

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	1	1	1	1	1	1		1 No. 33KV Pending
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	6	1	6	1	6	1	0	
	Grand Total	1082	6468	2	9	1	9	1	9	1	0	

TSSPDCL - LMRC / Corporate office

Date: 09.06.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Narayanpet	33KV	Narayanpet	05.55	09.10	03.15	E/L	Pin binding failed near Lingampally	Narayanpet	No
2		Gadwal	Nandinne	33KV	Gadwal	23.35	00.00	00.25	O/L	Due to Heavy Winds & Heavy Spark	Nandinne	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Nerallapally	11KV	Jadcherla	11.02	12.38	01.36		11KV Wire cut near Nerallapally	No
1	NLG	Yerkaram	Yerkaram	11KV	Suryapeta	13:45	16:20	2:35	E/L	HT/LT Line Melt	No
2		BNL Thanda	Vardapuram	11KV	Huzurnagar	08.30	09.30	01.00	EL	11KV Jumper cut	No
3		Kethepally	Kasanagodu	11KV	Nalgonda	12.00	13.00	01.00	EL	11KV Jumper cut	No
1	SDPT	Gandipally	Gandipally	11KV	Husnabad	7:16	8:10	0:54		Cable cut	No
2		Gurjakunta	Dommata	11KV	Husnabad	12.15	16.10	03.55		11KV Pin insulator failed	No
1	RR N	Kompally	Kompally	11KV	Medchal	20:33	21:09	0:36		Cable failed at Bhagireddy Function Hall	No
1	RR E	Chengicherla	RTC	11KV	Keesara	15:45	16:30	0:45		11KV Pin insulator failed at RTC Colony	No
1	HYD S	Petlaburz	Hussaini Alam	11KV	Charminar	10.45	11.55	01.10	EL,OL	Tree branches on lines & Jumper cut at Deccan Functional Hall	No