

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2							
7	RR(E)	168	403		2							
8	Hyd	194	1044	1	2	1	2	1	2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>2</b>	<b>1</b>	<b>2</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>6</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>12</b>	<b>2</b>	<b>8</b>	<b>2</b>	<b>8</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 10.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Narayankhed	Kalher	33kv	Jogipet	16.32	17.35	01.03		B/D Due to Jumper Cut	Kalher	-
1	HYD S	132KV Moosarambagh	Malakpet B-Block	33kv	Asmangadh	09.41	09.50	00.09	OL	O/G End Kit failed	Malakpet B-Block	Loads transferred onto 220KV Ch' Gutta SS via 33KV Laxmi Nagar fdr

## TSSPDCL - LMRC / Corporate office

Date: 10.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Annaram	Sangem	11kv	Suryapet	04.00	06.20	02.20	E/L	Insulator flashover	-
2		Nagaram	Indl. Feeder	11kv	Suryapet	14.30	15.30	01.00	E/L	Conductor snapped	-
3		Palakaaedu	Sajjapuram	11kv	Huzurnagar	06.00	08.40	02.40	EL	11 KV JUMPER CUT	-
4		Keethavarigudem	Laxmipuram	11kv	Huzurnagar	07.20	08.30	01.10	EL	11 KV LINE SNAPPED	-
5		Burugadda	K K Gudem	11kv	Huzurnagar	07.00	08.50	01.50	EL	11 KV LINE SNAPPED	-
6		Yellanki	Sarinenigudem	11kv	Choutuppal	13.15	14.35	01.20	EL	11 kv Line Snapped	-
1	RR N	Jeedimetla-II	Apuroopa Colony	11kv	Jeedimetla	10.37	12.15	01.38		11kv line AB Cable stret through joint failure at Phase-III	-
2		Dulapally	IDA-II	11kv	Medchal	18.12	19.08	00.56		11KV Jumper cut and replaced at Chowdary Company	-
1	RR E	Vasanthapuri	Ganesh Temple	11kv	Sainikpuri	16.15	17.16	01.01		Bird fallen and Jumper cut at Vasanthapuri Colony (L.Insp Narsing Rao)	-
2		Narapally	Narapally	11kv	Keesara	04.45	05.25	00.40		Copper patti cut at Vedeocone company	-
1	HYD N	Bowenpally	Pension Lane	11kv	Bowenpally	04.05	05.15	01.10	EL	Tree branches fallen on HT lines at Pension Line	-----
1	HYD S	Bathkammakunta	Saibaba Temple	11kv	Azamabad	01.00	02.34	01.34	EL	No Visible Fault	Arranged B/F on 11KV C.E Colony feeder