

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		5		5		5			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		8		8		8			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT			2	29		7		7			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>6</b>	<b>39</b>	<b>4</b>	<b>17</b>	<b>4</b>	<b>17</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>6</b>	<b>48</b>	<b>4</b>	<b>26</b>	<b>4</b>	<b>26</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 20.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kalwakurthy	SCL Mills	33KV	Nagarkurnool	22.15 (19.06.19)	08.15 (20.06.19)	10.00	E/L&O/L	New Cable Kit Provide at LIC Bilding	SCL Mills	-
2		Nagarkurnool	Rakonda	33KV	Nagarkurnool	10.02	15.04	05.02	E/L	Pin Binding Work & Removing tree on the Line	Rakonda	-
3		Narayanpet	Makthal	33KV	Gudeballore	17.45	22.15	04.30	E/L	2 Nos Pin Insulator Replacement Indupur Village	Makthal	-
1	MDK	Pashamailaram	SOL	33KV	Sangareddy	11.10	12.30	01.20		B/D due to Conductor Snapped at Sai nagar.	SOL	-
1	SDP	Palamakula	Gonepally	33KV	Siddipet	17.55	Still				Rampur	-
2		Mustyala	Tharigoppula	33KV	Husnabad	20.15	Still				Doolmitta	-

## TSSPDCL - LMRC / Corporate office

Date: 20.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Agamothkur	Bommakal	11KV	Miryalguda	07.15	12.10	04.55	E/L	11KV disc failed near village	-
2		Narsingbatla	Kuthurugudem	11KV	Nalgonda	05.30	10.40	05.10	E/L	Tree branches fallen on 11Kv line at Village end	-
3		Karivirala	Keshavapuram	11KV	Huzurnagar	05.30	08.10	02.40	E/L	11Kv Line Snapped	-
4		Gaddipally	Medaram	11KV	Huzurnagar	07.00	10.20	03.20	E/L	11Kv Line Snapped	-
5		Bhongir	Pahadinagar	11KV	Bhongir	02.30	04.45	02.15	EL/OL	11kv Line snapped near Pahadinagar SS-23 Bhongir(Town)	-
6		Motakondur	Vartoor	11KV	Bhongir	02.00	09.00	04.30	EL	11kv Insulator Failed near Vattor Village	-
7		Gundala	Ramaram	11KV	Bhongir	09.30	11.40	02.10	EL/OL	11kv Line snapped near Gundala Village	-
8		Juloor	Kapraipally	11KV	Choutuppal	05.00	09.00	04.00	EL/OL	11kv Insulator Failed & 11kv Line snapppe near Kapraipally Village	-
1	MDK	Bollaram - II	Vasavidatta	11KV	Patancheru	12.44	13.24	00.40		B/D due to Tree branches fallen on the line	-
2		Bollaram - II	Vipla	11KV	Patancheru	15.05	15.40	00.35		B/D due to Conductor snapped	-
1	SDP	Thotapally	Mallampally	11KV	Husnabad	19.34	20.25	00.51		Due to gale and wind	-
2		Thotapally	Thotapally Expres	11KV	Husnabad	17.22	18.00	00.38		Due to gale and wind lines touched same rectified	-
3		Ramchandrapur	Vinjapally	11KV	Husnabad	17.50	20.30	02.40		Insulator failed same rectified	-
4		Koheda	Koheda Town	11KV	Husnabad	18.00	19.00	01.00		Insulator failed same rectified	-
5		Shanigaram	Shanigaram Town	11KV	Husnabad	19.15	20.40	01.25		due to gale and wind	-
6		Baswapur	Baswapur (R)	11KV	Husnabad	14.20	16.58	02.38		Insulator failed same rectified	-
7		Gagillapur	Vallampatla	11KV	Husnabad	13.30	13.50	00.20		Lines touched same rectified	-
8		Potharam	Potharam Rural	11KV	Husnabad	19.00	Still			due to gale and wind, S-ph supply OK	-
9		Potharam	Mirzapoor	11KV	Husnabad	19.00	Still			due to gale and wind, S-ph supply OK	-
10		Potharam	Nagaram	11KV	Husnabad	19.00	Still			due to gale and wind, S-ph supply OK	-
11		Katkur	Ramavaram & Mallaram	11KV	Husnabad	21.35	Still			Due to gale and wind	-
12		Akkannapet	Pakilnayak Thanda	11KV	Husnabad	18.40	Still			Due to gale and wind	-
13		Gandipally	Ramavaram	11KV	Husnabad	18.45	Still			Due to gale and wind	-
14		Gandipally	Gandipally Express	11KV	Husnabad	18.45	Still			Due to gale and wind	-
15		Bejjanki	Kallepally	11KV	Husnabad	18.00	Still			due to gale and wind, S-ph supply OK	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
16	SDP	Bejjanki	Muthannapet	11KV	Husnabad	22.00	Still			due to gale and wind, S-ph supply OK	-
17		Thotapally	Thotapally Town	11KV	Husnabad	18.40	Still			due to gale and wind	-
18		Samudrala	Samudrala (R)	11KV	Husnabad	19.00	Still			due to gale and wind	-
19		Guruvannapet	Tapaspally	11KV	Husnabad	19.45	Still			due to gale and wind, S-ph supply OK	-
20		Komuravelly	Kadavergu	11KV	Husnabad	19.30	Still			due to gale and wind	-
21		Nagapuri	Nagapuri	11KV	Husnabad	20.10	Still			due to gale and wind, S-ph supply OK	-
22		Nagapuri	Gandikunta	11KV	Husnabad	20.10	Still			due to gale and wind, S-ph supply OK	-
23		Nagapuri	Pothireddypalli	11KV	Husnabad	20.10	Still			due to gale and wind, S-ph supply OK	-
24		Chityal	Chityal Agl	11KV	Husnabad	17.50	Still			due to gale and wind, S-ph supply OK	-
25		Chityal	Dommata	11KV	Husnabad	17.50	Still			due to gale and wind, S-ph supply OK	-
26		Chityal	Thadoor	11KV	Husnabad	17.50	Still			due to gale and wind, S-ph supply OK	-
27		Bekkal	Bairanpally	11KV	Husnabad	21.15	Still			due to gale and wind, S-ph supply OK	-
28		Bekkal	Thornala	11KV	Husnabad	17.25	Still			due to gale and wind, S-ph supply OK	-
29	Bekkal	Kondapur	11KV	Husnabad	17.25	Still			due to gale and wind, S-ph supply OK	-	
1	RR N	Medicity	Rajabollaram	11KV	Medchal	23.30	00.50	01.20		11KV Line cut and replaced at Gubadigutta Thanda, Crusher Company	-
2		Kolthur	Anantharam	11KV	Medchal	17.55	19.05	01.10		11KV Pin Insulator Failed at Shanker Reddy Thota, Anantharam	-
1	RR E	Sainikpuri	Ramalayam	11KV	Sainikpuri	20.44	22.06	01.22		11Kv Jumper touched to Cross aram at Vinyard Rainbow Apt (FOC Panthulu)	-
2		Narapally	P.Sinagaram	11KV	Keesara	15.03	15.43	00.40		Brash patti cut at Thenegudam	-
1	HYD N	Pragatools	Global Homes	11KV	VI	03.40	04.52	01.12	EL	I/C UG Cable failed at SS	-
2		Gunrock	Lal Bazar	11KV	C-VI	09.00	10.25	01.25	EL	Jumper touch to Channel at Hanuman Temple	-
3		Gunrock	Subhash Nagar	11KV	C-VI	23.15	00.50	01.35	EL,OL-Bph	Conductor snapped at Hussaini Apts X Road	-
1	HYD S	Falaknuma	Aliyabad	11KV	III	01.10	02.27	01.17	EL	I/C Cable fault	Arranged B/F on 11KV Rooplal Bazar feeder
2		Ch' Baradari	I.T.I Colony	11KV	III	06.38	08.15	01.37	OL	Conductor snapped, Jumper cut & Bird fault at Polytechnic	-