

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		6		6		6			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>18</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		21		21		21			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>3</b>	<b>22</b>	<b>3</b>	<b>22</b>	<b>3</b>	<b>22</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>3</b>	<b>40</b>	<b>3</b>	<b>40</b>	<b>3</b>	<b>40</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 23.06.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Buddaram	33KV	Wanaparthy	01.08	07.52	06.44	E/L&O/L	Due to Rain & 33KV Jumpers opened at Buddaram Gandhi	Buddaram	No
2		Wanaparthy	Gopalpet	33KV	Wanaparthy	01.08	07.10	06.02	E/L	Due to Rain & 33KV Jumpers opened at Gopalpet	Gopalpet	No
1	MDK	Bollaram	VIF	33KV	Patancheru	14:25	17:15	2:50		Jumper cut near VIF Company	VIF	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Rajupeta	Bandavarigudem	11KV	Nalgonda	04.00	08.05	04.05	O/L	11KV Line Jumper cut	No
2		B.Banda	T.K.PAHA	11KV	Nalgonda	04.50	07.20	02.30	E/L	11KV Line Jumper cut	No
3		Shaligouraram	Gurajala	11KV	Nalgonda	06.20	09.30	03.10	O/L	11KV Line Jumper cut	No
4		Rayanguda	J.R. guda	11KV	Nalgonda	04.30	07.50	03.20	E/L	11KV Line Jumper cut	No
5		Gundrampally	Apoor	11KV	Nalgonda	21.45	23.00	01.15	O/L	11KV Line Jumper cut	No
6		Thipparthi	Gangannapalem	11KV	Nalgonda	05.20	10.20	05.00	E/L	11KV Line Jumper cut	No
7		Veliminedu	Gundrampally	11KV	Nalgonda	01.30	06.00	04.30	E/L	11KV Line Jumper cut	No
8		Palem	Bopparam	11KV	Nalgonda	03.00	08.00	05.00	E/L	11KV Line Jumper cut	No
9		Chandur	Gundrapally	11KV	Nalgonda	03.05	07.50	04.45	O/L	11KV Line Jumper cut	No
10		Mushampally	Mushampallt	11KV	Nalgonda	06.00	10.00	04.00	O/L	11KV Line Jumper cut	No
11		Damarcherla	Watchya GP Agl	11KV	Miryalaguda	03.00	08.00	05.00	OL	Tree fallen on the 11KV line	No
12		Tripuraram	Industrial	11KV	Miryalaguda	05.40	11.30	05.50	OL	11KV Jumper cut	No
13		Haliya	Haliya T-II	11KV	Miryalaguda	04.15	05.15	01.00	OL	11KV Jumper cut	No
14		Laxmidevigudem	Ravulapenta	11KV	Miryalaguda	04.30	06.30	02.00	OL	11KV Jumper cut	No
15		Laxmidevigudem	Laxmidevigudem	11KV	Miryalaguda	04.00	07.00	03.00	OL	11KV Jumper cut	No
16		Settipalem	Industrial	11KV	Miryalaguda	03.20	05.20	02.00	OL	11KV Jumper cut	No
17		T Singaram	Mood thanda	11KV	Suryapet	06.00	09.30	03.30	EL	Insulator failed	No
18		Gondriyala	Gondriyala 01	11KV	Huzurnagar	05.00	06.00	01.00	EL	Due to 11KV Jumper cut	No
19		Kodad Town	Srirangapuram	11KV	Huzurnagar	04.30	06.30	02.00	EL	Due to 11KV Line Snapped	No
20		Mattapally	Sulthanpuram	11KV	Huzurnagar	03.00	05.00	02.00	EL	Due to 11KV Jumper cut	No
21		Marriguda	Konduru	11KV	Devarakonda	14:00	15:30	1:30	EL	Jumper Cut	No
1	MDK	Bollaram - II	Rupa	11KV	Patancheru	14:30	17:05	2:35		Conductor snapped	No
1	RR S	IJM	9th Phase	11KV	Kondpaur	14:16	15:21	1:05		11KV Disc failed near Plot no 60 at MIG - 2.	No
2		Nanakramguda	Gowlidoddi	11KV	Gachibowli	15.10	17.50	02.40		Keshav Nagar HT Service OH line Cable Jumper failure at Sbi Bank opposite.	No
1	RR N	HMT Hills	Police Station	11KV	Kukatpally	15:45	17:33	1:48		11kv line Jumper Cut at Jalavayuvihar gate	No
2		HMT Hills	Addagutta	11KV	Kukatpally	14.55	16.30	01.35		11KV line twist at subhodaya Colony	No
3		Nizampet	Srinivasa Colony	11KV	Kukatpally	14.30	16.10	01.40	EL	11KV line Pin Insulator failure at Nizampet	No
4		Mayurinagar	Cable	11KV	Kukatpally	14.38	15.40	01.02	EL/OL	11KV line Post of insulator failure at Hyderanagar Cheruvu Katta	No
5		JDMSS-II	Phase-V	11KV	Jeedimetla	07.55	09.10	01.15	EL/OL	11KV line AB Cable failure at Near Patel Timber Depo,at Phase-V	No
6		Rgk Suraram	Suraram Village	11KV	Jeedimetla	14.45	16.05	01.20	EL	Tree branches fallen on the 11KV line near Ambedkar statue at suraram village	No
7		Dulapally	Prashanth Nagar	11KV	Medchal	14.50	15.40	00.50	EL	No visible fault	No
8		Dulapally	KK Society	11KV	Medchal	15.27	16.07	00.40		11KV Pole damaged at Zindal Company	No
9		Gagillapur	Virchow	11KV	Jeedimetla	11:45	13:34	1:49	OL	Tree branches fallen on the 11kv line at Gagillapur Road	No
1	RR E	Nacharam	Muktha Metals	11KV	Habsiguda	21:40	22:45	1:05		HG fuse failed at St no 8 Nacaram SS Yard	No
1	HYD N	Prashanth Nagar	Time Tek	11KV	VI	14.20	15.29	01.09	EL,OL-R&Bph	Jumper cut in SS	No
2		Ravindra Society	Ginger Court	11KV	X	15:20	16:54	1:34	EL	Tree branches fallen on lines at Kakatiya Hills Kamman	No
3		Ravindra Society	Ayyanna Pride	11KV	X	15:25	17:09	1:44	EL	Pin Insulator flash over at Platinum Apts	No
1	HYD S	Panjasha	Darjling School	11KV	III	18.25	19.35	01.10	All Indication	I/C Cable fault at Darjling School	Arranged B/F on 11KV Shajahan Hotel fdr
2		Kandikalgate	G.M Chowni	11KV	III	10:40	11:57	1:17	EL	No Visible Fault	Arranged B/F on 11KV Ravindra Naik Nagar fdr
1	HYD C	Batkammakunta	C.E.Colony	11KV	II	20.12	21.26	01.14	EL	Tree branches fallen on lines at Nalanda Nagar, Road No.18	No