

Details of Power Transformers Failures

S.No.	Circle	No of PTRs Existing as on 30.06.2018	No of PTRs failed during the F/Y 2018-19	% Failures for the FY 2018-19	No of PTRs failed during the F/Y 2019-20	No of PTRs failed during the month June- 19	No.of PTRs failed during the day	PTRs failed under				Failed PTRs replaced during the month	Reasons for not replaced
								WGP	RGP	BGP	TOTAL		
1	MBN	529	1	0.19	0	0	0				0		
2	NLG	647	2	0.31	0	0	0				0		
3	MDK	711	3	0.42	0	0	0				0		
4	RR(S)	405	0	0.00	0	0	0				0		
5	RR(N)	119	0	0.00	0	0	0				0		
6	RR(E)	215	0	0.00	0	0	0				0		
7	Hyd	314	0	0.00	0	0	0				0		
	Company	2940	6	0.20	0	0	0	0	0	0	0		

Details of PTR failures during the current month :

PTRs replaced in place of failed PTRs .

Details of Accidents Reports

S.No.	Circle	Division	Section	Area	Name of the Person	Age	No of Accidents from FY 2019 - 2020 (April '19 to May'20)	No of Accidents during the June - 19 month till date	Department		Non-Department		Remarks
									Fatal	Non-Fatal	Fatal	Non-Fatal	
1	MBN						1						
2	NLG						2						
3	MDK & Siddipet						1						
4	RR(N)						0						
5	RR(S)						0						
6	RR(E)						0						
7	Hyd						0						
8	Company						4	0	0	0	0	0	

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		6		6		6			
6	RR(N)	54	550		5		5		5			
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044		28		28		28			
	Total	606	3055	0	44	0	44	0	44	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	2	3	2	3	2			
2	NLG	144	988	1	23	1	23	1	23			
3	MDK	107	933		3		3		3			
4	SDPT			1	8	1	8	1	8			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	36	5	36	5	36	0	0	
	Grand Total	1082	6468	5	80	5	80	5	80	0	0	

TSSPDCL - LMRC / Corporate office

Date: 25.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kalwakurthy	Macherla	33KV	Nagarkurnool	02.40	07.25	04.45	E/L&O/L	Due to Rain & HG Fuse Replaced work in SS	Kalwakurthy	No
2		Midjil	Vemula	33KV	Jadcherla	05.00	07.00	02.00	E/L	Isolator open at Chandradhana	Midjil	No
3		Amangal	Telkapally	33KV	Shadnagar	03.00	06.35	03.35	E/L	No Visible Fault Due to Rain	Amangal	No
1	NLG	Sh. Gowraram	Nakrekal	33KV	Nalgonda	10.05	17.18	07.13	E/L	Insulator Failure	Sh. Gowraram	132KV Aitipamula 33KV Nakrekal Kadaparthi, Annaram ss From 10:20
1	SDPT	Thukkapur	Mettu	33KV	Gajwel	16.00	17.00	01.00		Jumper cut	Thukkapur	-

TSSPDCL - LMRC / Corporate office

Date: 25.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nawabpet	Rudram	11KV	Jadcherla	04.00	10.00	06.00		11KV Wire Cut Near Seethamma Tanda.	-
2		Lokirev	Lingampally	11KV	Jadcherla	01.05	07.09	06.04		LT Line Cut Near Lingampally (Vi).	-
1	NLG	Nuthankal	Polumalla	11KV	Suryapeta	05.30	07.40	02.10	EL	Insulator flahover	-
2		Dirsincherla	Chillepally	11KV	Huzurnagar	11.40	14.20	02.40	EL	Due to 11Kv insulator failure	-
3		Mukundapuram	Somaram	11KV	Huzurnagar	11.34	14.28	02.54	EL/OL	Due to 11Kv jumper cutted	-
4		Gaddipaly	Gaddipally	11KV	Huzurnagar	10.15	13.50	03.35	EL	Due to 11Kv jumper cutted	-
5		Gaddipaly	Medaram	11KV	Huzurnagar	13.30	16.20	02.50	EL	Due to 11Kv line cutted	-
6		Shanthi Nagar	G.K.Annaram	11KV	Nalgonda	05.00	08.20	03.20	EL	LT Line /HT Melting	-
7		Kethepally	Kethepally	11KV	Nalgonda	14.45	16.10	01.25	EL	11 KV Line Jumper Cut	-
8		Wangamarthy	Madharam	11KV	Nalgonda	06.00	09.00	03.00	EL	11 KV Line Jumper Cut	-
9		Marrigudem	Konduru	11KV	Devarakonda	05.00	08.00	03.00	EL	Jumper Cutt	-
10		Agamothkur	Bommakal	11KV	Miryalaguda	05.30	07.20	01.50	EL	Tree Fallen on 11Kv line	-
11		Kothagudem	Kothagudem	11KV	Miryalaguda	02.00	04.30	02.30	EL	11KV Disc failed near village	-
12		V.K Palem	Thungapad	11KV	Miryalaguda	06.30	08.20	01.50	EL	11KV Insulator failed near village	-
13		Pulimamidi	Sreenadhapuram	11KV	Miryalaguda	05.30	07.20	01.50	EL	11KV Insulator failed near village	-
14		Matoor	Matoor	11KV	Miryalaguda	04.20	06.45	02.25	EL	Tree Fallen on 11Kv line	-
15		Damarcherla	T.V Gudem	11KV	Miryalaguda	16.50	18.10	01.20	EL	11KV Disc failed near village	-
16		Agamothkur	Bommakal	11KV	Miryalaguda	04.00	06.45	02.45	EL	Tree Fallen on 11Kv line	-
17		Kothagudem	Gudur	11KV	Miryalaguda	06.40	09.50	03.10	EL	DTR failed in village	-
18		NG.Bandal	Gandamalla	11KV	Bhongir	05.00	09.45	04.45	EL/OL	11kv Insulator Failed near Gandamalla	-
19		Pamkunta	Singaram	11KV	Bhongir	06.20	08.30	02.10	EL/OL	11kv Pin Insulator Failed near Singaram	-
20		Pamkunta	Jala	11KV	Bhongir	05.30	09.50	04.20	EL/OL	11kv Pin Insulator Failed near Jala Village	-
21		Pamkunta	Pamkunta	11KV	Bhongir	08.30	09.45	01.15	EL/OL	11kv Insulator Failed near Pamkunta V	-
22		Puligilla	Kirchpally	11KV	Choutuppal	03.00	07.30	04.30	EL/OL	11kv Disc Failed near kirch pally V	-
23		D.Nagaram	Pipalphad Agl	11KV	Choutuppal	12.50	14.20	01.40	EL/OL	LT Line Snapped near Pipal pahd V	-
1	MDK	Patancheru	Town	11KV	Patancheru	02.20	03.50	01.30		B/D due to Conductor snapped	-
2		Patancheru	MIA-II	11KV	Patancheru	05.45	08.05	02.20		B/D due to Jumper cut	-
3		Bollaram-I	Soubhagya	11KV	Patancheru	06.35	07.42	01.07		B/D due to Insulator fail	-
1	SDPT	Gouravelli	Gudatipally	11KV	Husnabad	13.10	16.10	03.00		Insulator failure (3 Ph)	-
2		Koheda	Kurella	11KV	Husnabad	00.00	10.40	10.40		Insulator failure	-
3		Baswapur	Poreddipally	11KV	Husnabad	00.50	04.50	04.00		Heavy gale and wind	-
4		Dhoolmitta	Arjunpatla	11KV	Husnabad	10.00	11.15	01.15		Insulator failure	-
5		Komuravelli	Kadaverugu	11KV	Husnabad	02.10	06.45	04.35		Jumper cut	-
6		Komuravelli	Kumuravelli	11KV	Husnabad	02.20	06.20	04.00		Heavyn gale and wind	-
7		Marmamula	Salakpur	11KV	Husnabad	10.05	15.18	05.13		Line Cut	-
8		Nagapuri	Nagapuri	11KV	Husnabad	00.00	03.45	03.45		Heavy gale and wind	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR S	APPA	APPA	11KV	RJNR	02.45	04.30	01.45	B/D	11kv insulator Failed at SS Opposite	-
2		NIRD	NIRD	11KV	RJNR	01.15	03.30	02.15	B/D	11kv insulator Failed at RTP	-
3		Chanda Nagar	Mythri Nagar	11KV	Gachibowli	01.35	03.20	01.45	B/D	Tree branches fallen on the 11kv line at Land mark	-
4		Kaithalapur	Kaithalapur	11KV	Kondapur	02.20	03.20	01.00	B/D	Due to Heavy Rain and Wind	-
5		Ayyappa Society	Survey of India	11KV	Kondapur	02.35	04.10	01.35	B/D	Due to Heavy Rain and Wind (HG Fuse Open at Vijay Super Market)	-
6		Gachibowli	Mezquity	11KV	Kondapur	02.40	04.40	02.00	B/D	11KV Disck Failed at Palma villageMezquity	-
1	RR N	KPHB	HMT	11KV	Kukatpally	01.52	03.28	01.36	BD	Cloth fallen the 11kv line at HMT Hills, {Due to Havy Rain }	-
2		Prashanthi Hills	Mithalanagar	11KV	Kukatpally	02.30	04.00	01.30	BD	Due to Havy Rain	-
3		Chandanagar	Sriramnagar	11KV	Kukatpally	01.40	02.40	01.00	BD	Due to Havy Rain	-
4		Gagillapur	Sundhara Ashramam	11KV	Jeedimetla	00.00	01.05	01.05	BD	Lorry Dash the Pole Damaged at Opp:Sub Station	-
5		Pudur	Pudur	11KV	Medchal	13.35	16.00	02.25	BD	11KV Disc failed at Sajeev Reddy Home, Pudur	-
1	RR E	Yapral	Tulasi Garden	11KV	SKP	00.05	01.40	01.35		11Kv Pin Insulator failed at Mahankali Temple (AE)	-
2		Chekripuram	Shilpa nagar	11KV	Keesara	16.25	17.10	00.45		NO visiable falt found due to rain	-
3		Chekripuram	Shimapuri	11KV	Keesara	16.28	18.16	01.48		HT/LT line cut at Teacher colony	-
4		Nagaram	P.S rao	11KV	Keesara	17.05	17.52	00.47		Pole bend at Gayatri nagar	-
5		Keesara	Ankireddypally	11KV	Keesara	17.15	18.30	01.15		Insulator fail aat Police station back side	-
1	HYD N	Hakeempet	Risala Bazar	11KV	Bowenpally	00.35	02.25	01.50	All Indication	Pin Insulator flash over at Turkapally Water Tank	-
2		Pragatools	Rasool Pharma	11KV	Bowenpally	02.00	04.00	02.00	EL	Pin Insulator flash over at Asbestos Colony	-
3		Bowenpally	I.A.F.	11KV	Bowenpally	02.10	07.55	05.45	EL	Tree fallen on lines at I.A.F.	-
4		Pragatools	Raj Foods	11KV	Bowenpally	02.15	04.05	01.50	EL,OL-Rph	Tree branches fallen on lines at Hanuman Temple	-
5		I.D.P.L.	S.V.C.I.E.	11KV	Bowenpally	03.10	05.10	02.00	EL	Tree branches fallen on lines & Pole bent at Nala DTR	-
6		Film Nagar	B.V.Bhavan	11KV	Banjarahills	06.30	08.35	02.05	EL,OL	AB Cable fault at Shabeer Ali's House	-
7		Road No.22	UCO Bank	11KV	Banjarahills	07.40	08.42	01.02	All Indication	Breaker problem at SS	Arranged B/F on 11KV Jubilee Hills feeder

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD S	Teegalaguda	Teegalaguda	11KV	Asmangadh	01.40	03.12	01.32	OL-R&Bph	HT Jumper cut Ganga Towers	-
2		Karwan	R.S Temple	11KV	Begumbazar	01.53	03.45	01.52	EL,OL-Rph	LV-3 Bus Jumper cut at SS	-
1	HYD C	Langer House	Nethaji Nagar	11KV	Mehdipatanam	01.25	03.40	02.15	EL	Pin Insulator flash over at Nethaji Nagar	-
2		Mothi Mahal	Balansar	11KV	Mehdipatanam	01.30	04.16	02.46	EL	Faulty loads of 11KV New Military feeder	-
3		Asif Nagar	Toli Chowki	11KV	Mehdipatanam	01.30	06.15	04.45	EL	Tree branches fallen on lines at Various Locations	-
4		Asif Nagar	Kakatiya Nagar	11KV	Mehdipatanam	01.36	04.46	03.10	EL	Tree branches fallen on lines at Kakatiya Nagar	-
5		A.S.R Raju Nagar	LIC Office	11KV	Mehdipatanam	01.42	07.50	06.08	EL	Disc Insulator flash over at backside LIC Office	-
6		Nampally	Yousufian Darga	11KV	Mehdipatanam	01.44	03.45	02.01	EL,OL	Foreign material fallen on DTR at Chilla PT	
7		Industrial Area	RTC X-Road	11KV	Azamabad	01.50	02.52	01.02	EL	No Visible Fault (due to heavy rain)	Arranged B/F on 11KV Chikkadapally feeder
8		Vittalwadi	Gandhi Kuteer	11KV	Azamabad	01.50	03.10	01.20	EL	Faulty loads of 11KV APCO feeder	
9		Nizam College	Rosary Convent	11KV	Saifabad	01.50	03.22	01.32	EL,OL-Rph	No Visible Fault	
10		A.S.R Raju Nagar	Jeevan Kalyan Nagar	11KV	Mehdipatanam	01.58	03.58	02.00	EL	No Visible Fault (due to heavy rain)	
11		Indira Park	Gulshan Nagar	11KV	Saifabad	02.00	03.10	01.10	EL	No Visible Fault (due to heavy rain)	
12		Toli Chowki	Para Mount Hills	11KV	Mehdipatanam	02.03	05.17	03.14	EL	Tree branches fallen on lines at Para Mount Colony, Gate No.2	
13		I.T.I Mallepally	V.B.R.I	11KV	Mehdipatanam	02.10	03.36	01.26	EL	Cable fault at V.B.R.I	
14		Golconda	Darga Cable	11KV	Mehdipatanam	02.13	03.25	01.12	EL	No Visible Fault (due to heavy rain)	
15		Mothi Mahal	M.D Lines	11KV	Mehdipatanam	02.32	03.38	01.06	EL,OL-Yph	Brass Patti cut M.D Lines	-
16		Golconda	Aditya Nagar OH	11KV	Mehdipatanam	02.45	06.00	03.15	EL	Tree branches fallen on lines at Adams Colony	-
17		Indira Park	Indian Bulls	11KV	Saifabad	03.15	04.35	01.20	EL	No Visible Fault (due to heavy rain)	-
18		Asif Nagar	Military	11KV	Mehdipatanam	04.48	06.41	01.53	EL	Tree branches fallen on lines at Military Area	
19		Hussain Sagar	NTR Garden	11KV	Saifabad	08.08	13.50	05.42	OL-Rph	CT PT failed at Lake Plaza	Arranged B/F on 11KV I.G.Mint fdr

Circle Wise Fuse off Calls URBAN

SI.No	Circle	PREVIOUS PENDING	TODAY	TOTAL	30min.	1hr	2hrs	2hrs Above	TOTAL	Balance
1	MBNR	0	174	174	142	18	14	0	174	0
2	NLG	0	25	25	20	2	2	1	25	0
3	MDK	0	50	50	20	19	10	1	50	0
4	RR -South	0	41	41	23	14	2	2	41	0
5	RR -North	0	124	124	87	37	0	0	124	0
6	RR -East	0	145	145	100	45	0	0	145	0
7	Hyd	15	1314	1329	1144	142	0	15	1301	28
	TOTAL	15	1873	1888	1536	277	28	19	1860	28

RURAL

SI.No	Circle	PREVIOUS PENDING	TODAY	TOTAL	30min.	1hr	2hrs	2hrs Above	TOTAL	Balance
1	MBNR	0	173	173	145	16	12	0	173	0
2	NLG	0	28	28	25	1	1	1	28	0
3	MDK	0	56	56	22	23	10	1	56	0
4	RR -South	0	20	20	13	5	2	0	20	0
5	RR -North	0	23	23	16	7	0	0	23	0
6	RR -East	0	25	25	15	10	0	0	25	0
	TOTAL	0	325	325	236	62	25	2	325	0

Daily Report on 9 & 24 hours 3 - Phase Power Supply to the Agriculture Sector

S.No	Circle	Total No. of rural feeders existing	No. of feeders for which 24 hrs supply extended in					No of feeders for which 24 hours supply given	No of feeders for which supply is not extended for 24 hrs			Reasons for could not giving 24 hrs supply	Reasons for given more than 2-spells	
			1-spell	2-spell	3-spell	4-spell	5-spell		Total	23 to 24 hrs	21 hrs			Less than 22 hrs
1	MDK	852	852	0	0	0	0	852	0	0	0	0	.	.
2	MBN	840	840	0	0	0	0	840	0	0	0	0	.	.
3	NLG	999	999	0	0	0	0	999	0	0	0	0	.	.
4	RR S	241	241	0	0	0	0	241	0	0	0	0	.	.
5	RR N	50	50	0	0	0	0	50	0	0	0	0	.	.
6	RR E	83	83	0	0	0	0	83	0	0	0	0	.	.
Total		3065	3065	0	0	0	0	3065	0	0	0	0	.	.