

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	1	3	1	3	1	3			
3	MDK	107	933		1		1		1			
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	4	2	4	2	4	0	0	
	Grand Total	1082	6468	2	8	2	8	2	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Wadapally	Damarcherla	33KV	Miryalaguda	08.05	12.30	04.25		Cross Arm Failures	Wadapally	No
1	SDPT	Siddipet	Peddakodur	33KV	Siddipet	02.30	06.00	03.30		B/D line problem due to rain		-

TSSPDCL - LMRC / Corporate office

Date: 26.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Nakrekal	Chandupatla	11KV	Nalgonda	10.50	13.40	02.50	EL	11 KV line Jumper cut	-
2		Tatikol	Kacharam	11KV	Devarakonda	10.30	13.30	03.00	EL	11 KV Jumper Cutt	-
3		Thatipamula	Nandapuram	11KV	Suryapet	04.45	07.30	02.45	EL	Conductor Snapped	-
1	MDK	Bollaram - II	Kottam	11KV	Patancheru	14.50	16.40	01.50		B/D Due to Conductor snapped	-
1	RR N	Petbasheerabad	Vaishanavi Enclave	11KV	Medchal	03.45	04.35	00.50	EL/OL	Tree Branches fallen on the 11KV Line at Deccan Chronical Press	-
2		UMCC	Gajularamaram	11KV	Medchal	12.50	13.15	00.25	EL/OL	11KV Line AB Switch Opened at Pochamma Temple, Nectanguda(UG Cable failed at Krishna Mahalaxmi Nagar, Apartment T/F)	-
1	RR E	Yapral	Govt. School	11KV	Sainikpuri	00.05	01.05	01.00		11Kv AB Switch Open at Employees Colony (AE/OP) 1/2 Bit charged ok (due to Feeder problem)	-
1	HYD S	Panjasha	Panch Mohallah	11KV	Charminar	01.02	02.28	01.26	All Indication	Cable fault near SS	Arranged B/F on 11KV Bibi Bazar & 11KV Asra Hospital fdrs