

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	0	9	0	9	0	9	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933	1		1		1				
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	7	1	7	1	7	0	0	
	Grand Total	1082	6468	1	16	1	16	1	16	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.06.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	Pashamailaram	33KV	Sangareddy	10.10	12.05	01.55		B/D due to Conductor snapped	Pashamailaram	-

TSSPDCL - LMRC / Corporate office

Date: 27.06.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Marroor	Marror	11KV	Nalgonda	14.20	16.30	02.10	E/L	11KV Disc failed	-
2		Pullemla	Bodangiparthi	11KV	Nalgonda	15.30	17.00	01.30	E/L	11KV Insulator failed	-
3		Abangapuram	Abangapuram	11KV	Miryalaguda	08.30	12.00	03.30	E/L	jumper cut	-
4		Haliya	Thirumalagiri	11KV	Miryalaguda	09.10	10.00	00.50	E/L	line snapped	-
5		Boppaam	Kothagudem	11KV	Suryapet	08.40	11.15	02.35	E/L	Insulator flashover	-
6		Munagala	Turkagudem-2	11KV	Huzurnagar	09.00	11.30	02.30	E/L	Due to 11Kv jumper cutted	-
1	SDP	Koheda	Theegalakuntapally	11KV	Husnabad	21.30	00.00	02.30		BD Due to jumper cut	-
1	RR N	Laxmapur	Narayanpur	11KV	Medchal	05.00	06.40	01.40	BD	11KV Pole Damaged by car at SS Opp(Backfeeding to 11KV MC Pally feeder)	-
1	RR E	Vinayak Nagar	Tank Bund	11KV	Sainikpuri	03.05	03.50	00.45		11KV jumper cut at Sharda Nagar at Srinivasa Apt (AE/OP)	-
2		Malkaigiri	Anandbagh	11KV	Sainikpuri	10.02	11.40	01.38		UG Cable fail at RK Nagar (AE/OP)	-
3		Narapally	P.singaram	11KV	Keesara	06.20	06.55	00.35		Tree branches fallen on 11kv line at Teenugudam	-
1	HYD S	Panjesha	Gulzar House	11KV	III	00.05	01.33	01.28	EL,OL	2No. HT Lines snapped at Chali Kaman, Daruva Galli	-
1	HYD C	Chilkaiguda	Bholakpur	11KV	I	06.18	07.37	01.19	All Indicatoin	End Kit failed at Tele.Exchange	-
2		Golconda	Darga OH	11KV	VII	13.12	14.15	01.03	All Indicatoin	Cable burnt out which is near by 11KV Darga Cable feeder	-
3		Golconda	Darga Cable	11KV	VII	13.12	14.48	01.36	All Indicatoin	Cable fault	Arranged B/F on 11KV Aditya Nagar Cable feeder
4		Nampally	Pearl Regency	11KV	VII	21.07	22.27	01.20	EL,OL-Rph	I/C Cable Jumper cut at Govt. College	-