

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		14		14		14			
3	MDK	107	933		5		5		5			
4	SDPT			2	18	2	18	2	18			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	38	5	38	5	38	0	0	
	Grand Total	1082	6468	5	45	5	45	5	45	0	0	

TSSPDCL - LMRC / Corporate office

Date: 30.06.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Peddmandadi	33KV	Wanaparthy	20.02	22.30	02.28	E/L	Due to Rain	Peddmandadi	Alternate Supply Arranged From Chinnamandadi SS at 22:30Hrs
2		Gadwal	Alwalpad	33KV	Gadwal	18.35	20.35	02.00	E/L	Idle Line Opened Supply stood OK	Alwalpad	No
3		Gadwal	Bijwaram	33KV	Gadwal	18.25	21.55	03.30	E/L&O/L	Due to Rain	Bijwaram	No
1	SDPT	Thukkapur	Lingapur	33KV	Gajwel	11.55	12.50	00.55		Line snapped at Kistapur	Lingapur	No
2		Thunikibollaram	Thunikibollaram	33KV	Gajwel	01.50	05.30	03.40		Continue tripping EL&OL	Thunikibollaram	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Badepally	Alwan pally	11KV	Jadcherla	08.55	12.15	03.20		11KV Insulater failed near Kareemulla Land	No
1	NLG	Bollepally	Jampally	11KV	Bhongir	11:45	13:35	1:50	EL	Phase to Phase at Reddynayakthanda	No
2		Addagudur	CH.Ramaram	11KV	Bhongir	10.20	11.35	01.15	EL	Insulator failed near Janakipuram Village	No
3		Kapraipally	Rahimkhanpeta	11KV	Bhongir	08.10	09.20	01.10	EL	11KV Jumper cut near Rahimkhanpeta Village	No
4		Panthangi	Panthangi indl	11KV	Choutuppal	12.57	14.40	01.43	EL	Lizard Fallen at Line near Areygudem Village	No
5		Bopparam	M.Kothagudem	11KV	Suryapet	09.35	12.00	02.25	EL	Disc flashover	No
6		Gondriyala	Gondriyala-1	11KV	Huzurnagar	10.25	12.41	02.16	EL	Due to 11KV line cut	No
7		Ananthagiri	Mogalaikota	11KV	Huzurnagar	10.42	13.15	02.33	EL	Due to 11KV line cut	No
8		Munagala	Munagala(T)	11KV	Huzurnagar	07.10	09.10	02.00	EL	Due to bird fall on 11KV line	No
9		Urulugonda	N S Puram	11KV	Huzurnagar	11.45	13.00	01.15	EL	Due to 11KV Line cut	No
10		Gaddipaly	Medaram	11KV	Huzurnagar	09.15	12.40	03.25	EL	Due to 11KV Jumper cutted	No
11		Aitipamula	Annaram	11KV	Nalgonda	12.35	16.00	03.25	EL	Insulator failed	No
12		Katangur	Dugnelly	11KV	Nalgonda	11.00	13.00	02.00	EL	Tree fallen on line	No
13		Chandur	Gundrampally	11KV	Nalgonda	13.30	14.30	01.00	EL	Tree fallen on line	No
14		K.M.Pally	K.M.Pally Idl	11KV	Devarakonda	15:32	16:20	0:48	EL	HT/HT	No
1	MDK	Dundigal	Annaram	11KV	Patancheru	0:00	4:00	4:00		Jumper cut	No
2		Gummadidala	Agrobell	11KV	Patancheru	09.15	10.25	01.10		Jumper cut	No
3		Bonthapally	Veerabadra	11KV	Patancheru	01.30	05.00	03.30		Insulator failed	No
4		Waddepally	Industrial	11KV	Patancheru	09.00	11.00	02.00		Insulator failed	No
5		Patancheru Town	Town	11KV	Patancheru	2:10	4:05	1:55		Jumper cut	No
1	SDPT	Guggilla	Thimmaipally	11KV	Husnabad	18:20	21:00	2:40		Insulator failed	No
2		Nagapuri	Gandikunta	11KV	Husnabad	09.50	13.10	03.20		Insulator failed	No
3		Nagapuri	Pothireddypalli	11KV	Husnabad	12.00	12.50	00.50		Insulator failed	No
4		Mustyal	Cherial Town	11KV	Husnabad	00.00	08.30	08.30		Insulator failed	No
5		Thotapally	Anthakkapet	11KV	Husnabad	00.00	08.00	08.00		3 Ph BD, 1 Ph OK	No
6		Thotapally	Thotapally	11KV	Husnabad	00.00	09.50	09.50		Jumper cut	No
7		Gandipally	Ramavaram	11KV	Husnabad	00.00	07.40	07.40		Trees fallen	No
8		Gandipally	Ramavaram Exp	11KV	Husnabad	00.00	04.30	04.30		Trees fallen	No
9		Pandilla	Potlapally	11KV	Husnabad	17.10	18.10	01.00		Jumper cut	No
10		Koheda	Kurella	11KV	Husnabad	17.10	19.50	02.40		Insulator failed	No
11		Koheda	Sriramulapally	11KV	Husnabad	16.45	17.30	00.45		Insulator failed	No
12		Koheda	Sriramulapally	11KV	Husnabad	03.15	05.10	01.55		Jumper cut	No
13		Koheda	Theegalakuntapally	11KV	Husnabad	13.50	17.30	03.40		Insulator failed	No
14		Bekkal	Bekkal town	11KV	Husnabad	03.30	07.40	04.10		Insulator failed	No
15		Dhoolmitta	Arjunpatla	11KV	Husnabad	04.44	10.04	05.20		Heavy gale	No
16		Marmamula	Salakpoor	11KV	Husnabad	00.00	08.30	08.30		Breaker failure & Line fault	No
17		Komuravelly	Kistampet	11KV	Husnabad	06.00	08.30	02.30		Line fault	No
18		Komuravelly	Komuravelly Agl	11KV	Husnabad	14:20	16:20	02.00		Line fault	No
1	RR N	Athiwelly	SPIC	11KV	Medchal	16:30	18:20	1:50		11KV Pin insulator failed at Somaram Cheruvu	No
2		Vijayanagar	Jayanagar	11KV	Kukatpally	11.55	14.00	02.05		11KV End Kit failure at Vijayanagar	No
1	RR E	Moula-Ali	Moula-Ali	11KV	Sainikpuri	13:52	14:50	0:58		Lezard fallen on 11Kv line at SP Nagar	No
2		Chakripuram	SV Nagar	11KV	Keesara	12.18	13.36	01.18		Tree branches fallen on 11KV line at S.V Nagar Road No. 02	No
3		Yadgarpally	Yadgarpally	11KV	Keesara	10.00	11.00	01.00		11KV Pin insulator failed, 11KV line cut & 11KV HG Fuse insulator failed at Kummarikunta	No
4		Aushapur	Aushapur	11KV	Keesara	13.50	15.05	01.15		11KV Line cut near Modi Builders	No
1	HYD C	Lakeview	Janapriya	11KV	Saifabad	23.15	00.59	01.44	EL, OL-Rph	Breaker problem at SS	Arranged B/F on 11KV Janapriya feeder from 33KV Hussainsagar