

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	2	2	2	2	2	2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044	1	2	1	2	1	2			
	Total	606	3055	3	5	3	5	3	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	3	9	3	9	3	9	0	0	

TSSPDCL - LMRC / Corporate office

Date: 05.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV Malkaram	33KV Ratnalayam	33KV	Medchal	07.35	09.05	01.30	BD	No fault (EL & OL B Phase)	33KV Ratnalayam	-
2		132KV Medchal	33KV Keshavaram	33KV	Medchal	10.18	12.10	01.52	BD	No visible fault	33KV Keshavaram	-
1	HYD S	220KV Shivrampally - Attapur	Hyderguda (Idle)	33KV	Malakpet	11.07	15.20	04.13	EL,OL-Rph	Disc Insulator flash over near 77/25 Towers	Hyderguda (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 05.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Palakeedu	Bothalapalem	11KV	Huzurnagar	06.10	08.00	01.50	EL	11 KV LINE SNAPPED	-
2		Singaram	Singaram	11KV	Huzurnagar	11.40	12.50	01.10	EL	11 KV JUMPER CUT	-
3		Choutuppal IPDS	Thangedipally	11KV	Choutuppal	10.30	13.05	02.35	EL	1kv Line snapped near Thangadapally Village	-
1	SDP	Cherial Town	Cherial-Town	11KV	Husnabad	15.25	16.05	00.40		Tree branch fallen on line, same rectified	-
1	RR N	Dulapally	Karteekavanam	11KV	Medchal	10.20	11.22	01.02	BD	No visible fault	-
2		Devarayamjal	Mandaipally	11KV	Medchal	09.00	11.20	02.20	BD	11KV Jumper Cut & Replaced at Darga, Yelagalaguda Village	-
1	RR E	Kushaiguda	Neredmet	11KV	Sainikpuri	23.10	23.46	00.36		Tree branches fallen on 11Kv line at HMT Galli AS Rao Nagar (LM Srinivas)	-
1	HYD N	Mothi Nagar	Avanthi Nagar	11KV	IV	00.58	02.23	01.25	All Indication	AB Cable fault at Kabeer Nagar Bus Stop	Arranged B/F on 11KV P.R.Nagar fdr
1	HYD S	Malakpet	M.M.H.	11KV	VIII	06.35	08.45	02.10	EL,OL-Rph	Disc Insulator flash over at Imthiza Masjid	-