

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	1	5	1	5	1	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 06.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDP	Siddipet	Peddkodur	33KV	Siddipet	12.00	13.40	01.40		B/D for Tree branches fall line	Peddkodur	-

TSSPDCL - LMRC / Corporate office

Date: 06.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kudakuda	MG Nagar Thanda	11KV	Suryapet	11.00	13.05	02.05	E/L	11Kv Insulator failed	-
2		Nadigudem	Nadigudem agl	11KV	Huzurnagar	16.00	17.10	01.10	E/L	11Kv Jumper cut	-
3		Gundala	Gangapur	11KV	Bhongir	09.15	13.00	03.45	E/L	11kv Disc Failed near SS-13 Machampally (V) 3Phase B/d Single phase ok	-
1	RR N	Subhash Nagar	Gayatri Nagar	11KV	Medchal	17.30	18.30	01.00	BD	11KV Pin Insulator failed at TNR	-
1	HYD C	Asif Nagar	Mehdipatnam OH	11KV	VII	19.15	20.43	01.28	EL,OL	Insulator flash over at Jayabhushan Hospital	Arranged B/F on 11KV Mehdipatnam Cable fdr