

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		6		6		6			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>11</b>	<b>0</b>	<b>0</b>	



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Chedella	Nelamarri	11KV	Suryapet	8:00	10:40	2:40	EL	Insulator failed	No
2		Siripuram	Siripuram	11KV	Huzurnagar	14.15	16.20	02.05	EL	Insulator failed	No
3		Jublakpally	Kanumukula	11KV	Choutuppal	06.00	10.18	04.18	EL	11KV Insulator failed near Kanumukula Village	No
1	RR N	Nuthankal	Bharathi	11KV	Medchal	9:10	9:50	0:40		Bird fallen on the 11KV line at Bharathi Company	No
2		Laxmapur	Laxmapur	11KV	Medchal	15.55	16.42	00.47		Tree branch fallen on the line at Kushi Foultry Farm	No
1	HYD N	Addagutta	Hanuman Temple	11KV	C-VI	05.08	06.21	01.13	OL-Rph	Pin Insulator flash over at Polytechnic College	No
2		Marredpally	Ramsar Café	11KV	C-VI	13:35	15:20	1:45	EL	Tree branches fallen on lines at West Marredpally	No
3		Bowenpally	I.A.F	11KV	VI	15:30	17:00	1:30	EL,OL-Yph	CT PT failed at I.A.F	No
1	HYD C	Golnaka	Harazpenta	11KV	II	17.43	18.59	01.16	EL,OL	Cable fault at Golnaka New Bridge	Arranged B/F on 11KV Prabath fdr
2		Vittalwadi	APCO	11KV	II	05.35	07.02	01.27	EL,OL-Rph	Auto Reclosure Jumper cut at Shanthi Theatre	6:50Hrs partial feeder chared, remaining loads added on 11KV Preventive Medicine fdr
3		Golnaka	Kamala Nagar	11KV	II	10.04	11.54	01.50	EL,OL	Pin Insulator flash over at Ashoka Biscuit	No