

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1		1		1				
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	6	0	6	0	6	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

## TSSPDCL - LMRC / Corporate office

Date: 10.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV DP Pally	33KV Gowdawelly	33KV	Medchal	03.02	10.00	06.58		Tree Fallen on 33KV Line	33KV Gowdawelly	-

## TSSPDCL - LMRC / Corporate office

Date: 10.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marrikal	Chakalapally	11KV	Narayanpet	10.01	14.15	04.14		11KV Jumper cut near Mogulapally(v)	-
1	NLG	Kattangur	Kurumarthy	11KV	Nalgonda	04.00	10.00	06.00	EL	11Kv Jumper cut	-
2		Aipoor	Mukkududevulapally	11KV	Suryapet	15.15	18.00	02.45	EL	Insulator Failed	-
3		Dirsincherla	Yellapuram	11KV	Huzurnagar	04.00	07.00	03.00	EL	Due to 11Kv line snapped	-
1	SDPT	Koheda	Theegalakuntapally	11KV	Husnabad	06.10	11.10	05.00		B/D due to Insulator Fail	-
2		Koheda	Theegalakuntapally	11KV	Husnabad	15.00	15.50	00.50		B/D due to Jumper cut	-
1	HYD S	Asmangadh	Shiva Ganga	11KV	VIII	21.45	23.25	01.40	EL	Pin Insulator flash over at Bharadvaj Apts	