

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | | | | | | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 2 | | 2 | | 2 | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 1 | | 1 | | 1 | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | 1 | | 1 | | 1 | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 5 | 1 | 5 | 1 | 5 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 7 | 1 | 7 | 1 | 7 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 12.11.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-----------------------------------|-----------------------|---------------------------|
| 1 | SDP | Mustyala | Komuravelly | 33KV | Husnabad | 06.10 | 11.15 | 05.05 | | Insulator Fail at ramsagar chervu | Komuravelly | - |

TSSPDCL - LMRC / Corporate office

Date: 12.11.2019

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Udithyal | Macharam | 11KV | Jadcherla | 08.21 | 12.50 | 04.29 | | 11KV Phase To Phase Near Suraram Vagu Side | - |
| 1 | NLG | Kethepally | Chikatigudem | 11KV | Nalgonda | 13.00 | 15.00 | 02.00 | E/L | 11 KV Line Junper Cut | - |
| 2 | | Kamareddygudem | Konathanapally | 11KV | Miryalaguda | 15.20 | 16.35 | 01.15 | E/L | 11KV Conductor snapped near village | - |
| 3 | | Keethavarigudem | Sarvaram | 11KV | Huzurnagar | 05.00 | 06.45 | 01.45 | EL | 11 KV LINE SNAPPED | - |
| 4 | | Phanigir | Etoor | 11KV | Suryapeta | 05.00 | 07.40 | 02.40 | EL | Insulator failed | - |
| 1 | HYD N | Chilkaiguda | New Boiguda | 11KV | V | 19.35 | 21.00 | 01.25 | EL | No Visible Fault | - |
| 1 | HYD S | C.R.P.F | Omar Colony | 11KV | III | 16.30 | 17.38 | 01.08 | EL | Kept off Pashabai DTR at Omar Colony | - |