

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933	1		1		1				
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	3	1	3	1	3	0	0	
	Grand Total	1082	6468	1	8	1	8	1	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.11.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Bollaram	Shathavahana	33KV	Sangareddy	10:00	11:45	1:45		Tree branches fallen on the line	Shathavahana	No

TSSPDCL - LMRC / Corporate office

Date: 14.11.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Cherkupally	Bandapalem	11KV	Nalgonda	15:18	17:35	2:17	EL	11KV Jumper cut	No
2		Raghunadapalem	Raghunadapalem	11KV	Huzurnagar	05.30	08.25	02.55	EL	11KV Insulator failure	No
3		B.Ramaram	Hajipur	11KV	Bhongir	02.30	08.00	05.30	EL	11KV Insulator failed near Machanpally Village	No
1	RR N	Jeedimetla SSII	Phase IV	11KV	Jeedimetla	3:35	5:10	1:35		11KV Phase IV feeder incoming jumper cut at Sub station	No
2		Devarayamjal	Mandaipally	11KV	Medchal	04.30	07.40	03.10		25KVA T/F Failed at Mandaipally Village	No
1	RR E	Sainikpuri	Saipuri	11KV	Sainikpuri	12:05	14:05	2:00		11KV Line snapped at Hasthinapuri near Road No 2	No
2		Sainikpuri	Ramalyam	11KV	Sainikpuri	17.00	18.25	01.25		11KV AB cable cut and rebinding at Defence Colony near Indu Travels	No
1	HYD C	S.D.Hospital	Crescent Hospital	11KV	VII	02.11	03.50	01.39	EL,OL	Cable damaged at Crescent Hospital	No