

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988	1	4	1	4	1	4			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>2</b>	<b>4</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 15.11.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Town-3	33KV	Mahabubnagar	09.56	10.12	00.16	E/L&O/L	Due to heavy spark at line side	Town-3	Alternate Supply Arranged From 33KV Nawabpet at 10:12Hrs.
1	NLG	Dirincherla	Kalmalcheruvu	33KV	Huzurnagar	13:45	16:00	2:15	EL/OL	33KV Jumper and Insulator damaged	Kalmalcheruvu	No

TSSPDCL - LMRC / Corporate office

Date: 15.11.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kethepally	Kothapet	11KV	Nalgonda	9:00	13:22	4:22	E/L	11KV Jumper cut	No
2		Kasarabada	Kesaram	11KV	Suryapet	07.45	09.46	02.01	E/L	11KV Conductor snapped	No
3		Raghunadapalem	Nakkagudem	11KV	Huzurnagar	13.10	14.50	01.40	E/L	11KV Jumper cut	No
4		Yallanki	Sarnenigudem	11KV	Choutuppal	09.00	16.10	07.10	E/L	11KV Line snapped near Sarnenigudem (V)	No