

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	G.T Giri	Bakthalapuram	11KV	Suryapet	04.30	08.15	03.45	E/L	11Kv Conductor snapped	-
2		Palakeedu	Sajapuram	11KV	Huzurnagar	13.00	14.45	01.45	E/L	11Kv Conductor snapped	-
3		Velmajala	Kommaipally	11KV	Bhongir	23.05	07.50	08.45	EL	11Kv Line snappad Near Kommaipally (V) 3Phase B/d Single phase ok	-
1	SDP	Thotapally	Thotapally (R)	11KV	Husnabad	08.20	12.17	03.57		BD,Insulator failure	-
2		Bekkal	Kutigal	11KV	Cherial	08.00	12.25	04.25		BD,Jumper problem	-
1	HYD S	Kandikalgate	Phool Bagh	11KV	III	23.25	01.00	01.35	EL,OL-R&Bph	Breaker problem at SS	Arranged B/F on 11KV Gazi Millath Colony & 11KV Saibaba Nagar feeders
2		Kanchanbagh	Riyasath Nagar	11KV	III	23.34	00.50	01.16	All Indication	Cable fault	Arranged B/F on 11KV Omar Colony feeder