

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403									
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933									
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>8</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>12</b>	<b>0</b>	<b>0</b>	



S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Katangur	Mallaram	11KV	Nalgonda	14:10	16:30	2:20	EL	11KV Line Jumper Cut	No
2		Arjalabavi	Arjalabavi	11KV	Nalgonda	04.00	06.10	02.10	EL	Bird died on the line	No
3		N Annaram	Lingala	11KV	Suryapet	09.00	12.30	03.30	EL	Insulator failed	No
4		Thogarrai	Kuchipudi	11KV	Huzurnagar	06.10	08.00	01.50	EL	11KV Line sanpped	No
5		Garidepally	Appannapet	11KV	Huzurnagar	06.25	07.35	01.10	EL	11KV Line sanpped	No
6		Paladugu	Duppally	11KV	Bhongir	12:25	14:00	1:35	EL	11KV Line sanpped	No
1	SDPT	Akunoor	Dommata	11KV	Husnabad	11:45	18:10	6:25		DTR Problem	No
2		Gagillapur	Vallampatla	11KV	Husnabad	08.35	10.33	01.58		Insulator failed	No
1	RR N	Jagathgiringutta	Maqdoom Nagar	11KV	Medchal	15:35	16:40	1:05		End Kit failed at Polala Basti	No
2		Gowdawelly	IDA Gowdavelly	11KV	Medchal	05.40	06.10	00.30		Tree fallen on 11KV line at Saketh Vencher	No
3		Nuthankal	Bharathi	11KV	Medchal	09.30	10.48	01.18		11KV Line cut & replaced at Narasimha Bhavi, near SS	No
4		Medchal	IDA-I	11KV	Medchal	09.53	11.05	01.12		11KV Line cut & Replaced at REVL Canteen Opposite	No