

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044	1	1	1	1	1	1			
	Total	606	3055	1	1	1	1	1	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	3	2	3	2	3	0	0	
	Grand Total	1082	6468	3	4	3	4	3	4	0	0	

TSSPDCL - LMRC / Corporate office

Date: 24.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Narayanapet	Kotakonda	33KV	Narayanapet	01.30	08.10	06.40	E/L	Insulator Replacement at 33KV Kotakonda SS	Kotakonda	-
2		Kodangal	Hamsanpally	33KV	Vikarabad	13.30	16.10	02.40	E/L	for chameleon Fallen on the line Near 132KV SS	Hamsanpally	-
1	HYD N	220KV Shapur Nagar	I.D.P.L. (Idle)	33KV	Allwyn	09.32	16.55	07.23	EL	Cable End kit failed at D.P.Structure, 132KV IDPL SS	I.D.P.L. (Idle)	-

TSSPDCL - LMRC / Corporate office

Date: 24.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Urulugonda	Thummagudem	11KV	Huzurnagar	03.00	06.00	03.00	EL	Due to 11Kv line cuuted	-
2		Mothkur	Areygudem	11KV	Bhongir	14.50	16.40	01.50	OL	11 kv Line Snapped	-
3		Golanpally	Golanpally	11KV	Choutuppal	13.05	16.30	03.25	OL	11 KV Line Snapped	-
1	HYD C	Vittalwadi	Gandhi Kuteer	11KV	II	18.38	21.40	03.02	EL,OL-R&Bph	Bird fault on lines at Airbus Apts & Jumper cut at Vittalwadi	20:35Hrs partial fdr charged