

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988	4	7	4	7	4	7			
3	MDK	107	933		1		1		1			
4	SDPT			2		2		2				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	8	6	8	6	8	0	0	
	Grand Total	1082	6468	6	13	6	13	6	13	0	0	

TSSPDCL - LMRC / Corporate office

Date: 26.11.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Madugulapally	Agamothkur	33kv	Miyalaguda	10.50	12.15	01.25		132KV Yard Jumper Cut	Agamothkur	-
2		Madugulapally	Thadakamalla	33kv	Miyalaguda	10.50	12.15	01.25		132KV Yard Jumper Cut	Thadakamalla	-
3		Madugulapally	Agamothkur	33kv	Miyalaguda	14.00	15.15	01.15		33KV wire melting 33/11KV SS Madugulapally	Agamothkur	-
4		Madugulapally	Thadakamalla	33kv	Miyalaguda	14.00	15.15	01.15		33KV wire melting 33/11KV SS Madugulapally	Thadakamalla	-
1	SDPT	Chandlapur	Kammarlapally	33kv	Siddipet	21.14	00.00	02.46		No visible fault	Kammarlapally	-
2		Thukkapur	Mirdoddy	33kv	Gajwel	12.55	17.10	04.15		33 KV loose line kangal village	Mirdoddy	-

TSSPDCL - LMRC / Corporate office

Date: 26.11.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Akaram	Shanthinagar	11KV	Nalgonda	04.15	08.30	04.15	EL	11KV Jumper cut	-
2		Nampally	M.R.Pally	11KV	Devarakonda	03.00	10.45	07.45	EL	Movement Fault	-
3		Penpahad	Anajipuram	11KV	Suryapet	04.30	07.20	02.50	E/L	Conductor S.napped	-
4		Dirsincherla	Nereducherla T-2	11KV	Huzurnagar	04.00	06.15	02.15	EL	Due to 11Kv Jumper cutted	-
5		Ananthagiri	V.R.Puram	11KV	Huzurnagar	14.30	16.15	01.45	EL	Due to 11Kv Jumper cutted	-
6		Bollepally	Jampally	11KV	Bhongiri	13.10	16.50	03.40	EL/OL	11kv Line Snapped near R N Thanda	-
7		Choutuppal	Jublakpally	11KV	Choutuppal	07.50	11.10	03.20	EL/OL	100 kva DTR Blast at SS-1 & 11 KV Disc Failed Near Dharmojigudem Village , 11 kv Line Snapped Near Lakkaram Village.	-
1	MDK	Sadasivapet	TSM	11KV	Sangareddy	06.30	08.30	02.00		B/D Due to Tree branches fallen on the line.	-
1	RR N	Aleap	Doctors colony	11KV	Jeedimetla	17.20	19.00	01.40	BD	11kv cable kit, Insulator failure near pt no 141 at Ayyappa nilayam	-
2		Ravalkole	IDA Ravalkole	11KV	Medchal	13.40	15.30	01.50	BD	Bird fallen on the 11KV Line at JC Premium Company	-
1	RR E	Nacharam	Surana	11KV	Habsiguda	02.01	02.46	00.45		Due to Lorry parked below 11kv line & touched to 11kv line near Indian Petrol Bunk	-
2		Aushapur	Aushapur	11KV	Keesara	09.10	10.30	01.20		Bird fallen on 11kv line at SPR College	-
1	HYD S	Ch' Baradari	Doodh Bowli	11KV	Asmangadh	10.10	11.30	01.20	EL	AB Cable fault at Osmanbagh	