

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3	1	3	1	3	1			
2	NLG	144	988		5		5		5			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	4	7	4	7	4	7	0	0	
	Grand Total	1082	6468	4	8	4	8	4	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 27.11.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kankurthy	33KV	Narayanapet	06.00	07.15	01.15	EL	Insulator failed	Kankurthy	Alternate supply taken from Mogalmdka SS at 7:15Hrs.
2		Kodangal	Kodangal	33KV	Vikarabad	04.30	09.15	04.45	EL	Insulator failed and Replaced	Kodangal	No
3		Alampur	Shanthinagar -1	33KV	Gadwal	09.51	16.12	06.21	OL	Tree branch fallen on the line and Tree cutting near Maisammagattu	Shanthinagar -1	No
1	MDK	Zaheerabad	Machanoor	33KV	Zaheerabad	12:20	15:00	2:40		Jumper cut	Machanoor	No

TSSPDCL - LMRC / Corporate office

Date: 27.11.19

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Rajapur	Chennavelly	11KV	Jadcherla	09.00	14.00	05.00		11KV Wire cut near Kucharkal	No
1	NLG	G.T Giri	Thirumalagiri	11KV	Suryapeta	1:30	5:00	3:30	E/L	Insulator flashover	No
2		Munagala	Lift	11KV	Huzurnagar	04.00	07.00	03.00	EL	Due to 11KV line cut	No
3		Janpahad	Janpahad	11KV	Huzurnagar	09.59	12.30	02.31	EL	Due to 11KV Jumper cut	No
4		MT.Pally	Dharmaram	11KV	Bhongir	06.30	08.35	02.05	EL	11KV Line snapped	No
5		Choutuppal	Town 2	11KV	Choutuppal	7:40	10:15	2:35	EL	11 kv Line snapped at Residential school near Choutuppal Town	No
1	MDK	Gummadidala	Bell Remedies	11KV	Patancheru	11:50	15:50	4:00		Insulator failed	No
1	RR E	Kushaiguda	Sriram Nagar	11KV	Sainikpuri	2:40	3:10	0:30		No visible fault	No