

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | | | | | | | | |
| 7 | RR(E) | 168 | 403 | | 1 | | 1 | | 1 | | | |
| 8 | Hyd | 194 | 1044 | | 1 | | 1 | | 1 | | | |
| | Total | 606 | 3055 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | | 1 | | 1 | | | | |
| 2 | NLG | 144 | 988 | | 4 | | 4 | | 4 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 1 | 4 | 1 | 4 | 1 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 1 | 6 | 1 | 6 | 1 | 6 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 30.11.19

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---------------------------|
| 1 | MBNR | Maddur | Vepoor | 33KV | Narayanpet | 09.32 | 13.25 | 03.53 | E/L | 33KV Jumper cut and touched to the Cross arm at Ekkadamad (V) | Vepoor | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--------------------------|---------------------------|
| 1 | NLG | Kothagudem | Kothagudem | 11KV | Miryalaguda | 3:00 | 5:25 | 2:25 | EL | 11KV Disc failure | No |
| 2 | | Mupparam | G.K.Palem | 11KV | Miryalaguda | 04.00 | 06.00 | 02.00 | EL | 11KV Insulator failure | No |
| 3 | | Dirsincherla | Chillepally | 11KV | Huzurnagar | 05.30 | 08.30 | 03.00 | EL | 11KV Line Snapped | No |
| 4 | | Urulugonda | Thummagudem | 11KV | Huzurnagar | 07.00 | 09.00 | 02.00 | EL | 11KV Line cut | No |
| 1 | RR E | Moula-Ali | Mirzalaguda | 11KV | Sainikpuri | 15:34 | 16:30 | 0:56 | | 11KV Disc failed | No |
| 1 | HYD C | Golnaka | Nehru Nagar | 11KV | II | 03.42 | 04.57 | 01.15 | EL,OL | HT Jumper cut at Goshala | No |