

## Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	5	1	5	1	5			
7	RR(E)	168	403		10		10		10			
8	Hyd	194	1044		40		40		40			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>55</b>	<b>1</b>	<b>55</b>	<b>1</b>	<b>55</b>	<b>0</b>	<b>0</b>	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	2	7	2	7	2	7			
3	MDK	107	933		1		1		1			
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>5</b>	<b>9</b>	<b>5</b>	<b>9</b>	<b>5</b>	<b>9</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>6</b>	<b>64</b>	<b>6</b>	<b>64</b>	<b>6</b>	<b>64</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 04.10.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Machanpally	33KV	Mahabubnagar	14.48	20.40	05.52	EL	33KV Conductor snapped near Bandamedipally.	Machanpally	No
2		Polepally	Jadcherla	33KV	Jadcherla	23.25	00.40	01.15	EL	33KV Jumper cut near 132KV Polepally End	Jadcherla	No
1	NLG	Kusumanchi	Mamillagudem	33KV	Huzurnagar	9:30	15:30	6:00	EL/OL	11KV 5 Poles bended due to heavy wind and gail	Mamillagudem	No
2		B.B.Nagar	Kondamadugu	33KV	Bhongiri	13.40	14.40	01.00	EL/OL	33KV CT Blast	Kondamadugu	No
1	SDPT	Angadikistapur	Jagadevpur	33KV	Gajwel	17:26	19:10	1:44		Earth Fault or Insulater Blost	Jagadevpur	No
1	RR N	132KV Medchal	Athiwelly	33KV	Medchal	15:15	17:27	2:12		Tree branches fallen on 33KV line at CMR College	Athiwelly	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	D.Nagaram	Machireddy Pally	11KV	Suryapeta	4:20	6:50	2:30	E/L	Disc flashover	No
2		Keethavarigudem	Kothagudem	11KV	Huzurnagar	04.00	06.00	02.00	EL	11 KV Insulator failed	No
3		Mellacheruvu	Revoor	11KV	Huzurnagar	17.50	21.40	03.40	EL	11 KV Line snapped	No
4		Thogarrai	Thogarrai	11KV	Huzurnagar	15.30	17.00	01.30	EL	11 KV Line snapped	No
5		Yennaram	Kakkireni	11KV	Choutuppal	11.30	14.20	02.50	EL	11 kv Insulator failed near Kakkireni Village	No
6		MT.Pally	MT.Pally	11KV	Choutuppal	12.20	17.15	04.55	EL	100KVA DTR failed at SS-35 near MT.Pally Village	No
7		Settipalem	AR Gudem	11KV	Miryalaguda	8:05	9:10	1:05	EL	Moment fault	No
1	MDK	Kistareddypet	Industrial	11KV	Patancheru	9:00	10:00	1:00		Tree branches fallen on the line	No
1	SDPT	Shanigaram	Shanigaram Town	11KV	Husnabad	12:00	14:00	2:00		Conductor snapped	No
1	RR N	Subhash Nagar	Padma Nagar	11KV	Medchal	15:55	17:30	1:35	EL	11KV Pin insulator failed at Padma nagar Phase -II	No
2		Petbasheerabad	Vaishnavi Enclave	11KV	Medchal	16.20	18.30	02.10	EL	Tree fallen on the 11KV line at Deccan Crannical	No
3		Kompally	Dholari Dhani	11KV	Medchal	15.47	17.38	01.51	EL	Tree fallen on 11KV line at SNR Gadham	No
4		Kandlakoya	KV Reddy Nagar	11KV	Medchal	16.00	18.10	02.10	EL/OL	11KV Line cut at at Bio Sakshi dhaba	No
5		GP Pally	GP Pally	11KV	Medchal	16:10	16:50	0:40	EL/OL	Tree fallen on 11KV line at Ayodhya X road	No
1	RR E	Cherlapally-V	Ambedkar Nagar	11KV	Sainikpuri	9:55	10:30	0:35		11KV Line Jumper cut at Chinna Cherlapally	No
2		Moula-Ali	Meerpet	11KV	Sainikpuri	16.30	18.25	01.55		11KV Disc failed at Tirumala Nagar	No
3		AS Rao Nagar	Barath Nagar	11KV	Sainikpuri	16.45	18.10	01.25		HG Fuse insulator fail at Barath Nagar	No
4		AS Rao Nagar	AS Rao Nagar	11KV	Sainikpuri	16.45	18.20	01.35		Coconut Tree Branches on 11KV line at AS Rao Nagar	No
5		Vasanthapuri	Ragavendra	11KV	Sainikpuri	16.30	19.05	02.35		UG Cabe failed Ragavendra Load Add on Dayanand Nagar feeder	No
6		Malkajgiri	Dayanand Nagar	11KV	Sainikpuri	17.10	18.15	01.05		Tree branches fallen on 11KV line Street No 4 Vani Nagar	No
7		Malkajgiri	Uttam Nagar	11KV	Sainikpuri	17.28	18.42	01.14		Tree fallen on 11KV line on Sharee fallen on 11KV line at Uttam Nagar	No
8		Uppal	Adarsh nagar	11KV	Habsiguda	16.30	18.40	02.10		Insulator failed & tree fallen on 11KV line at Mahadev Motor	No
9		Uppal	GKSAR	11KV	Habsiguda	16.35	17.30	00.55		Tree branches fallen on 11KV line at new Bharath nagar	No
10		Pocharam	Jodimatla	11KV	Keesara	6:20	7:05	0:45		Tree fallen on 11KV line at Legther company	No
1	HYD N	Road No.13	Gowri Shankar Nagar	11KV	X	00.38	01.46	01.08	EL,OL	No Visible Fault	Arranged B/F on 11KV Babukhan Chambers fdr
2		Tirumalagiri	Mangapuram Colony	11KV	C-VI	15:55	17:25	1:30	EL,OL-Bph	No Visible Fault (Due to Rain)	No
3		R.P Nilayam	E.M.E	11KV	C-VI	15:45	17:10	1:25	EL	No Visible Fault (Due to Rain)	No
4		R.P Nilayam	Venkatapuram	11KV	C-VI	15:45	17:15	1:30	EL	No Visible Fault (Due to Rain)	No
5		R.P Nilayam	Naga Devatha Temple	11KV	C-VI	15:55	17:15	1:20	OL-Rph	No Visible Fault (Due to Rain)	No
6		Bhudevi Nagar	L.N Colony	11KV	C-VI	15:50	17:20	1:30	EL	No Visible Fault (Due to Rain)	No
7		Tirumalagiri	Chinna Kamella	11KV	VI	15:50	16:51	1:01	EL,OL-Bph	HG fuse at Chinna Kamella	No
8		New Bowenpally	Ali Complex	11KV	VI	16:25	17:30	1:05	EL,OL-Rph	Tree branches fallen on lines at MMR Garden	No
9		Gunrock	A.W.H.O	11KV	C-VI	15:55	17:05	1:10	EL	No Visible Fault (Due to Rain)	No
10		Gunrock	Surya Enclave	11KV	C-VI	16:00	17:20	1:20	EL	No Visible Fault (Due to Rain)	No
11		Bowenpally	Sancharpuri Colony	11KV	VI	16:20	17:45	1:25	OL-Y&Bph	No Visible Fault (Due to Rain)	No
12		Bowenpally	Kalinga Enclave	11KV	VI	16:10	17:20	1:10	EL	No Visible Fault (Due to Rain)	No
13		Gymkhana	Vasavi Nagar	11KV	C-VI	16:11	17:34	1:23	EL	No Visible Fault (Due to Rain)	No
14		Pattigadda	Budha Bhavan	11KV	V	16:15	17:50	1:35	EL	Tree branches fallen on lines at Buda Bhavan	No
15		K.I.M.S	D.V Colony	11KV	V	16:17	18:00	1:43	EL,OL-Rph	DTR fault at Akash Apartment	No
16		Gunrock	Lal Bazar	11KV	C-VI	15:58	17:50	1:52	EL	Net Cable & Tree branches fallen on lines at P&T Colony	No
17		Gunrock	Gymkhana	11KV	C-VI	16:05	18:15	2:10	EL	Tree branches fallen on lines at Surya Nagar & Sector 'A'	No
18		Gunrock	M.D.F	11KV	VI	16:11	17:25	1:14	EL	No Visible Fault (Due to Rain)	No
19		Gunrock	Anjaiah Nagar	11KV	VI	16:12	17:27	1:15	EL	No Visible Fault (Due to Rain)	No
20		Bhudevi Nagar	Ramraj Nagar	11KV	VI	16:00	18:20	2:20	EL	Tree fallen on lines at Samatha Nagar	No
21		Bansilalpet	Botany School	11KV	VI	16:15	18:19	2:04	All Indication	HT line snapped at Botany School	No
22		Gunrock	Tirumalagiri	11KV	C-VI	16:13	18:25	2:12	EL	Tree branches fallen on lines at Kanta Basti	No
23		Gunrock	Medchal	11KV	C-VI	16:10	18:30	2:20	EL	Tree branches fallen on lines at Ravi Colony & O/G Bph jumper cut at SS	No
24		Nehru Nagar	LIC Colony	11KV	C-VI	16:15	18:30	2:15	EL,OL-Yph	Tree branches fallen on lines at LIC Colony	No
25		Chinna Thokatta	Parkview Enclave	11KV	VI	16:08	18:05	1:57	EL,OL	Tree branches fallen on lines at Allam Tea	No
26		Chinna Thokatta	Hasmathpet	11KV	VI	16:04	18:40	2:36	EL	No Visible Fault (Due to Rain)	No
27		R.P Nilayam	Naga Devatha Temple	11KV	C-VI	17:20	18:45	1:25	EL,OL-Rph	No Visible Fault (Due to Rain)	No
28		Gymkhana	Balamrai	11KV	C-VI	16:13	18:10	1:57	EL,OL-Yph	Tree branches fallen on lines at Balamrai	No
29		Gymkhana	Tadbun Temple	11KV	C-VI	16:13	17:57	1:44	EL,OL-Yph	Tree branches fallen on lines at Tadbun Temple	No
30		Gymkhana	Rani Bagh	11KV	C-VI	16:13	18:35	2:22	EL,OL-Rph	Tree branches fallen on lines at Ranibagh	No
31		Gymkhana	Pared Ground	11KV	C-VI	16:15	19:28	3:13	EL,OL-Rph	Tree branches fallen on lines at Tovoli	No
32		Gymkhana	Vikrampuri	11KV	C-VI	16:30	19:16	2:46	EL,OL-Bph	Tree branches fallen on lines at Janakpuri	No
33		Gymkhana	Sikh Village	11KV	C-VI	16:31	18:39	2:08	EL,OL-Yph	Tree branches fallen on lines at Sikh Village	No
34		Marredpally	Jyothi Colony	11KV	C-VI	16:12	19:00	2:48	EL	Tree branches fallen on lines at JBS	No
35		R.P Nilayam	Rythu Bazar	11KV	C-VI	16:35	20:20	3:45	EL	Tree branches fallen on lines at H.P Petrol Bunk	No
36		Tirumalagiri	Sinagar Colony	11KV	C-VI	15:55	20:25	4:30	EL,OL-R&Yph	Tree fallen on lines at Mahalaxmi Colony	(3no DTR off)
37	Marredpally	Military Hospital	11KV	C-VI	16:10	0:25	8:15	EL	Tree branches fallen tree branches on lines at Military Hospital	Partial fdr charged & remaining loads added on 11KV Officers Colony fdr	
38	Marredpally	R.K.Puram	11KV	C-VI	16.10	22.02	05.52	EL	Tree branches fallen tree branches on lines at R.K.Puram	At 21:35Hrs partial fdr charged & remaining loads added on 11KV AOC feeder	
1	HYD C	Fever Hospital	Sri Ram Nagar	11KV	II	06.20	08.20	02.00	EL	Tree branches fallen on lines at Chary Lange	No
2		Golconda	Darga OH	11KV	VII	16.36	19.30	02.54	EL	Cable fault & Braker problem at SS	Arranged B/F on 11KV O.U Colony fdr