

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No. of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | 4 | | 4 | | 4 | | | |
| 6 | RR(N) | 54 | 550 | 2 | 9 | 2 | 9 | 2 | 9 | | | |
| 7 | RR(E) | 168 | 403 | | 5 | | 5 | | 5 | | | |
| 8 | Hyd | 194 | 1044 | | 4 | | 4 | | 4 | | | |
| | Total | 606 | 3055 | 2 | 22 | 2 | 22 | 2 | 22 | 0 | 0 | |

Rural

| S.No | Circle | No. of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|--------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-----------------------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 6 | 1 | 6 | 1 | 6 | 1 | | | |
| 2 | NLG | 144 | 988 | | 9 | | 9 | | 9 | | | |
| 3 | MDK | 107 | 933 | 3 | 5 | 2 | 4 | 2 | 4 | 1 | 1 | 1No. 33KV Still & 1No. 11KV Still |
| 4 | SDPT | | | 1 | 5 | 1 | 5 | 1 | 5 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 10 | 20 | 9 | 19 | 9 | 19 | 1 | 1 | |
| | Grand Total | 1082 | 6468 | 12 | 42 | 11 | 41 | 11 | 41 | 1 | 1 | |

TSSPDCL - LMRC / Corporate office

Date: 10.10.19

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|-------------------------------------|-----------------------|--|
| 1 | MBNR | Kodangal | Kodangal | 33KV | Vikarabad | 04.35 | 07.35 | 03.00 | EL | No visible fault | Kodangal | No |
| 2 | | Kodangal | Peddandandigama | 33KV | Vikarabad | 15.25 | 18.30 | 03.05 | EL | 2No Insulators replaced at Narsapur | Peddandandigama | No |
| 3 | | Balanagar | G.R Cable | 33KV | Jadcherla | 03.20 | 07.45 | 04.25 | EL | Isolator opened at Ranga Reddyguda | G.R Cable | No |
| 4 | | Ghanapur | Lattupally | 33KV | Nagarkurnool | 13:56 | 15:51 | 1:55 | EL | Conductor snapped | Lattupally | Alternate Supply Arranged from 132KV Nagarkurnool at 15:51Hrs. |
| 5 | | Wanaparthy | Peddmandadi | 33KV | Wanaparthy | 10:05 | 17:51 | 7:46 | EL | 33KV Jumper cut | Peddmandadi | Alternate Supply Arranged from 33KV Kothakota at 17:45Hrs. |
| 6 | | Kothur | Sangem | 33KV | Shadnagar | 13.35 | 15.45 | 02.10 | EL | Conductor snapped at AP Darga | Sangem | No |
| 1 | MDK | Zaheerabad | Zaheerabad | 33KV | Zaheerabad | 15:00 | 16:55 | 1:55 | | Insulator failed | Zaheerabad | No |
| 2 | | Bollaram | Agarwal Globle Steel | 33KV | Patancheru | 13.45 | 17.05 | 03.20 | | Tree braches fallen on the line | Agarwal Globle Steel | No |
| 3 | | Narayankhed | Kalher | 33KV | Jogipet | 19.25 | Still | | | | Kalher | No |
| 1 | SDPT | Thukkapur | Dom mata | 33KV | Gajwel | 17:40 | 19:20 | 1:40 | | Insulator failed | Dom mata | No |
| 1 | RR N | 132KV Medchal | Kompally | 33KV | Medchal | 15:05 | 17:25 | 2:20 | | No visible fault | Kompally | No |
| 2 | | 132KV Medchal | Santha Bio Tech | 33KV | Medchal | 13.25 | 15.40 | 02.15 | | No visible fault | Santha Bio Tech | No |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | MBNR | Ediganipally | Nandigama | 11KV | Jadcherla | 08.00 | 12.00 | 04.00 | | 11KV Disc failed near SS | No |
| 1 | NLG | Pamanagundla | Pittampally | 11KV | Nalgonda | 4:00 | 8:30 | 4:30 | E/L | 11 KV Line Jumper cut | No |
| 2 | | Edulur | Naragudem | 11KV | Nalgonda | 04.00 | 08.00 | 04.00 | E/L | 11 KV Line Jumper cut | No |
| 3 | | Narsingbatla | Chenugudem | 11KV | Nalgonda | 04.00 | 08.00 | 04.00 | E/L | AB switch Problem | No |
| 4 | | Jammigadda | Kesaram | 11KV | Suryapet | 08.00 | 10.30 | 02.30 | E/L | 11KV Insulator failed | No |
| 5 | | Penpahad | N Annaram | 11KV | Suryapet | 07.00 | 09.15 | 02.15 | E/L | 11KV Jumper cut | No |
| 6 | | Gaddipally | Gaddipally | 11KV | Huzurnagar | 09.30 | 10.45 | 01.15 | E/L | 11KV Line snapped | No |
| 7 | | Paladugu | Duppally | 11KV | Bhongir | 04.30 | 10.30 | 06.00 | EL/OL | 11KV Insulator failed nearDuppally (V) | No |
| 8 | | Jangam | Puttapaka | 11KV | Choutuppal | 02.00 | 09.20 | 07.20 | EL | 11KV Insulator failed near Puttapaka (V) | No |
| 9 | | Jublakpally | Jublakpally | 11KV | Choutuppal | 4:00 | 9:40 | 5:00 | EL | 11KV Insulator failed near Mallareddy Well (V) | No |
| 1 | MDK | Ismailkhan Pet | Industrial | 11KV | Sangareddy | 15:40 | 19:37 | 3:57 | | Insulator failed | No |
| 2 | | Inole | Sathyasai WW | 11KV | Patancheru | 15.30 | 16.30 | 01.00 | | AB switch failed | No |
| 3 | | Patancheru Town | Shanthinagar | 11KV | Patancheru | 09.55 | 11.05 | 01.10 | | 11KV Cable kit failed | No |
| 4 | | Bollaram - II | Rupa | 11KV | Patancheru | 13.41 | 15.04 | 01.23 | | Insulator failed | No |
| 5 | | Gundla Machnoor | Industrial | 11KV | Jogipet | 15:25 | 5:00 | 13:35 | | Insulator failed | No |
| 1 | SDPT | Thotapally | Thotapally (R) | 11KV | Husnabad | 17:20 | 19:30 | 2:10 | | Due to rain tree branches fallen | No |
| 2 | | Gagillapur | Gagillapur Agl | 11KV | Husnabad | 21.06 | 22:30 | 1:24 | | Due to rain insulator failed | No |
| 3 | | Guruvannapet | Guruvannapet | 11KV | Husnabad | 14.30 | 15:45 | 1:15 | | Due to rain tree branches fallen | No |
| 4 | | Thotapally | Thotapally | 11KV | Husnabad | 17.34 | 18:54 | 1:20 | | Due to rain | No |
| 5 | | Gurjakunta | Vechareni | 11KV | Husnabad | 15:50 | 17.35 | 1:45 | | Jumper cut | No |
| 1 | RR S | IIIT | Jayabheri | 11KV | Gachibowli | 14:45 | 16:00 | 1:15 | | 11KV Pin insulator failed | No |
| 2 | | Papireddy Colony | Premnagar | 11KV | Gachibowli | 15.17 | 17.00 | 01.43 | | 11KV Disc failed | No |
| 3 | | IJM | IX th Phase | 11KV | Kondapur | 18.10 | 19.11 | 01.01 | | 11KV Disc failed | No |
| 4 | | ESCI | Lumbini Park | 11KV | Kondapur | 14.51 | 16.01 | 01.10 | | No visible fault | No |
| 1 | RR N | Subhash Nagar | Padma Nagar | 11KV | Medchal | 16:02 | 17:01 | 0:59 | | No visible fault | No |
| 2 | | Subhash Nagar | Jairam Nagar | 11KV | Medchal | 16.02 | 17.30 | 01.28 | | Kite stick fallen on the 11KV Line at Rukmini Estate | No |
| 3 | | HMT | Quthbullapur | 11KV | Medchal | 14.50 | 16.20 | 01.30 | | Tree fallen on the 11KV line at Quthbullapur | No |
| 4 | | HMT | Manikya Nagar | 11KV | Medchal | 14.47 | 16.37 | 01.50 | | 11KV Pin insulator failed at Chintal | No |
| 5 | | Petbasheerabad | Balaji Hospital | 11KV | Medchal | 16.20 | 18.25 | 02.05 | | Tree fallen on the 11KV line at Balaji Hospital | No |
| 6 | | Petbasheerabad | Vaishnavi Enclave | 11KV | Medchal | 17.30 | 18.55 | 01.25 | | Tree fallen on the 11KV line at Harsha Hospital | No |
| 7 | | Subhash Nagar | Bank Colony | 11KV | Medchal | 16.05 | 20.20 | 04.15 | | 11KV Jumper cut SBI Bank at government school and 11KV line cut at the true value | No |
| 8 | | Kandlakoya | KV Reddy Nagar | 11KV | Medchal | 15.15 | 16.25 | 01.10 | | Tree fallen on the 11KV line at EMRI | No |
| 9 | | Vemana Colony | friends colony | 11KV | Kukatpally | 20:11 | 21:46 | 1:35 | | 11KV Disc failure | No |
| 1 | RR E | Vinayak Nagar | RK Nagar | 11KV | Sainikpuri | 15:13 | 16:34 | 1:21 | | 11KV Pin Insuletor fail at Dayanand Nagar Railway Station | No |
| 2 | | Keesara | Bogaram | 11KV | Keesara | 14.50 | 15.50 | 01.00 | | 11KV Pin Insulator failed at Reddy Gudem | No |
| 3 | | Rampally Dayara | Kareemguda | 11KV | Keesara | 14.50 | 16.10 | 01.20 | | 11KV Post of insulator failed at Kareemguda Road | No |
| 4 | | Chakripuram | Simhapuri | 11KV | Keesara | 14.50 | 16.43 | 01.53 | | 11KV Jumper cut at Simhapuri Colony | No |
| 5 | | Singapur | Singapur-2 | 11KV | Keesara | 15:45 | 16:35 | 0:50 | | 11KV Pin Insulator failed at Singapurtownship A-17 Block | No |
| 1 | HYD N | Macha Bollaram | Sai Reddy Nagar | 11KV | C-VI | 14.45 | 16.08 | 01.23 | EL | No visible fault | No |
| 2 | | Prashanth Nagar | Ganesh Kanta | 11KV | VI | 15:10 | 16:20 | 1:10 | OL-Rph | Big tree fallen on lines at Cheruvu Katta | No |
| 3 | | Hakimpet | Risala Bazar | 11KV | C-VI | 15:45 | 17:05 | 1:20 | All Indication | No visible fault | No |
| 1 | HYD C | Bathkammakunta | D.D Colony | 11KV | II | 15.55 | 17.20 | 01.25 | EL | DTR fault at Indra Govind Apts | No |