

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	3	7	3	7	3	7			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		13		13		13			
	Total	606	3055	3	22	3	22	3	22	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988		11		11		11			
3	MDK	107	933	1		1		1				
4	SDPT			2	9	2	9	2	9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	22	5	22	5	22	0	0	
	Grand Total	1082	6468	8	44	8	44	8	44	0	0	

TSSPDCL - LMRC / Corporate office

Date: 11.10.19

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/33KV Palkonda	Kodur	33KV	Mahabubnagar	08.57	10.30	01.33	E/L	Tree fallen on the line	Kodur	No
2		Makthal	Maganoor	33KV	Narayanapet	07.20	10.50	03.30	E/L	Tree branch fallen on the 33KV line	Maganoor	No
1	MDK	Sadasivapet	Koheer	33KV	Sangareddy	2:45	9:05	6:20		Conductor snapped	Koheer	No
1	SDPT	Shanigaram	Koheda	33KV	Husnabad	19:25	0:35	5:10		Insulator failed near Koheda	Koheda	No
2		Shanigaram	Ramachandrapur	33KV	Husnabad	19.50	05.15	09.25		Pin insulator failed near Guggilla Village	Ramachandrapur	No
1	RR N	132KV Chintal	Jagathgirigutta	33KV	Medchal	11:55	14:12	2:17		No visible fault	Jagathgirigutta	No
2		132KV Chintal	UMCC	33KV	Medchal	11.55	14.12	02.17		No visible fault	UMCC	No
3		132KV Medchal	Keshavaram	33KV	Medchal	15.43	20.50	05.07		33KV Pin insulator failed at 132KV Medchal SS Back side	Keshavaram	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Annasagar	Annasagar	11KV	Jadcherla	09.20	13.50	04.30		11KV Insulator failed near Ravulapally	No
2		Karkonda	Fathepur	11KV	Jadcherla	10.00	11.34	01.34		11KV Insulator failed near Palagadda	No
1	NLG	Arlagaddagudem	Suraram	11KV	Nalgonda	8:00	10:30	2:30	EL	11KV Line jumper cut	No
2		Athmakur(S)	Athmakur(S) AGL	11KV	Suryapet	11.00	13.30	02.30	EL	Insulator failed	No
3		Phanigii	Anantharam	11KV	Suryapet	15.00	16.30	01.30	EL	Jumper cut	No
4		Thogarrai	Kuchipudi	11KV	Huzurnagar	04.39	07.40	03.01	OL	Snake fallen on the 11KV line	No
5		Burugadda	Karkayalagudem	11KV	Huzurnagar	08.16	11.15	02.59	EL	11KV Jumper cut	No
6		Sharajipet	Tangutoor	11KV	Bhongir	05.20	09.15	03.55	EL	11KV Insulator failed near Pembarthy Village	No
7		Pamkunta	Singaram	11KV	Bhongir	07.30	12.00	04.30	EL	11KV Insulator failed near Singaram Village	No
8		Bondugula	Godumakunta	11KV	Bhongir	06.00	08.55	02.55	EL	11KV Insulator failed at Surrender reddy well near Godumakunta Village	No
9		Datherpally	Mallapuram	11KV	Bhongir	07.10	09.46	02.36	EL	11KV Insulator failed near Mallapuram Village	No
10		Azeempet	Kanchanapally	11KV	Bhongir	05.00	09.00	04.00	EL	11KV Insulator failed near Boddugudem Village	No
11		Kapraipally	Kapraipally	11KV	Bhongir	7:50	10:55	3:05	EL	11KV Insulator failed near Kapraipally Village	No
1	SDPT	Nagapuri	Pothireddypalli	11KV	Husnabad	16:50	17:50	1:00		Conductor snapped	No
2		Guruvannapet	Tapaspally	11KV	Husnabad	06.10	10.15	04.05		DTR problem	No
3		Gagillapur	Gagillapur Agl	11KV	Husnabad	00.00	11.15	11.15		Heavy gale & wind	No
4		Pandilla	Pandilla Rural	11KV	Husnabad	07.20	08.10	00.50		Heavy gale & wind	No
5		Ramchandrapur	Vinjalpally	11KV	Husnabad	00.00	09.10	09.10		Heavy gale & wind	No
6		Akunoor	Rudraipally	11KV	Husnabad	09.20	10.20	01.00		Insulator failure	No
7		Akkannapet	Gollakunta	11KV	Husnabad	08.00	09.50	01.50		Jumper cut	No
8		Cherial Town	Cherial-Town	11KV	Husnabad	18.50	20.15	01.25		Jumper cut	No
9		Potharam	Mirzapoor	11KV	Husnabad	6:20	9:15	2:55		Jumper cut	No
1	RR N	Subhash Nagar	Meenakshi	11KV	Medchal	16:40	18:10	1:30		11KV Disc failed at Meenakshi	No
2		Athiwelly	Athiwelly	11KV	Medchal	15.35	17.10	01.35		11KV Pin insulator failed at Athiwelly Court	No
3		Medchal	IDA Kandlakoya	11KV	Medchal	15.40	17.45	02.05		Tree fallon on the 11KV line at Oxygen park	No
4		Kandlakoya	Godrej	11KV	Medchal	17.00	18.30	01.30		11KV Pin Insulator failed at Godrej Company	No
5		Laxmapur	Laxmapur	11KV	Medchal	17.50	19.40	01.50		Tree fallon on 11KV line near Laxmapur Village	No
6		Aliabad	Jaganguda	11KV	Medchal	18.15	20.10	01.55		11KV Disc failed at Jaganguda Village	No
7		Devarayamjal	DMC	11KV	Medchal	15:25	19:45	4:20		100KVA AGL DTR failed at Arukalaguda 'X' road	No
1	RR E	Vinayak Nagar	Tankbund	11KV	Sainikpuri	6:28	7:00	0:32		Bird fallen on the 11KV line at Balaram Nagar	No
2		NN Colony	Jai Jawan	11KV	Sainikpuri	02.20	03.20	01.00		Pin insulator failed at Jai Jawan Colony	No
1	HYD N	New Bowenpally	Seetharamapuram	11KV	VI	15.45	17.50	02.05	EL,OL	Tree branches fallen on lines at Seetharamapuram	No
2		Marredpally	Tagore Home	11KV	C-VI	15:45	18:13	2:28	EL	No visible fault	Arranged B/F on 11KV Addagutta & 11KV Hanuman Temple fdrs
3		Macha Bollaram	Father Balaiah Nagar	11KV	C-VI	15:53	17:08	1:15	EL,OL-Bph	No visible fault	No
4		Addagutta	Ambedkar Nagar	11KV	C-VI	15:55	17:30	1:35	EL,OL-Bph	AB Cable fault at Pooja Hotel	No
5		Tirumalagiri	Mangapuram Colony	11KV	C-VI	16:05	18:15	2:10	EL	Tree branches fallen on lines at Opp: Shiva Enclave	No
6		Vasanthapuri	Siripuri	11KV	V	16:13	20:30	4:17	EL	Disc Insulator flash over at Dhobighat DTR	Arranged B/F on 11KV Sheshapahad, 11KV Lalaguda & 11KV Shanthi Nagar feeder
7		R.P Nilayam	Ram Nagar	11KV	C-VI	16:46	19:48	3:02	EL,OL-Yph	Disc Insulator flash over at Kanaka Reddy line AB Switch	No
8		Marredpally	A.O.C.	11KV	C-VI	16.00	21.40	05.40	OL-R&Bph	Tree branches fallen on lines at Opp. SS	No
1	HYD C	S.D Hospital	Khadi Bhandar	11KV	VII	13.40	14.55	01.15	EL,OL-Bph	Pin Insulator flash over at Masoom Apts	No
2		Asif Nagar	Market Yard	11KV	VII	15.18	16.25	01.07	EL,OL-Bph	No Visible Fault	No
3		Chilkalguda	Golconda X-Roads	11KV	II	16.20	18.10	01.50	EL,OL-Rph	Tree branches fallen on lines at Weley Church	No
4		Indira Park	Domalguda	11KV	I	16:30	19:25	2:55	EL	Pin Insulator flash over at Saketh Enclave	Arranged B/F on 11KV Kuchipudi & 11KV Brand Factory feeders
5		Bathkammakunta	D.D Colony	11KV	II	17.45	18.50	01.05	OL-Rph	Disc Insulator flash over at Praveen Residency	No