

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		6		6		6			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		3		3		3			
	Total	606	3055	0	11	0	11	0	11	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		8		8		8			
3	MDK	107	933	1		1		1				
4	SDPT			1	1	1	1	1	1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	11	3	11	3	11	0	0	
	Grand Total	1082	6468	3	22	3	22	3	22	0	0	

TSSPDCL - LMRC / Corporate office

Date: 13.10.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Kosgi	Surayapally	33KV	Narayanpet	16.55	19.30	02.35	E/L	Due to Jumper Cut		NO
1	MDK	Gummadidala	GPSS-2	33KV	Patancheru	14.10	15.15	01.05		B/D Due to tree branch fallen on the line		-
1	SDPT	Chandlapur	Vitlapur	33KV	Siddipet	15.50	18.25	02.35		Insulator Fail		-

TSSPDCL - LMRC / Corporate office

Date: 13.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Konded	Chinna Adirala	11KV	Jadcherla	04.10	08.00	03.50		11KV Jumper cut near Chinna Adirala	-
2		Udithal	Udithal	11KV	Jadcherla	14.00	16.00	02.00		11KV Jumper cut near Veerannapaly	-
1	NLG	Nemmani	Melakunta	11KV	Nalgonda	07.00	09.00	02.00	EL	Bird died on line	-
2		Gaddipally	Medaram	11KV	Huzurnagar	03.30	06.30	03.00	EL	11 KV LINE SNAPPED	-
3		N B Gudem	Redlakunta	11KV	Huzurnagar	05.00	07.30	02.30	EL	11 KV INSLATER FAILED	-
4		Anatharam	Hanmapuram	11KV	Bhongir	06.05	10.27	04.22	EL	11 kv Insulator Failed at Hussainabad Near Bhongir Town	-
5		Nandanam	Nagireddypally	11KV	Bhongir	03.00	06.05	03.05	EL	11 kv Disc Failed Near Yerrambelli Village	-
6		Jublakpally	Jublakpally	11KV	Choutuppal	04.00	07.00	03.00	EL	11 kv Insulator Failed at Kota Mallareddy well Near Jublakpally Village	-
7		Jublakpally	Kanumukula	11KV	Choutuppal	06.00	09.48	03.48	EL	15kva DTR Failed Near Kanumukula Village	-
8		Arror	Appareddypally	11KV	Choutuppal	05.00	08.30	03.30	EL	11 kv Insulator Failed Near Appareddypally Village	-
1	SDPT	Ramchandrapur	Varikolu	11KV	Husnabad	10.15	13.50	03.35		Insulator failure, same rectified	-
1	RR N	Kompally	Kompally	11KV	Medchal	09.15	09.40	00.25	BD	11KV Line AB Switch opened at Dulapally X road (100KVA DTR Cable Failed)	-
2		UMCC	RM Nagar	11KV	Medchal	14.50	15.25	00.35	BD	11KV Line AB Switch opened at PP Nagar (11KV Pin Insulator failed)	-
3		Dulapally	Dulapally Village	11KV	Medchal	04.10	04.45	00.35	BD	No Fault	-
4		Gowdawelly	IDA Gowdawelly	11KV	Medchal	14.30	17.00	02.30	BD	Tree fallen on the 11KV Line at Basaragadi Village	-
5		GP Pally	GP Pally	11KV	Medchal	14.10	15.10	01.00	BD	Tree fallen on the 11KV Line at Ayodhya X Road	-
6		GP Pally	Apparel Park	11KV	Medchal	14.35	15.50	01.15	BD	Tree fallen on the 11KV Line near Bio Vista Company	-
1	RR E	Polytechnic	Srinivasapuram	11KV	Habsiguda	23.52	01.30	01.38		11KV Line cut near Babu Rao Hotel & 11KV line AB Switch opened at Babu Rao Hotel	-
2		Polytechnic	P S Colony	11KV	Habsiguda	00.08	01.49	01.41		Line patrolling but no visible fault	-
1	HYD N	Madhapur	Ven-E-Burg	11KV	Banjarahills	11.55	13.35	01.40	EL,OL-Rph	Cable fault at Traffic P.S	Arranged B/F on 11KV Ohri's feeder
2	HYD S	Hyderguda	A.G.Colony	11KV	Charminar	16.10	17.17	01.07	EL	Pin Insulator flash over at P.G.R.Apts	-
3	HYD C	Lake View	N.K.M's Hotel	11KV	Saifabad	21.37	23.00	01.23	All Indication	Cable fault at NKM's Hotel (1No. DTR kept off)	-