

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | | 3 | | 3 | | 3 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | | 1 | | 1 | | 1 | | | |
| | Total | 606 | 3055 | 0 | 4 | 0 | 4 | 0 | 4 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 5 | 1 | 5 | 1 | 5 | 1 | | | |
| 2 | NLG | 144 | 988 | | 3 | | 3 | | 3 | | | |
| 3 | MDK | 107 | 933 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 5 | 4 | 5 | 4 | 5 | 4 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 5 | 8 | 5 | 8 | 5 | 8 | 0 | 0 | |

TSSPDCL - LMRC / Corporate office

Date: 14.10.2019

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|----------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|-----------------------|---|
| 1 | MBNR | Kosgi | Surayapally | 33KV | Narayanpet | 16.56 | 18.40 | 01.44 | E/L | Jumper open at 33KV SS Doulthabad | Kosgi | Alternate Supply Arranged from 33KV Peddanadigama Feeder at 18:40Hrs. |
| 2 | | Nagarkurnool | Telkapally | 33KV | Nagarkurnool | 12.47 | 14.20 | 01.33 | E/L | Due to Insulator Failed | Nagarkurnool | NO |
| 3 | | 220/33KV SS Singotam | Narsaipally | 33KV | Nagarkurnool | 19.19 | 20.02 | 00.43 | E/L | AB Switch opened at 33KV Kodair SS | 220/33KV SS Singotam | Alternate Supply Arranged from 132KV Wanaparthy SS at 20:02Hrs. |
| 4 | | Gadwal | Oil Seeds | 33KV | Gadwal | 11.00 | 11.50 | 00.50 | E/L | Breaker Limb to Bus Isolater B Phase Jumper cut & Bus Isolater to breaker Limb Y Phase jumper cut heavy Spark observed. | Gadwal | Alternate Supply Arranged from 132KV Alampur SS at 11:50Hrs. |
| 5 | | Amangal | Kadthal | 33KV | Shadnagar | 06.43 | 06.53 | 00.10 | E/L | Due to Rain | Amangal | Alternate Supply Arranged from 33KV Mudwin SS at 6:53Hrs. |

TSSPDCL - LMRC / Corporate office

Date: 14.10.2019

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|---------------------------|
| 1 | MBNR | Donoor | Vaspula | 11KV | Jadcherla | 08.08 | 09.50 | 01.42 | | 11KV Jumper Cut Near Vaspula (V) | - |
| 1 | NLG | Ravipahad | Burkacherla | 11KV | Huzurnagar | 05.00 | 07.30 | 02.30 | E/L | 11KV Jumper cut | - |
| 2 | | Siripuram | Vallapuram | 11KV | Huzurnagar | 12.30 | 14.00 | 01.40 | E/L | 11Kv Line Snapped | - |
| 3 | | Nuthankal | Chilpakuntla | 11KV | Suryapet | 05.55 | 07.40 | 01.45 | E/L | 11Kv Insulator failed | - |
| 1 | RR N | Subhash Nagar | Jairam Nagar | 11KV | Medchal | 15.30 | 15.55 | 00.25 | | No Fault | - |
| 2 | | BalajiNagar | Kukatpally | 11KV | Kukatpally | 14.00 | 15.38 | 01.38 | | 11KV lineEndkit failure at pawanbar at KPHB main Road | - |
| 3 | | Gagillapur | Thanda | 11KV | Jeedimetla | 07.00 | 08.45 | 01.45 | | 11KV pin insulator failed at dundigal ring road | - |
| 1 | HYD S | Falaknuma | Fathima Nagar | 11KV | Charminar | 05.12 | 06.18 | 01.06 | EL | Lizard fault on DTR at Urdu School | - |