

Status Report on Breakdowns (Urban / Rural)

Urban

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		2		2		2			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		11		11		11			
8	Hyd	194	1044		8		8		8			
	Total	606	3055	0	23	0	23	0	23	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		14		14		14			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	14	0	14	0	14	0	0	
	Grand Total	1082	6468	0	37	0	37	0	37	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Pamangundla	Pittampally	11KV	Nalgonda	06.00	07.10	01.10	EL	Jumper cut	-
2		Edulur	Parada	11KV	Nalgonda	11.20	13.00	01.40	EL	Insulator failed	-
3		Akaram	Akaram	11KV	Nalgonda	11.40	12.45	01.05	EL	Tree fallen on the line	-
4		Thatipamula	Sri Ram thanda	11KV	Suryapet	05.30	09.00	03.30	EL	Disc Flash over	-
5		Gaddipally	Medaram	11KV	Huzurnagar	00.30	04.40	03.10	EL	11 KV LINE SNAPPED	-
6		Thogarrai	Ganapavaram	11KV	Huzurnagar	09.50	12.50	03.00	EL	11 KV LINE SNAPPED	-
7		Ch.Laxmapur	Malkapur	11KV	Bhongir	04.30	09.00	04.30	EL	11kv Disc Failed	-
8		Kolanpaka	Somaram	11KV	Bhongir	05.30	11.10	05.40	EL	11kv Pin Insulator Faile	-
9		Y.Gutta	Wangapally	11KV	Bhongir	07.15	14.00	06.45	EL	11kv Disc Failed	-
10		Mothkur	Mothkur Rural	11KV	Bhongir	06.00	12.40	06.40	EL	11kv Disc Failed	-
11		Addagudur	Ramaram	11KV	Bhongir	04.00	07.00	03.00	EL	11kv Disc Failed	-
12		Thummalagudem	Bogaram	11KV	Choutuppal	11.05	13.10	02.05	EL	11kv Disc Failed	-
13		MT.Pally	Mogalipaka	11KV	Choutuppal	04.45	09.50	05.05	EL	11kv Pin Insulator Failed	-
14		MT.Pally	MT.Pally	11KV	Choutuppal	11.05	13.20	02.15	EL	11kv Insulator Failed	-
1	RR S	Nanakramguda	N'Widia	11KV	Gachibowli	01.32	02.42	01.10		Due to heavy rain(Line AB-Switch Opened at EKTA Apartmnet)	-
2		ESCI	Prashanti Hill	11KV	Gachibowli	12.38	13.45	01.07		Due to rain, Line petroling, No Visible fault found(LABSO && LABSC at Prashanti Hills caman)	-
1	RR N	ICICI	Bharath Biotech	11KV	Medchal	00.51	07.30	06.39		Bird fallen on the 11KV Line at Genetic Company	-
2		Ravalkole	IDA Ganapathi	11KV	Medchal	16.05	17.15	01.10		Tree fallen on the 11KV Line at Crusher	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR E	Moula-Ali	Mirzalguda	11KV	Sainikpuri	04.20	06.00	01.40		Ground petrolling but no visible fault found (due to Rain/Artisan Naresh, Ramesh)	-
2		Vayupuri	RKH Colony	11KV	Sainikpuri	04.35	05.10	00.35		11Kv Pin Insulator failed at Adhitya Admet (LM Narsihma)	-
3		Uppal	Uppal	11KV	Habsiguda	05.40	06.50	01.10		11KV Pin insulator failed at Vijaypuri colony	-
4		Mallapur 2	AP Colony	11KV	Habsiguda	04.58	05.32	00.34		11KV Post of insulator failed at My flower park	-
5		Nacharam	Mukthametal	11KV	Habsiguda	05.00	06.09	01.09		due to rain & 11KV Jumper cut at road no 9	-
6		IDA Uppal	Devender Nagar	11KV	Habsiguda	08.30	09.50	01.20		11KV Line cut at Noble Hotel	-
7		Chakripuram	Shilpa Nagar	11KV	Keesara	13.15	14.50	01.35		11KV Disc insulator failed at Bapu Reddy Nagar	-
8		Ghatkesar	HPCL	11KV	Keesara	13.00	15.00	02.00		Line patrolling but no visible fault(Due to Heavy rain)	-
9		Narapally	AP Meat	11KV	Keesara	05.15	06.15	01.00		11KV Pin Insulator failed near Nalla Malla Reddy College	-
10		Narapally	AP Meat	11KV	Keesara	08.30	09.48	01.18		11KV Disc failed near Nalla Malla Reddy College	-
11		Nagaram	Bandlaguda	11KV	Keesara	04.58	07.20	02.22		11KV Pin Insulator failed at Weaker Section Colony	-
1	HYD N	Bowenpally	I.A.F	11KV	VI	02.30	03.40	01.10	EL	Tree Banches fallen on lines at I.A.F	-----
2		Marredpally	Tagore Home	11KV	C-VI	05.00	06.12	01.12	EL	Cable Fault	Arranged B/F on 11KV Hanuman Temple fdr
3		Thirumalgiri	Chinna Kamela	11KV	C-VI	05.50	07.00	01.10	EL	Tree banches fallen on lines at Military Area	-----
4		Chinna Thokatta	Hasmathpet	11KV	VI	06.35	07.35	01.00	EL	Faulty 11KV MDF feeder loads	-----
5		Gunrock	M.D.F	11KV	VI	06.35	08.05	01.30	EL	Insulator flash over at Harijan Basti	-----
6		Gunrock	Bowenpally	11KV	C-VI	18.25	19.30	01.05	EL	No Visible Fault	-----
1	HYD S	Ch' Baradari	Fire Station	11KV	III	05.13	07.10	01.57	EL,OL-Bph	Big tree fallen on lines at Eagle Rubbers	-----
1	HYD C	Golconda	Darga Cable	11KV	VII	01.30	02.35	01.05	EL,OL-Bph	No Visible Fault	-----