

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234		1		1		1			
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	0	7	0	7	0	7	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	3		3		3				
2	NLG	144	988		10		10		10			
3	MDK	107	933	2	2	2	2	2	2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	12	5	12	5	12	0	0	
	Grand Total	1082	6468	5	19	5	19	5	19	0	0	

TSSPDCL - LMRC / Corporate office

Date: 21.10.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	G.R Cable	33KV	Jadcherla	11.30	13.50	02.20	E/L	33KV Jumper cut at Rangareddy Guda	Balanagar	NO
2		Wanaparthy	Solipur	33KV	Wanaparthy	02.05	08.30	06.25	E/L&O/L	Pin Binding Failed at Gurkula Patashala & 33KV Jumper Replacement at 132KV Wanaparthy SS	Wanaparthy	Alternate Supply Arranged From 132KV SS Ghanapur at 8:30Hrs.
3		Wanaparthy	Buddaram	33KV	Wanaparthy	14.26	20.24	05.58	E/L	Due to Tree Cutting at Polkepad X Road & Insulator Damaged at 16No Pole at Polkepad	Wanaparthy	NO
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	13.10	16.20	03.10		B/D due to Disk failure at Bilalapur Village.		-
2		Pashamailaram	EPIP	33KV	Sangareddy	05.40	08.30	02.50		B/D due to Conductor snapped		-

TSSPDCL - LMRC / Corporate office

Date: 21.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Eduloor	Munukuntla	11KV	Nalgonda	02.22	07.50	05.28	E/L	HT/LT line melting	-
2		Madugulapally	Madugulapally	11KV	Nalgonda	00.05	06.45	06.40	E/L	HT/LT line melting	-
3		Chandampeta	Mudidandla	11KV	Devarakonda	00.00	08.30	08.30	E/L	Jumper Cut	-
4		Nampally	Peddapuram	11KV	Devarakonda	13.00	16.00	03.00	E/L	11 KV Insulator Failed	-
5		Koduru	Kommala	11KV	Suryapet	03.20	07.10	03.50	E/L	Conductor snapped	-
6		MT.Pally	MT.Pally Agl	11KV	Bhongir	10.30	15.50	05.20	EL	11kv Line snapped near D.B Thanda	-
7		NG.Bandal	Konapur	11KV	Bhongir	06.45	12.00	05.15	EL	3 Phase B/d Single phase ok 11kv Insulator Failed near SS-12	-
8		Golankonda	Golankonda	11KV	Bhongir	06.20	09.40	03.20	EL/OL	11 kv Line Snapped Near Chandepally Village. 3 Phase B/d Single phase ok	-
9		Arror	Gurnathpally	11KV	Choutuppal	04.00	09.15	05.15	EL/OL	11 KV Insulator Failed Near Gurnathpally Village. 3 Phase B/d Single phase ok	-
10		MT.Pally	Mogalipaka	11KV	Choutuppal	11.20	12.10	00.50	EL	11kv Insulator Failed near Mogalipaka Village	-
1	MDK	Athmakur	Manjith	11KV	Sangareddy	15.00	18.00	03.00		B/D due to Tree branches fallen on the line	-
2		Bollaram-I	NCL	11KV	Patancheru	02.55	07.35	04.40		B/D due to Conductor Snapped	-
1	RR S	Nanakramguda	Church	11KV	Gachibowli	13.04	14.12	01.08	BD	AB Cable endy kit failed Near Hanuman temple at Nanakramguda	-
1	RR N	Ravalkole	IDA Ganapathi	11KV	Medchal	00.46	01.38	00.52	EL	11KV Pin Insulator Failed at Monark Company,Rajabollram(11KV Jumper Opened)	-
2		Thurkapally	Thurkapally	11KV	Medchal	12.45	15.15	02.30	EL/OL	11KV Line Replaced at Rice Mill Backside, Thurkapally	-
1	HYD N	Osm. University	Ladies Hostel	11KV	Sec-Bad	06.20	08.00	01.40	EL	Tree branches fallen on lines at Manikeshwara Nagar	-
1	HYD S	C.R.P.F	Balapur	11KV	Charminar	03.10	05.15	02.05	OL	Cable End Kit failed & HT Line snapped at C-Block	Arranged B/F on 11KV Barkas fdr
1	HYD C	Golconda	Mothi Mahal	11KV	Mehdipatanam	21.55	23.20	01.25	EL,OL-R&Bph	AB Cable fault at F.M.Function Hall	Arranged B/F on 11KV M.D.Lines fdr
2		Golconda	Aditya Nagar OH	11KV	Mehdipatanam	23.20	00.25	01.05	EL,OL-Rph	No Visible Fault	-