

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		10		10		10			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		6		6		6			
	Total	606	3055	0	18	0	18	0	18	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	2	1	2	1	2			
2	NLG	144	988		19		19		19			
3	MDK	107	933		8		8		8			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	31	1	31	1	31	0	0	
	Grand Total	1082	6468	1	49	1	49	1	49	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.10.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Nagarkurnool	Telkapally	33KV	Nagarkurnool	21.34	21.35	00.01	O/L	Due to Line Problem	Telkapally	-

TSSPDCL - LMRC / Corporate office

Date: 22.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Marikal	Kanmankalwa	11KV	Jadcherla	02.30	08.20	05.50		11KV Jumper cut near Kothapally	-
2		Marikal	Chakalapally	11KV	Jadcherla	08.40	11.00	02.20		11KV Jumper cut near Nerabathanda	-
1	NLG	Madgulapally	Madgulapally	11KV	Nalgonda	09.15	12.25	03.10	E/L	Tree Fallen on the Line	-
2		Akaram	Akaram	11KV	Nalgonda	16.30	19.00	02.30	E/L	11Kv Jumper Cut	-
3		Avanthipuram	Allagadapa	11KV	Miryalguda	15.22	17.49	02.27	E/L	11Kv Disc failed	-
4		Damarcharla	Damarcharla Rural	11KV	Miryalguda	10.30	11.56	01.26	E/L	11Kv Insulator failed	-
5		Damarcharla	T.V.Gudem	11KV	Miryalguda	07.10	08.00	00.50	E/L	Tree fallen on line	-
6		Thimmapuram	Thimmapuram	11KV	Miryalguda	08.15	09.35	01.20	E/L	11Kv Jumper cut	-
7		Nidmanoor	Bankapuram	11KV	Miryalguda	07.00	08.43	01.43	E/L	11Kv Jumper cut	-
8		Kamareddygudem	Konthalapally	11KV	Miryalguda	14.40	16.10	01.30	E/L	11Kv Disc failed	-
9		Ramadugu	Thimmapuram	11KV	Miryalguda	08.40	10.45	02.05	E/L	Tree fallen on line	-
10		Kasarabadha	Kasarabadha	11KV	Suryapet	09.50	11.50	02.00	E/L	11Kv Jumper cut	-
11		Athmakur(S)	Dacharam	11KV	Suryapet	13.00	15.10	02.10	E/L	11Kv Insulator failed	-
12		Amaravaram	Srinivasapuram	11KV	Huzurnagar	14.00	15.30	01.30	E/L	11Kv Insulator failed	-
13		Thogarrai	Kapugallu	11KV	Huzurnagar	15.00	16.40	01.40	E/L	11KV Disc failed	-
14		Siripuram	Siripuram	11KV	Huzurnagar	12.50	13.50	01.00	E/L	11Kv Line Snapped	-
15		Sirikonda	Lalthanda	11KV	Huzurnagar	15.00	15.00	01.00	E/L	11KV Disc failed	-
16		Anantharam	Anantharam	11KV	Bhongir	09.40	11.00	01.10	E/L	25KVA DTR Failed near Tajpur (V)	-
17		Choutuppal	Lingoigudem	11KV	Choutuppal	04.00	10.15	06.15	E/L	11kv Disc Failed near Lingoigudem (V)	-
18		Choutuppal IPDS	Damera	11KV	Choutuppal	11.10	14.00	02.50	E/L	11kv Insulator Failed near Damera (V)	-
19		Koyyalagudem	Koyyalagudem Agl	11KV	Choutuppal	02.30	07.00	04.30	E/L	11kv Insulator Failed near Koyyalagudem (V)	-
1	MDK	Pati	My Home	11KV	Patancheru	14.00	17.00	03.00		BD due to Tree fallen on line	-
2		Pati	Pati	11KV	Patancheru	14.00	17.00	03.00		BD due to Tree fallen on line	-
3		Pati	Shalimar	11KV	Patancheru	14.00	17.00	03.00		BD due to Tree fallen on line	-
4		Patancheru Town	Town Ind	11KV	Patancheru	14.05	15.10	01.05		BD due to Disk failed	-
5		Patancheru Town	Town Ind	11KV	Patancheru	17.05	18.30	01.25		BD due to Cable kit failed	-
6		Kistareddypet	Industrial	11KV	Patancheru	13.43	14.50	01.07		BD due to Insulator failed	-
7		Gaddapotharam -II	Kistaiahpally Indl.	11KV	Patancheru	15.05	16.25	01.20		BD due to Disk failed	-
8		Gundla Machnoor	Industrial	11KV	Patancheru	15.40	17.54	02.14		BD due to Tree fallen on line	-
1	SDP	Gurjakunta	Vechareni	11KV	SDP	15.20	16.30	01.10		BD, Due to rain	-
2		Nagapuri	Gandikunta	11KV	SDP	07.08	10.05	02.57		BD, Insulator failure	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Kompally	Aparna	11KV	Medchal	17.45	18.11	00.26	BD	Tree fallen on the 11KV Line at HP Petrol Bunk, Kompally main road	-
2		Subhash Nagar	Saibaba Nagar	11KV	Medchal	15.48	17.15	01.27	BD	Tree fallen on the 11KV Line at Vasudha Apartment	-
3		Bowrampet	CoCo-Cola	11KV	Jeedimetla	11.55	12.57	01.02	BD	Tree Branches Fallen On The 11kv Line AT H V colony	-
4		Shameerpet	Shameerpet	11KV	Medchal	11.45	19.00	07.15	BD	11KV Disc Failed at SC Colony,Shameerpet	-
5		Thumkunta	Thumkunta	11KV	Medchal	14.20	19.35	05.15	BD	11KV Pin Insulator Failed and replaced at Gayathri Mata temple,Thumkunta	-
6		Gowdawelly	Ayodhya	11KV	Medchal	14.05	15.35	01.30	BD	11KV Disc failed at Gowdavelly Village	-
7		Athiwelly	PHI	11KV	Medchal	16.50	18.10	01.20	BD	11KV Disc Failed at PHI Company	-
8		Gowdawelly	IDA	11KV	Medchal	14.10	15.25	01.15	BD	Tree fallen on the 11KV Line at HP Petrol Bunk, Basaragadi Village	-
9		Kandlakoya	KV Reddy Nagar	11KV	Medchal	14.50	16.00	01.10	BD	Tree fallen on the 11KV Line at Prestiage Park	-
10		Shameerpet	Nalsar	11KV	Medchal	15.32	16.15	00.43	BD	Tree fallen on the 11KV Line at Old KLR College Beside	-
1	RR E	CRPF	CRPF Non Residential	11KV	Keesara	13.10	15.20	02.10		11KV Jumper cut & HG Fuse failed at CRPF Yard	-
2		Nagaram	S N colony	11KV	Keesara	10.53	11.34	00.41		Tree branches fallen on 11kv line at Poles Company	-
1	HYD N	H.M.T	Sri Sai Colony	11KV	VI	13.00	14.01	01.01	EL,OL-Rph	Tree branches fallen on lines at HMT Tractors Factory	Arranged B/F on 11KV A.O.L feeder
2		Film Nagar	B.V.Bhavan	11KV	X	15.55	16.58	01.03	EL,OL	Tree branches fallen on lines at B.V.Bhavan	-----
3		Prashasan Nagar	Nandagiri Hills	11KV	X	17.03	18.40	01.37	EL,OL	End Kit failed at Guru Brahma Nagar	-----
1	HYD S	Kandikalgate	Kandikalgate	11KV	III	11.36	12.50	01.14	EL,OL-R&Bph	2No.top Jumpers cut, 2No. HG fuses blown off at Tallakunta Govt.Hospital, 2No.top Jumpers cut & 2No. Brass Patties cut at National High School	-----
2		C.R.P.F	C.R.P.F	11KV	III	16.20	18.47	02.27	EL	Breaker Problem at SS	Arranged B/F on 11KV Keshavagiri feeder
1	HYD C	Golconda	Darga OH	11KV	VII	00.05	02.44	02.39	EL	Post type Insulator flash over Gummas	Arranged B/F on 11KV O.U Colony feeder