

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	3	1	3	1	3			
7	RR(E)	168	403		4		4		4			
8	Hyd	194	1044		5		5		5			
	Total	606	3055	1	12	1	12	1	12	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				1		1		1			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	5	0	5	0	5	0	0	
	Grand Total	1082	6468	1	17	1	17	1	17	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.10.2019

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	Shameerpet	33KV Leo Meridian	33KV	Medchal	05.50	07.00	01.10		Line Patrolling (No Fault)	33KV Leo Meridian	-

TSSPDCL - LMRC / Corporate office

Date: 23.10.2019

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Velugupally	Pasnoor	11KV	Suryapet	08.00	10.05	02.05	E/L	Insulator failed	-
2		Athmakur(S)	Athmakur(S) AGL	11KV	Suryapet	09.00	11.30	02.30	E/L	Jumper cut	-
3		Gaddipaly	Kuthubushapur	11KV	Huzurnagar	14.30	17.00	02.30	EL	Due to 11kv jumper cutted	-
4		Pamanagundla	Pittampally	11KV	Nalgonda	09.00	11.30	02.30	EL	11 KV Line Jumper Cut	-
1	SDP	Pandilla	Kunchanpally	11KV	Husnabad	18.35	19.05	00.30		BD,Jumper cut	-
1	RR N	Chintal	Ganesh Nagar	11KV	Medchal	16.10	17.30	01.20		Tree fallen on the 11KV Line at Ganesh Apartment	-
2		Gowdawelly	Ayodhya	11KV	Medchal	09.30	10.40	01.10		Tree fallen on the 11KV Line at Saketh Venture	-
3		Laxmapur	MC Pally	11KV	Medchal	14.45	15.45	01.00		15KVA T/F failed at Dharam Foultry Farm	-
1	RR E	Uppal	Raghavendra nagar	11KV	Habsiguda	17.00	18.20	01.20		End kit fail at SR Height Dharmapuri colony	-
2		NGRI	Scientist colony	11KV	Habsiguda	17.00	17.55	00.55		Tree branches fallen on 11kv line near NMDC Opp Main road	-
3		Nacharam Indore	Ramreddy nagar	11KV	Habsiguda	14.46	18.05	03.19		Disk insulator fail at Hanuman temple	-
4		Sai nagar	Maruthi nagar	11KV	Habsiguda	17.15	18.45	01.30		Bird fallen on 11kv line at Sitari nagar	-
1	HYD N	Lalaguda	Lalapet	11KV	V	01.00	02.25	01.25	EL	Disc Insulator flash over at Lalapet main road	-
2		Osm.University	Ladies Hostel	11KV	V	16.55	18.25	01.30	EL	Tree branches on line at Cycle Stadium	-
1	HYD S	Gosha Mahal	Hindi Nagar	11KV	IX	00.36	01.39	01.03	EL,OL-R&Bph	Cable fault	Arranged B/F on 11KV Seetharampet feeder
2		Ch' Baradari	Gazi Banda	11KV	III	04.17	06.26	02.09	EL	Cable End Kit failed at Gazi Banda Kabrasthan	-----
1	HYD C	Industrial Area	Azamabad Key SS Cable	11KV	II	00.50	01.57	01.07	EL,OL-R&Bph	Cable fault	Arranged B/F on 11KV Shastry Nagar fdr