

## Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban |      | Breakdowns occurred during the day |      | Attended during the day |      | Time taken for restoring the supply |      |                                |      | Remarks (Pending) |
|------|--------|------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
|      |        | 33KV                         | 11KV | 33KV                               | 11KV | 33KV                    | 11KV | Rectified (Within 24 Hours)         |      | Not Rectified (Above 24 Hours) |      |                   |
|      |        |                              |      |                                    |      |                         |      | 33KV                                | 11KV | 33KV                           | 11KV |                   |
| 1    | MBN    | 18                           | 107  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 2    | NLG    | 22                           | 358  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 3    | MDK    | 97                           | 359  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 4    | SDPT   |                              |      |                                    |      |                         |      |                                     |      |                                |      |                   |
| 5    | RR(S)  | 53                           | 234  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 6    | RR(N)  | 54                           | 550  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 7    | RR(E)  | 168                          | 403  |                                    | 1    |                         | 1    |                                     | 1    |                                |      |                   |
| 8    | Hyd    | 194                          | 1044 |                                    | 1    |                         | 1    |                                     | 1    |                                |      |                   |
|      | Total  | 606                          | 3055 | 0                                  | 2    | 0                       | 2    | 0                                   | 2    | 0                              | 0    |                   |

Rural

| S.No | Circle      | No.of Feeders Existing Rurals |      | Breakdowns occurred during the day |      | Attended during the day |      | Time taken for restoring the supply |      |                                |      | Remarks (Pending) |
|------|-------------|-------------------------------|------|------------------------------------|------|-------------------------|------|-------------------------------------|------|--------------------------------|------|-------------------|
|      |             | 33KV                          | 11KV | 33KV                               | 11KV | 33KV                    | 11KV | Rectified (Within 24 Hours)         |      | Not Rectified (Above 24 Hours) |      |                   |
|      |             |                               |      |                                    |      |                         |      | 33KV                                | 11KV | 33KV                           | 11KV |                   |
| 1    | MBN         | 107                           | 849  | 1                                  |      | 1                       |      | 1                                   |      |                                |      |                   |
| 2    | NLG         | 144                           | 988  |                                    | 3    |                         | 3    |                                     | 3    |                                |      |                   |
| 3    | MDK         | 107                           | 933  |                                    | 2    |                         | 2    |                                     | 2    |                                |      |                   |
| 4    | SDPT        |                               |      |                                    | 2    |                         | 2    |                                     | 2    |                                |      |                   |
| 5    | RR(S)       | 58                            | 396  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 6    | RR(N)       | 38                            | 114  |                                    |      |                         |      |                                     |      |                                |      |                   |
| 7    | RR(E)       | 22                            | 133  |                                    |      |                         |      |                                     |      |                                |      |                   |
|      | Total       | 476                           | 3413 | 1                                  | 7    | 1                       | 7    | 1                                   | 7    | 0                              | 0    |                   |
|      | Grand Total | 1082                          | 6468 | 1                                  | 9    | 1                       | 9    | 1                                   | 9    | 0                              | 0    |                   |

TSSPDCL - LMRC / Corporate office

Date: 25.10.19

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                         | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1    | MBNR   | Maddur              | Damargidda           | 33KV | Narayanapet          | 12.45 | 18.45 | 06.00    | EL               | 2 Nos. Disc insulators failed and replaced | Damargidda            | No                        |

TSSPDCL - LMRC / Corporate office

Date: 25.10.19

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol  | Name of the Division | From  | To    | Duration | Relay Indication | Cause of Breakdown                      | Alternate Supply Arranged                              |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1    | NLG    | Dondapahad         | Vajinepally          | 11KV | Huzurnagar           | 4:00  | 6:15  | 2:15     | EL               | 11KV Line snapped                       | No   |
| 2    |        | Mothkur            | Mothkur Rural        | 11KV | Bhongir              | 09.00 | 11.40 | 02.40    | EL               | 11KV Line snapped near Mothkur Village  | No   |
| 3    |        | Athmakur           | Koratikal            | 11KV | Bhongir              | 09.50 | 10.50 | 01.00    | EL               | 11KV Disc failed near Koratikal Village | No   |
| 1    | MDK    | Inole              | Beyar                | 11KV | Patancheru           | 8:30  | 10:00 | 1:30     |                  | Conductor snapped                       | No   |
| 2    |        | Gundla Machnoor    | Industrial           | 11KV | Patancheru           | 05.14 | 09.30 | 04.16    |                  | Insulator failed                        | No   |
| 1    | SDPT   | Pandilla           | Pandilla Rural       | 11KV | Husnabad             | 10:30 | 12:30 | 2:00     |                  | Disc failed                             | No   |
| 2    |        | Bekkal             | Kutigal              | 11KV | Husnabad             | 07.00 | 13.20 | 06.20    |                  | Insulator failed                        | No   |
| 1    | RR E   | Kushaiguda         | Saibaba Temple       | 11KV | Sainikpuri           | 0:50  | 1:50  | 1:00     |                  | 11KV Jumper cut                         | No   |
| 1    | HYD N  | Chilkaiguda        | Pragatools           | 11KV | V                    | 04.11 | 05.35 | 01.24    | EL,OL-Rph        | Jumper cut at Raja Laxmi Housing Colony | Arranged B/F on 11KV Rajalaxmi Housing Corporation for |